

ZION STATION

RADIOACTIVE WASTE AND ENVIRONMENTAL MONITORING

Annual Report 1979

EBERLINE INSTRUMENT CORPORATION
Midwest Facility

MARCH 1980

8 004140

322
306

ENVIRONMENTAL SAMPLING AND ANALYSIS PROGRAM

for

ZION GENERATING STATION
Commonwealth Edison Company

ANNUAL REPORT 1979

EBERLINE INSTRUMENT CORPORATION

Midwest Facility

Compiled by:

Kathryn A. Kohl
Kathryn A. Kohl, Administrator

Reviewed and
Approved by:

Chandrasekaran, E. S.
Chandrasekaran, E. S., Manager

Date: 3-14-80

TABLE OF CONTENTS

	<u>PAGE</u>
Introduction.....	1
Summary.....	2
1.0 Effluents	
1.1 Gaseous.....	3
1.2 Liquid.....	3
2.0 Solid Waste.....	3
3.0 Dose To Man	
3.1 Gaseous Effluent Pathways.....	4
3.2 Liquid Effluent Pathways.....	5
4.0 Site Meteorology.....	5
5.0 Environmental Monitoring.....	6
5.1 Gamma Radiation.....	6
5.2 Airborne I-131 and Particulate Radioactivity.....	6
5.3 Aquatic Radioactivity.....	6
5.4 Milk.....	7
6.0 Analytical Procedures.....	7
7.0 Milch Animal Census.....	7
Appendix I - Figures and Data Tables.....	8
Station Releases	
Gaseous Effluents.....	9
Liquid Effluents.....	15
Solid Waste Shipments.....	27
Isodose and Concentration Contours.....	41
Dose Calculation Parameters.....	45
Dose Calculations.....	46
Environmental Monitoring	
Locations of Fixed Environmental Radiological Stations.....	48
Standard Radiological Monitoring Program.....	49
Summary Tables - Environmental.....	52
Gamma Radiation Measurements (TLD).....	56
Appendix II - Meteorological Data.....	57

INTRODUCTION

Zion Station, adjacent to Lake Michigan in Zion, Illinois, consists of two Westinghouse pressurized water reactors, each with a generating capacity of 1100 MWE (3250 MWT) at full power. The Zion plant has been designed to minimize radioactive releases to the environment. The Technical Specifications limit radionuclide releases to values that will insure that radiation doses attributable to the operation of the plant will satisfy the "as low as practicable" philosophy.

Various environmental samples are collected at indicator and background stations and analyzed to determine if changes in radioactivity levels may be attributable to the operation of the plant. If significant changes due to the plant are measured, these changes are correlated with effluent releases. The results of these analyses are summarized on a monthly basis and reported to the Nuclear Regulatory Commission annually.

SUMMARY

Gaseous and liquid effluents for the period remained below the Technical Specification limits. Calculations of environmental concentrations based on effluent and meteorological data for the period indicate that consumption by the public of radioactive materials attributable to the plant are unlikely to exceed regulatory limits. Gamma radiation exposure from noble gases released to the atmosphere represented the critical pathway for the period with a maximum individual dose estimated to be 0.2 mrem for the year, when a shielding and occupancy factor of 1.4 is assumed. Environmental monitoring results confirm that dose via other pathways was not significant.

1.0 EFFLUENTS

1.1 GASEOUS EFFLUENTS TO THE ATMOSPHERE

Measured concentrations and isotopic composition of noble gases, radioiodine, and particulate radioactivity released to the atmosphere during the year, are listed in Table 1.1-1. A total of $3.41 \text{ E}+04$ curies of noble gases was released with a maximum release rate of $2.1 \text{ E}+04 \text{ } \mu\text{Ci/sec}$ during any one-hour period.

A total of $6.19 \text{ E}-03$ curies of I-131 was released during the year.

A total of $6.12 \text{ E}-02$ curies of beta-gamma emitters and non-detectable amounts of alpha emitters was released as airborne particulate matter.

1.2 LIQUIDS RELEASED TO LAKE MICHIGAN

A total of $1.24 \text{ E}+08$ liters of radioactive liquid wastes containing 2.17 curies (excluding tritium) were discharged from the station. These wastes were released at a maximum monthly average concentration of $1.5 \text{ E}-09 \text{ } \mu\text{Ci/ml}$ which is 12.8% of the Technical Specification release limits for unidentified radioactivity. During the same period, 601 curies of tritium and $6.13 \text{ E} 03$ curies of alpha radioactivity were released. Monthly release estimates and principal radionuclides in liquid effluents are given in Table 1.2-1.

2.0 SOLID RADIOACTIVE WASTES

Solid radioactive wastes were shipped to Richland, Washington; Hanford, Washington; Beatty, Nevada; and/or Barnwell Nuclear Center, South Carolina. The record of waste shipments is summarized in Table 2.0-1.

3.0 DOSE TO MAN

3.1 GASEOUS EFFLUENT PATHWAYS

GAMMA DOSE RATES

Gamma air and whole body dose rates off-site were calculated based on measured release rates, isotopic composition of the noble gases, and meteorological data for the period (Table 3.1-1). Isodose contours of whole body dose are shown in Figure 3.1-1 for the year. Based on measured effluents and meteorological data, the maximum dose to an individual would be 0.2 mrem for the year, with an occupancy or shielding factor of 1.4 included. The maximum gamma air dose was 2.7 mrad.

BETA AIR AND SKIN RATES

The range of beta particles in air is relatively small (on the order of a few meters or less): consequently, plumes of gaseous effluents may be considered "infinite" for purpose of calculating the dose from beta radiation incident on the skin. However, the actual dose to sensitive skin tissues is difficult to calculate because this depends on the beta particle energies, thickness of inert skin, and clothing covering sensitive tissues. For purposes of this report the skin is taken to have a thickness of 0.7 mg/cm² and an occupancy factor of 0.5 is used. The skin dose from beta and gamma radiation for the year was 0.2 mrem.

The air concentrations of radioactive noble gases at the off-site receptor locations are given in Figure 3.1-2. The maximum off-site beta air dose for the year was 0.6 mrad.

RADIOACTIVE IODINE

The human thyroid exhibits a significant capacity to concentrate ingested or inhaled iodine, and the radioiodine, I-131, released during routine operation of the plant, may be made available to man thus resulting in a dose to the thyroid. The principal pathway of interest for this radionuclide is ingestion of radioiodine in milk by an infant. Calculations made in previous years indicate that contributions to doses from inhalation of I-131 and I-133, and I-133 in milk are negligible.

IODINE-131 CONCENTRATIONS IN AIR

The calculated concentration contours for I-131 in air are shown in Figure 3.1-3. Included in these calculations is an iodine cloud depletion factor which accounts for the phenomenon of elemental iodine deposition on the ground. The maximum off-site average concentration is estimated to be 3.1×10^{-3} pCi/m³ for the year.

DOSE TO INFANTS THYROID

The hypothetical thyroid dose to an infant living near the plant via ingestion of milk was calculated. The radionuclide considered was I-131 and the source of milk was taken to be the nearest dairy farm with the cows pastured from May to October. The maximum infant's thyroid dose was 0.0 mrem during the year (Table 3.1-1).

CONCENTRATION OF PARTICULATES IN AIR

Concentrations contours of radioactive airborne particulates are shown in Figure 3.1-4. The maximum off-site average level is estimated to be 2.6×10^{-2} .

SUMMARY OF DOSES

Table 3.1-1 summarizes the doses resulting from releases of airborne radioactivity via the different exposure pathways.

3.2 LIQUID EFFLUENT PATHWAYS

The three principal pathways through the aquatic environment for potential doses to man from liquid waste are ingestion of potable water, eating aquatic foods, and exposure while walking on the shoreline. Not all of these pathways are applicable at a given time or station but a reasonable approximation of the dose can be made by adjusting the dose formula for season of the year or type and degree of use of the aquatic environment. NRC* developed equations were used to calculate the doses to the whole body, lower GI tract, thyroid, bone and skin; specific parameters for use in the equations are given in Table 3.2-1. In general, the values of the parameters used were taken from HERMES**, a report which summarizes the living habits of persons in the North Central U.S. These doses are summarized in Table 3.2-2. No organ dose exceeded 9×10^{-2} mrem for the year.

4.0 SITE METEOROLOGY

A summary of the site meteorological measurements taken during each calendar quarter of the year is given in Appendix II. The data are presented as cumulative joint frequency distributions of 35' level wind direction and wind speed class by atmospheric stability class determined from the temperature difference between the 125' and 35' levels. Data recovery for these measurements was 96%.

*Nuclear Regulatory Commission, Regulatory Guide 1.109 (Rev 1).

**J. F. Fletcher and W. L. Dotson (compilers), "HERMES-A digital Computer Code for Estimating Regional Radiological Effects from the Nuclear Power Industry," USAEC Report HEDL-TME-71-168, Hanford Engineering Development Laboratory, 1971.

5.0 ENVIRONMENTAL MONITORING

Table 5.0-1 provides an outline of the radiological environmental monitoring program as required in current Technical Specifications. This program went into effect in November 1977 and differs from previous programs in the number and types of analyses performed. Tables 5.0-2 to 5.0-5 summarize data for the year.

Except for tables of special interest, tables listing all data are no longer included in the annual report. All data tables are available for inspection at the Station.

Specific findings for various environmental media are discussed below.

5.1 GAMMA RADIATION

External radiation dose from on-site sources and noble gases released to the atmosphere was measured at three indicator and ten reference (background) locations using solid lithium fluoride thermoluminescent dosimeters (TLD). A comparison of the TLD results for reference stations with on-site indicator stations is included in Table 5.1-1.

5.2 AIRBORNE I-131 and PARTICULATE RADIOACTIVITY

Concentrations of airborne I-131 and particulate radioactivity at monitoring locations are summarized in Tables 5.0-2 through 5.0-5. Locations of the samplers are the same as for direct radiation measurements, shown in Figure 5.0-1. Airborne I-131 remained below the LLD of 0.10 pCi/m^3 throughout the year.

Gross beta concentrations ranged from less than 0.01 to 0.08 pCi/m^3 in indicator stations with an average concentration of 0.04 pCi/m^3 . No radioactivity attributable to station operation was detected in any sample.

5.3 AQUATIC RADIOACTIVITY

Water samples were collected weekly from six public water works that draw water from Lake Michigan. The samples are composited and analyzed monthly for gamma emitters and quarterly for tritium. Gamma emitters were in all cases below the limits of detection for the program, and tritium concentrations were within the ranges expected in environmental water.

Cooling water samples are composited, collected weekly, and analyzed for gross beta and tritium concentrations. Some samples contained both gross beta activity and tritium in concentrations above what would be expected in environmental samples. Two samples from Z-23S (Discharge area 1) collected in January contained gross beta activity

of 100 pCi/l and 70 pCi/l. These samples were analyzed by gamma spectrometry as a supplementary analysis and found to contain Cs-134 and Cs-137.

Fish samples were collected from the vicinity of the station, and the edible portions analyzed for gamma emitters. Concentrations of radioactivity in these samples were either below the limits of detection for the program or at levels usually encountered in the environment indicating the presence of no radioactivity due to station operations.

Sediment samples were collected from the areas of the North and South discharges and analyzed for gamma emitters. Gamma radioactivity was below the limit of detection for both of the samples.

5.4 MILK

Milk samples are collected from November through April, and weekly the rest of the year. From May through October the samples are analyzed for I-131 by high-sensitivity methods (iodine chemistry and low level beta counting) and non-grazing season samples are analyzed by gamma counting. Radioiodine remained below the limits of detection throughout the year.

6.0 ANALYTICAL PROCEDURES

A summary of the procedures used for analyzing radioactivity in environmental samples is given in Appendix III of the report for the period January through June 1975. Procedures used during the period covered by this report remain unchanged.

7.0 MILCH ANIMAL CENSUS

There are no milk-producing animals within a five-mile radius of the Zion Generating Station. The closest dairy animals on record are those at Amestead Dairy (Z-32), located just over five miles at 270°. This information was obtained through the Agricultural Extension Office in Grayslake, Illinois.

APPENDIX I
TABLES AND FIGURES

TABLE 1.1-1

REPORT OF RADIOACTIVE EFFLUENTS

DOCKET NOS: 50-295 and 50-304

YEAR: 1979

FACILITY: Zion

I. Airborne Effluents		UNITS	January	February	March	First Quarter	April	May	June	Second Quarter	6 MO TOTAL	PERCENT LIMIT
1. Gross Radioactivity Releases												
a) Total Release		Curies	2,278.23	2,264.70	5,477.88	10,020.81	3,198.56	3,500.84	2,110.91	8,810.31	18,831.12	6.63 E-1
b) Maximum Release Rate (1)		uci/sec	2,611.00	2,611.00	4,900.18	4,900.18	20,931.00	8,258.00	9,395.00	20,931.00	20,931.00	6.63 E-1
c) Isotopes Released		Curies										6.63 E-1
Xe-131m			3.27 E-2	N.D.	25.09	25.12	N.D.	9.62 E-3	6.71 E-3	1.63 E-2	25.14	
Xe-133m			1.47 E-2	N.D.	1.59	1.60	9.50 E-3	N.D.	4.80	4.81	6.41	
Sr-90			N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Kr-81m			N.D.	N.D.	7.56 E-2	7.56 E-2	N.D.	N.D.	N.D.	N.D.	7.56 E-2	
Xe-135			224.10	230.86	367.36	822.32	309.05	349.99	202.84	861.88	1,684.20	
Xe-133			2054.09	2033.83	5083.77	9171.69	2889.50	3150.84	1900.64	7940.98	17,112.67	
Ar-41			N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Kr-85			N.D.	N.D.	N.D.	N.D.	N.D.	2.18 E-6	2.63	2.63	2.63	
												3.12 E-1
d) Percent of quarterly gaseous activity limit (6500 uci/sec)		%	3.02	3.00	7.26	13.28	4.24	4.64	2.79	11.67	24.95	6.63 E-1
												3.12 E-1
2. Iodine Releases												
a) Isotopes Released		Curies										6.63 E-1
I-131			5.48 E-4	1.10 E-4	4.56 E-4	1.11 E-3	1.39 E-3	1.27 E-4	7.58 E-4	2.28 E-3	3.39 E-3	
I-133			2.26 E-4	1.04 E-5	7.28 E-4	9.64 E-4	1.99 E-4	6.39 E-4	2.67 E-5	8.65 E-4	1.83 E-3	
I-135			N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
b) Percent of Iodine 131 Limit		% (2)	--	--	--	--	--	--	--	--	--	6.63 E-1
												3.12 E-1

1. Gross Gaseous Radioactivity Release Maximum Release Rate 60,000 uci/sec.
2. Iodine and Particulate Limits are Total Limit - See Item 14 of this report.

POOR ORIGINAL

TABLE 1.1-1 (Cont.)

REPORT OF RADIOACTIVE EFFLUENTS

DOCKET NOS: 50-295 and 50-304

YEAR: 1979

FACILITY: Zion

I. Airborne Effluents	UNITS	July	August	September	Third Quarter	October	November	December	Fourth Quarter	6 MO TOTAL	TECH SPEC REQ.
1. Gross Radioactivity Releases											
a) Total Release	Curies	3,727.87	4,737.53	4,137.14	12,602.54	1,572.63	558.16	518.94	2,649.73	5,252.27	6.6A31a1
c) Maximum Release Rate (1)	uci/sec	14,755.00	9,503.00	15,216.00	15,216.00	4,227.00	11,272.00	204.00	11,272.00	5,216.00	6.6A31a2
c) Isotopes Released	Curies										6.6A31a3
Xe-131m		3.65E-2	N.D.	N.D.	3.65E-2	144.29	37.69	31.13	213.11	213.15	
Xe-133m		N.D.	2.00E-2	N.D.	2.00E-2	3.99	3.30	3.35	10.64	10.66	
Kr-88		3.80E-2	3.96E-2	23.27	23.35	8.46	N.D.	9.69	18.15	41.50	
Xi-85m		2.30E-3	3.05E-2	N.D.	3.28E-2	N.D.	N.D.	1.56	1.56	1.59	
Xe-133		362.99	473.58	411.26	1,247.83	149.25	55.43	47.92	252.60	1,500.43	
Xe-133		3364.80	4263.86	3702.61	11,331.27	1263.55	457.30	425.29	2146.14	3,477.41	
Ar-41		N.D.	N.D.	N.D.	N.D.	3.09	4.44	N.D.	7.53	7.53	
Kr-85		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
											3.12.1.A.1
d) Percent of quarterly gaseous activity limit (6000 uci/sec)	%	4.94	6.28	5.48	16.70	2.08	0.74	0.69	3.51	20.21	6.6A31a4
											3.12.1.A
2. Iodine Releases											
a) Isotopes Released	Curies										6.6A31b1
I-131		2.00E-5	4.34E-5	9.60E-4	1.02E-3	1.68E-3	1.02E-4	1.18E-6	1.78E-3	2.80E-3	
I-133		2.32E-5	1.71E-3	9.39E-4	2.67E-3	1.36E-4	1.02E-6	3.56E-7	1.37E-4	2.81E-3	
I-135		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
b) Percent of Iodine 131 Limit	%(2)	-	-	-	-	-	-	-	-	-	6.6A31b2
											3.12.1.B

1. Gross Gaseous Radioactivity Release Maximum Release Rate 60,000 uci/sec.

2. Iodine and Particulate Limits are Total Limit - See Item 14 of this report.

TABLE 1.1-1 (Cont.)

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: ZION

Docket Nos: 50-295 and 50-304

YEAR: 1979

1. Airborne Effluents	UNITS	January	February	March	First Quarter	April	May	June	Second Quarter	6 mo. Total	TECH SPEC REF.
3. Particulate Releases											6.6A3f1c1
a) Gross Radioactivity	Curies	4.77E-2	2.98E-4	2.10E-3	5.01E-2	2.94E-3	3.51E-3	5.51E-4	7.00E-3	5.71E-2	6.6A3f1c2
b) Gross Alpha Radioactivity	Curies	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	6.6A3f1c3
c) Isotopes Released	Curies										
Sr-89		----	----	----	4.90E-11	----	----	----	(2)	(2)	
Sr-90		----	----	----	2.00E-11	----	----	----	(2)	(2)	
Co-58		3.12E-6	N.D.	2.58E-4	2.61E-4	1.40E-4	2.01E-4	4.47E-5	3.85E-5	6.46E-4	
Co-60		4.77E-2	1.66E-7	7.09E-4	4.84E-2	1.43E-4	3.66E-4	3.41E-4	8.50E-4	4.93E-2	
Cs-134		1.45E-5	1.01E-4	2.96E-4	4.12E-4	6.96E-5	2.50E-3	8.45E-5	2.65E-3	3.06E-3	
Cs-137		2.41E-5	9.06E-5	4.01E-4	5.16E-4	2.53E-3	1.15E-4	7.99E-5	2.72E-3	3.24E-3	
Mn-54		N.D.	N.D.	3.60E-3	3.60E-5	8.29E-12	1.51E-6	3.37E-7	1.85E-6	3.79E-5	
I-131		9.83E-9	4.84E-6	1.19E-4	1.24E-4	3.02E-4	1.97E-7	2.80E-7	3.50E-6	1.28E-4	
I-133		N.D.	N.D.	3.01E-5	3.01E-5	N.D.	3.28E-4	N.D.	3.28E-4	3.58E-4	
I-135		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Nb-95		N.D.	N.D.	8.39E-5	8.39E-5	3.36E-6	9.08E-8	4.08E-7	3.86E-6	8.77E-5	
Zr-95		N.D.	N.D.	N.D.	N.D.	5.19E-5	N.D.	N.D.	5.19E-5	5.19E-5	
Cr-51		N.D.	N.D.	N.D.	N.D.	2.14E-8	N.D.	N.D.	2.14E-8	2.14E-8	
Ba-La 140		9.66E-8	N.D.	N.D.	9.66E-8	N.D.	N.D.	N.D.	N.D.	9.66E-8	
Mo 99		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Tc 99m		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
NP 239		1.79E-6	N.D.	6.86E-8	1.86E-6	N.D.	N.D.	N.D.	N.D.	1.86E-6	
Na 24		1.10E-6	1.01E-4	3.47E-5	1.37E-5	1.37E-4	2.47E-6	N.D.	2.47E-6	1.40E-4	
Sb 124		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Fe 59		N.D.	N.D.	1.33E-4	1.33E-4	N.D.	N.D.	N.D.	N.D.	1.33E-4	
d) Percent of Particulate	(1) %	----	----	----	----	----	----	----	----	----	6.6A3f1c4
with half lives greater											3.12.1.B
than 2 days											

N.D. = No detectable activity above background

1. Iodine and Particulate limits are expressed as a combined limit-See Item I.4 of this report.

2. Waiting for analysis results - data will be presented in an errata to the Annual Report

TABLE 1.1-1 (Cont.)

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: IION

Docket Nos: 50-293 and 50-304

YEAR: 1979

I. Airborne Effluents	UNITS	July	August	September	Third Quarter	October	November	December	Fourth Quarter	no. Total	TECH SPEC REF.
3. Particulate Releases											
a) Gross Radioactivity	Curies	9.97E-4	3.86E-4	1.43E-3	2.81E-3	4.94E-4	7.21E-4	1.05E-4	1.32E-3	4.13E-3	6A3flc1
b) Gross Alpha Radioactivity	Curies	N.D.	N.D.	N.D.	N.D.	N.D.	1.30E-4	N.D.	1.30E-4	1.30E-4	6A3flc2
c) Isotopes Released	Curies										6A3flc3
Sr-82		- -	- -	- -	N.D.	- -	- -	- -	(2)	(2)	
Sr-90		- -	- -	- -	N.D.	- -	- -	- -	(2)	(2)	
Co-58		3.78E-6	2.77E-8	5.42E-5	8.0E-5	7.46E-7	2.42E-5	N.D.	2.50E-5	8.30E-5	
Co-60		1.98E-4	1.00E-4	2.77E-4	5.75E-4	1.22E-5	4.46E-5	1.50E-5	7.18E-5	6.47E-4	
Cs-134		6.36E-4	2.26E-4	7.16E-5	9.34E-4	4.55E-6	5.20E-6	1.43E-6	1.12E-5	9.45E-4	
Cs-137		1.39E-4	3.93E-5	8.52E-5	2.64E-4	2.51E-5	3.58E-5	2.49E-5	8.58E-5	3.50E-4	
Mn-54		1.32E-6	1.99E-8	6.51E-6	7.85E-6	3.68E-7	5.81E-7	N.D.	9.49E-7	8.80E-6	
I-131		1.29E-9	N.D.	5.31E-5	5.31E-5	3.42E-6	N.D.	1.18E-6	4.60E-6	5.77E-5	
I-133		N.D.	6.18E-6	8.50E-4	8.56E-4	1.27E-4	N.D.	N.D.	1.27E-4	9.83E-4	
I-135		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Nb-95		N.D.	N.D.	3.02E-7	3.02E-7	1.71E-8	4.75E-5	N.D.	4.75E-5	4.78E-5	
Zr-95		N.D.	N.D.	N.D.	N.D.	N.D.	4.54E-5	N.D.	4.54E-5	4.54E-5	
Cr-51		N.D.	6.39E-6	N.D.	6.39E-6	4.74E-6	9.31E-6	5.89E-5	3.0E-5	7.94E-5	
Ba-La 140		N.D.	N.D.	N.D.	N.D.	6.41E-6	N.D.	N.D.	6.41E-6	6.41E-6	
Mo 99		1.84E-5	N.D.	N.D.	1.84E-5	N.D.	N.D.	N.D.	N.D.	1.84E-5	
Tc 99m		N.D.	5.29E-8	N.D.	5.29E-8	3.15E-5	3.59E-5	N.D.	6.74E-5	6.75E-5	
DP 235		N.D.	5.96E-6	N.D.	5.96E-6	6.05E-7	N.D.	3.59E-6	4.20E-6	1.02E-5	
Na 24		1.48E-7	1.39E-6	3.29E-5	1.44E-5	1.64E-6	N.D.	N.D.	1.64E-6	3.60E-5	
Sb 124		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Fe 59		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Percent of Particulate	(1) %	- -	- -	- -	- -	- -	- -	- -	- -	- -	6A3flc4
with half lives greater											12.1.3
than 3 days											

N.D. = No detectable activity above background

1. Iodine and Particulate limits are expressed as a combined limit-See Item I.4 of this report.

2. Waiting for analysis results - data will be presented in an errata to the Annual Report

REPORT OF RADIOACTIVE EFFLUENTS

Docket Nos: 50-295 and 50-304

VEIS: 1979

[illegible]

TABLE 1.2-1.

REPORT OF RADIOACTIVE EFFLUENTS

Unit I Discharge

YEAR: 1979

FACILITY: ZION

Docket Nos: 50-295 and 50-304

II. Liquid Effluents	UNITS	January	February	March	First Quarter	April	May	June	Second Quarter	No. Total	TECH. SPEC
1. Gross Radioactivity*											
a) Total Release	Curies	6.87 E-2	8.55 E-2	1.19 E-1	2.73 E-1	1.98 E-1	7.17 E-2	1.45 E-2	2.84 E-1	5.57 E-1	6.6A7400
b) Average Concentration Released	uci/ml	5.19 E-10	7.14 E-10	9.19 E-10	7.17 E-10	1.55 E-9	5.41 E-10	1.38 E-10	7.43 E-10	7.30 E-10	6.6A7400
c) Maximum Concentration Released	uci/ml	4.28 E-9	2.68 E-8	1.65 E-8	2.68 E-8	2.15 E-8	9.89 E-9	4.39 E-9	2.15 E-8	2.68 E-8	6.6A7400
d) Percent of Tech Spec Limit (5 curies)	%	1.37	1.71	2.38	5.46	3.96	1.43	2.90	8.29	13.75	6.6A7400
2. Tritium (1)											
a) Total Release	Curies	4.42 E+1	3.44 E+1	2.89 E+1	1.08 E+2	3.95 E+1	7.67 E+1	3.08 E+1	1.47 E+2	2.55 E+2	6.6A7400
b) Average Concentration Released	uci/ml	3.34 E-7	2.88 E-7	2.23 E-7	2.82 E-7	3.08 E-7	5.79 E-7	2.94 E-7	3.94 E-7	3.38 E-7	6.6A7400
c) Percent of Tech Spec Limit (3 X 10 ⁻³ uci/ml)	%	1.11 E-2	9.60 E-3	7.43 E-3	9.38 E-3	1.03 E-2	1.93 E-2	9.80 E-3	1.31 E-2	1.13 E-2	6.6A7400
3. Dissolved Noble Gases											
a) Total Release	Curies	3.56 E-2	1.13	1.30 E-1	1.30	5.12 E-2	8.05 E-2	8.06 E-4	1.33 E-1	1.43	6.6A7400
b) Average Concentration Released	uci/ml	2.69 E-10	9.44 E-9	1.00 E-9	3.57 E-9	1.05 E-11	6.08 E-10	7.69 E-12	2.09 E-10	1.89 E-9	6.6A7400

N.D. = No detectable activity above background * Excluding tritium and Dissolved Noble Gases

(1) Minimum detectable tritium is 1 X 10⁻⁵ uc/cc

POOR ORIGINAL

TABLE 1.2-1 (Cont.)

REPORT OF RADIOACTIVE EFFLUENTS

Unit I Discharge

YF/R: 1979

FACILITY: ZION

Docket Nos: 50-295 and 50-304

II. Liquid Effluents	UNIT	July	August	September	Third Quarter	October	November	December	Fourth Quarter	Gro. Total	YF/R: 1979
1. Gross Radioactivity*											
a) Total Release	Curies	5.41E-2	3.45E-2	5.14E-2	1.40E-1	2.65E-1	No Liquid	No Liquid			6.62E-1
b) Average Concentration Released	uci/ml	4.08E-10	2.63E-10	4.01E-10	3.57E-10	7.38E-11	Waste Discharged	Waste Discharged	2.65E-3	1.43E-1	6.62E-1
c) Maximum Concentration Released	uci/ml	7.56E-9	4.72E-9	1.12E-8	1.12E-8	5.41E-9			5.41E-9	1.12E-8	6.62E-1
d) Percent of Tech Spec Limit (5 curies)	%	1.08	6.90E-1	1.03	2.80	5.30E-2			5.30E-2	2.85	6.62E-1
2. Tritium (1)											
a) Total Release	Curies	1.13E+2	1.33E+2	7.64E+1	3.22 E+2	2.44E+1			2.44E+1	3.46E+2	6.62E-1
b) Average Concentration Released	uci/ml	8.53E-7	1.01E-6	5.96E-7	8.20E-7	6.79E-7			2.26E-7	5.23E-7	6.62E-1
c) Percent of Tech Spec Limit (3 X 10 ⁻³ uci/ml)	%	2.84E-2	3.37E-2	1.99E-2	2.73E-2	2.26E-2			7.53E-3	1.74E-2	6.62E-1
3. Dissolved Noble Gases											
a) Total Release	Curies	1.48E-3	1.10E-2	1.13E-2	2.38 E-2	5.23E-3			5.23E-3	2.90E-2	6.62E-1
b) Average Concentration Released	uci/ml	1.12E-11	8.39E-11	8.82E-11	6.11E-11	1.46 E-10	✓	✓	4.87E-11	5.49E-11	6.62E-1

N.D. = No detectable activity above background * Excluding tritium and Dissolved Noble Gases

(1) Minimum detectable tritium is 1 X 10⁻⁵ uc/cc

TABLE 1.2-1 (Cont.)
REPORT OF RADIOACTIVE EFFLUENTS

Unit I Discharge

YF/R: 1979

FACILITY: ZION

Docket Nos: 50-295 and 50-304

I. Liquid Effluents	UNITS	January	February	March	First Quarter	April	May	June	Second Quarter	Gmo. Total	TECH SPEC
1. Gross Alpha Radioactivity											
a) Total Release	Curies	4.12 E-4	3.27 E-3	9.10 E-5	3.77 E-3	1.35 E-3	2.76 E-4	9.19 E-5	1.72 E-3	5.49 E-3	6.63E-3
b) Average Concentration Released	uci/ml	3.11 E-12	2.73E-11	7.03 E-13	1.04 E-11	1.05E-11	2.08 E-12	8.76E-13	4.48 E-12	7.44 E-12	6.63E-3
2. Volume of Liquid Waste to Discharge	Liters	2.42 E+7	1.27 E+7	1.45 E+7	5.14 E+7	1.53 E+7	1.12 E+7	1.42 E+7	4.07 E+7	9.21 E+7	6.63E-3
3. Volume of Dilution Water	Liters	1.32 E+11	1.20E+11	1.29 E+11	3.81 E+11	1.28 E+11	1.32 E+11	1.05 E+11	3.65 E+11	7.46 E+11	6.63E-3
4. Isotopes Released	Curies										6.63E-3
Cs-134		2.00 E-2	7.99 E-3	1.16 E-2	3.96 E-2	1.75 E-2	1.04 E-2	3.09 E-3	3.10 E-2	7.06 E-2	
17 Cs-137		6.63 E-5	N.D.	1.28 E-3	1.34 E-3	5.50 E-4	N.D.	N.D.	5.50 E-4	1.89 E-3	
Cs-137		1.94 E-4	1.36 E-3	3.13 E-3	4.68 E-3	2.27 E-3	2.01 E-3	4.60 E-5	4.32 E-3	9.00 E-3	
Co-60		3.56 E-2	1.76 E-2	1.62 E-2	6.94 E-2	1.31 E-2	1.33 E-2	1.44 E-3	2.78 E-2	9.72 E-2	
Co-60		4.03 E-3	3.23 E-3	2.26 E-2	2.98 E-2	6.61 E-2	1.98 E-2	1.63 E-3	8.75 E-2	1.17 E-1	
Cr-51		6.54 E-3	5.29 E-2	3.27 E-2	9.21 E-2	3.67 E-2	1.80 E-2	5.48 E-3	6.02 E-2	1.52 E-1	
Cr-51		5.94 E-4	N.D.	1.57 E-2	1.63 E-2	3.97 E-2	2.22 E-3	3.56 E-4	4.23 E-2	5.86 E-2	
Zn-65		4.72 E-4	2.37 E-3	2.67 E-3	5.51 E-3	2.15 E-3	1.05 E-3	2.29 E-3	5.49 E-3	1.10 E-2	
Sr-89		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
Sr-90		--	--	--	2.65 E-4	--	--	--	*	*	
Cu-64		--	--	--	3.13 E-4	--	--	--	*	*	
I-132		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
I-132		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	

N.D. = No detectable activity above background

* Waiting for analysis results - data will be presented in an errata to the Annual Report.

POOR ORIGINAL

TABLE 1.2-1 (Cont.)

REPORT OF RADIOACTIVE EFFLUENTS

Unit _____ Discharge

FACILITY: ZION

Docket Nos: 50-295 and 50-304

YEAR: 1979

II. Liquid Effluents	UNITS	July	August	September	Third Quarter	October	November	December	Fourth Quarter	No. Total	TECH. SPEC
4. Gross Alpha Radioactivity							No Liquid	No Liquid			
a) Total Release	Curies	1.85E-4	1.83E-4	2.67E-4	6.35E-4	1.62E-6	Waste	Waste	1.62E-6	6.37E-4	6.63E-4
b) Average Concentration							Discharged	Discharged			6.63E-4
Released	uci/ml	1.40E-12	1.40E-12	2.08E-12	1.61E-12	4.51E-14			1.50E-14	8.23E-13	
5. Volume of Liquid Waste to Discharge	Liters	1.22E+7	1.42E+7	1.54E+7	4.11E+7	4.65E+6			4.65E+6	4.65E+7	6.63E-4
6. Volume of Dilution Water	Liters	1.32E+11	1.31E+11	1.28E+11	3.91E+11	3.60E+10			3.60E+10	4.27E+11	6.63E-4
7. Isotopes Released	Curies										6.63E-4
Cs-134		1.10E-2	5.41E-3	1.61E-2	3.25E-2	4.88E-4			4.88E-4	3.30E-2	
Cs-137		5.96E-3	7.07E-3	1.65E-2	2.91E-2	7.23E-4			7.23E-4	3.02E-2	
Co-60		1.27E-2	5.46E-3	4.89E-3	2.31E-2	1.35E-4			1.35E-4	2.32E-2	
Cr-51		N.D.	4.05E-4	N.D.	4.05E-4	2.30E-4			2.30E-4	6.35E-4	
Fe-54		1.48E-3	7.88E-4	1.60E-4	2.43E-3	7.49E-5			7.49E-5	2.51E-3	
Fe-59		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-60		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-65		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-69		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-70		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-74		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-76		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-78		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-80		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-82		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-84		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-86		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-88		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-90		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-92		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-94		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-96		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-98		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-100		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-102		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-104		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-106		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-108		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-110		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-112		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-114		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-116		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-118		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-120		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-122		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-124		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-126		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-128		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-130		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-132		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-134		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-136		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-138		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-140		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-142		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-144		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-146		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-148		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-150		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-152		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-154		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-156		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-158		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-160		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-162		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-164		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-166		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-168		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-170		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-172		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-174		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-176		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-178		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-180		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-182		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-184		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-186		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-188		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-190		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-192		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-194		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-196		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-198		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-200		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-202		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-204		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-206		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-208		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-210		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-212		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-214		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-216		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-218		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-220		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-222		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-224		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-226		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-228		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-230		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-232		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-234		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-236		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-238		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-240		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-242		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-244		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-246		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-248		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-250		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-252		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-254		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-256		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-258		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-260		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-262		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-264		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-266		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-268		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-270		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-272		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-274		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-276		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-278		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-280		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-282		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-284		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-286		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-288		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-290		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-292		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-294		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-296		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-298		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	
Fe-300		N.D.	N.D.	N.D.	N.D.	N.D.			N.D.	N.D.	

N.D. = No detectable activity above background

* = Waiting for Analysis results- data will be presented in an errata to the Annual Report.

REPORT OF RADIOACTIVE EFFLUENTS

Unit	I	Discharge
1	1	1
2	2	2
3	3	3
4	4	4
5	5	5
6	6	6
7	7	7
8	8	8
9	9	9
10	10	10
11	11	11
12	12	12
13	13	13
14	14	14
15	15	15
16	16	16
17	17	17
18	18	18
19	19	19
20	20	20
21	21	21
22	22	22
23	23	23
24	24	24
25	25	25
26	26	26
27	27	27
28	28	28
29	29	29
30	30	30
31	31	31
32	32	32
33	33	33
34	34	34
35	35	35
36	36	36
37	37	37
38	38	38
39	39	39
40	40	40
41	41	41
42	42	42
43	43	43
44	44	44
45	45	45
46	46	46
47	47	47
48	48	48
49	49	49
50	50	50
51	51	51
52	52	52
53	53	53
54	54	54
55	55	55
56	56	56
57	57	57
58	58	58
59	59	59
60	60	60
61	61	61
62	62	62
63	63	63
64	64	64
65	65	65
66	66	66
67	67	67
68	68	68
69	69	69
70	70	70
71	71	71
72	72	72
73	73	73
74	74	74
75	75	75
76	76	76
77	77	77
78	78	78
79	79	79
80	80	80
81	81	81
82	82	82
83	83	83
84	84	84
85	85	85
86	86	86
87	87	87
88	88	88
89	89	89
90	90	90
91	91	91
92	92	92
93	93	93
94	94	94
95	95	95
96	96	96
97	97	97
98	98	98
99	99	99
100	100	100

FACILITY: ZION

Docket Nos: 50-295 and 50-304

YEAR: 1979

II. Liquid Effluents	UNITS	January	February	March	First Quarter	April	May	June	Second Quarter	Qo. Total	TECH SPEC REF.
SD 124		5.33 E-4	N.D.	5.63 E-3	6.16 E-3	5.23 E-3	5.91 E-4	N.D.	5.82 E-3	1.20 E-2	
I 133		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
SD 110m		6.34 E-5	N.D.	1.87 E-3	1.93 E-3	4.08 E-3	3.49 E-4	N.D.	4.43 E-3	6.36 E-3	
SD 21		6.39 E-4	2.30 E-4	8.10 E-4	1.68 E-3	1.01 E-3	3.10 E-3	N.D.	4.11 E-3	5.79 E-3	
W 187		N.D.	N.D.	7.06 E-4	7.06 E-4	4.53 E-4	N.D.	N.D.	4.53 E-4	1.16 E-3	
CC 57		N.D.	N.D.	9.41 E-5	9.41 E-5	5.60 E-4	N.D.	N.D.	5.60 E-4	6.54 E-4	
TC 59B		N.D.	N.D.	5.92 E-4	5.92 E-4	N.D.	N.D.	N.D.	N.D.	5.92 E-4	
IT 95		N.D.	N.D.	7.54 E-4	7.54 E-4	2.10 E-3	1.52 E-4	N.D.	2.25 E-3	3.00 E-3	
MD 95		N.D.	N.D.	2.17 E-3	2.17 E-3	6.13 E-3	7.66 E-4	1.51 E-4	7.05 E-3	9.22 E-3	
FE 59		N.D.	N.D.	2.77 E-4	2.77 E-4	4.24 E-4	N.D.	N.D.	4.24 E-4	7.01 E-4	
VA 239		N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	N.D.	
X# 253		2.85 E-2	1.07	5.60 E-2	1.15	9.87 E-3	1.43 E-2	6.47 E-4	2.48 E-2	1.17	
X# 135		6.44 E-3	5.66 E-2	7.39 E-2	1.37 E-1	4.14 E-2	6.62 E-2	1.59 E-4	1.08 E-1	2.45 E-1	
X# 133m		6.47 E-4	N.D.	5.04 E-4	1.15 E-3	N.D.	N.D.	N.D.	N.D.	N.D.	

N.D. = No detectable activity above background

POOR ORIGINAL

REPORT OF RADIOACTIVE EFFLUENTS

Docket Nos: 50-295 and 50-304

YEAR: 1979

20

N.D. = No detectable activity above background

YEAR: 1979

POOR ORIGINAL

Docket Nos: 50-295 and 50-304

YEAR: 1979

[illegible]

N.D. = No detectable activity above background * Excluding tritium and Dissolved Noble Gases

(1) Minimum detectable tritium is $1 \times 10^{-5} \text{uc/cc}$

TABLE 1.2-1 (Cont.)

REPORT OF RADIOACTIVE EFFLUENTS

FACILITY: ZION

Docket Nos: 50-295 and 50-304

Unit II Dictionaries

VER: 1979

II. Liquid Effluents		UNITS	January	February	March	First Quarter	April	May	June	Second Quarter	Go. Total	TECH SPEC
4. Gross Alpha Radioactivity												
a) Total Release	Curies		No Liquid	No Liquid	No Liquid	No Liquid	No Liquid	No Liquid	No Liquid	No Liquid	No Liquid	2.61E-06
b) Average Concentration Released	uci/ml		Waste Dischrgd	Waste Dischrgd	Waste Dischrgd	Waste Dischrgd	Waste Dischrgd	Waste Dischrgd	Waste Dischrgd	Waste Dischrgd	Waste Dischrgd	2.61E-06
5. Volume of Liquid Waste to Discharge		Liters										2.61E-06
6. Volume of Dilution Water		Liters										2.61E-06
7. Isotopes Released		Curies										2.61E-06
Cs-134												
Cs-136												
Cs-137												
Cs-138												
Cs-139												
Cs-140												
Cs-141												
Cs-142												
Cs-143												
Cs-144												
Cs-145												
Cs-146												
Cs-147												
Cs-148												
Cs-149												
Cs-150												
Cs-151												
Cs-152												
Cs-153												
Cs-154												
Cs-155												
Cs-156												
Cs-157												
Cs-158												
Cs-159												
Cs-160												
Cs-161												
Cs-162												
Cs-163												
Cs-164												
Cs-165												
Cs-166												
Cs-167												
Cs-168												
Cs-169												
Cs-170												
Cs-171												
Cs-172												
Cs-173												
Cs-174												
Cs-175												
Cs-176												
Cs-177												
Cs-178												
Cs-179												
Cs-180												
Cs-181												
Cs-182												
Cs-183												
Cs-184												
Cs-185												
Cs-186												
Cs-187												
Cs-188												
Cs-189												
Cs-190												
Cs-191												
Cs-192												
Cs-193												
Cs-194												
Cs-195												
Cs-196												
Cs-197												
Cs-198												
Cs-199												
Cs-200												
Cs-201												
Cs-202												
Cs-203												
Cs-204												
Cs-205												
Cs-206												
Cs-207												
Cs-208												
Cs-209												
Cs-210												
Cs-211												
Cs-212												
Cs-213												
Cs-214												
Cs-215												
Cs-216												
Cs-217												
Cs-218												
Cs-219												
Cs-220												
Cs-221												
Cs-222												
Cs-223												
Cs-224												
Cs-225												
Cs-226												
Cs-227												
Cs-228												
Cs-229												
Cs-230												
Cs-231												
Cs-232												
Cs-233												
Cs-234												
Cs-235												
Cs-236												
Cs-237												
Cs-238												
Cs-239												
Cs-240												
Cs-241												
Cs-242												
Cs-243												
Cs-244												
Cs-245												
Cs-246												
Cs-247												
Cs-248												
Cs-249												
Cs-250												
Cs-251												
Cs-252												
Cs-253												
Cs-254												
Cs-255												
Cs-256												
Cs-257												
Cs-258												
Cs-259												
Cs-260												
Cs-261												
Cs-262												
Cs-263												
Cs-264												
Cs-265												
Cs-266												
Cs-267												
Cs-268												
Cs-269												
Cs-270												
Cs-271												
Cs-272												
Cs-273												
Cs-274												
Cs-275												
Cs-276												
Cs-277												
Cs-278												
Cs-279												
Cs-280												
Cs-281												
Cs-282												
Cs-283												
Cs-284												
Cs-285												
Cs-286												
Cs-287												
Cs-288												
Cs-289												
Cs-290												
Cs-291												
Cs-292												
Cs-293												
Cs-294												
Cs-295												
Cs-296												
Cs-297												
Cs-298												
Cs-299												
Cs-300												
Cs-301												
Cs-302												
Cs-303												
Cs-304												
Cs-305												
Cs-306												
Cs-307												
Cs-308												
Cs-309												
Cs-310												
Cs-311												
Cs-312												
Cs-313												
Cs-314												
Cs-315												
Cs-316												
Cs-317												
Cs-318												
Cs-319												
Cs-320												
Cs-321												
Cs-322												
Cs-323												
Cs-324												
Cs-325												
Cs-326												
Cs-327												

no detectable activity above background

TABLE 1.2-1 (Cont.)

REPORT OF RADIOACTIVE EFFLUENTS

Unit II Discharge

FACILITY: ZION

Docket Nos: 50-295 and 50-304

YEAR: 1979

II. Liquid Effluents	UNITS	July	August	September	Third Quarter	October	November	December	Fourth Quarter	6mo. Total	TECH SPEC
4. Gross Alpha Radioactivity		No Liquid	No Liquid	No Liquid	No Liquid						
a) Total Release	Curies	Waste	Waste	Waste	Waste	1.48E-4	1.46E-4	1.06E-4	4.00E-4	4.00E-4	6.63E-4
b) Average Concentration		Discharged	Discharged	Discharged	Discharged						6.63E-4
Released	uci/ml					2.46E-12	3.20E-12	2.25E-12	2.64E-12	2.64E-12	
5. Volume of Liquid Waste to Discharge	Liters					7.21E+6	2.98E+6	4.57E+6	1.48E+7	1.48E+7	6.63E-4
6. Volume of Dilution Water	Liters					6.02E+10	4.56E+10	4.71E+10	1.53E+11	1.53E+11	6.63E-4
7. Isotopes Released	Curies										6.63E-4
Cs-134						6.26E-3	5.19E-3	2.98E-3	1.44E-2	1.44E-2	
Ba-La-140						N.D.	N.D.	N.D.	N.D.	N.D.	
I-131						6.99E-4	1.11E-4	6.43E-5	8.74E-4	8.74E-4	
Cs-137						7.52E-3	6.67E-3	2.58E-3	1.68E-2	1.68E-2	
Co-59						7.52E-3	1.62E-2	1.49E-2	3.86E-2	3.86E-2	
Co-60						7.58E-3	1.32E-2	2.47E-2	4.55E-2	4.55E-2	
Cr-51						5.49E-3	5.97E-3	3.83E-3	1.53E-2	1.53E-2	
Mn-54						2.43E-4	6.64E-4	1.94E-3	2.85E-3	2.85E-3	
Mn-55						5.32E-5	N.D.	N.D.	5.32E-5	5.32E-5	
Sr-89						- -	- -	- -	*	*	
Sr-90						- -	- -	- -	*	*	
Cu-64						N.D.	N.D.	N.D.	N.D.	N.D.	
I-132						N.D.	N.D.	N.D.	N.D.	N.D.	

N.D. = No detectable activity above background

* = Waiting for analysis results - data will be presented in an errata to the Annual Report.

REPORT OF RADIOACTIVE EFFLUENTS

Unit	II	Discharge
1	10	10
2	20	20
3	30	30
4	40	40
5	50	50
6	60	60
7	70	70
8	80	80
9	90	90
10	100	100

FACILITY: ZION

Docket Nos: 50-295 and 50-304

YEAR: 1979

[illegible]

N.D. = No detectable activity above background

POOR ORIGINAL

ZION GENERATING STATION UNIT 1/2

Month January Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec. 6.6A3g)

TABLE 2.0-1

Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicuries Per Month
01 1-5-79	CEMENTED DRUMS	249.90	249.9	2312.64	2312.64
02 1-5-79	CEMENTED DRUMS	176.40	426.30	1704.55	4017.19
03 1-10-79	CEMENTED DRUMS	176.40	602.70	3511.30	7528.49
04 1-12-79	CEMENTED DRUMS	264.60	867.30	2817.80	10,346.29
06 1-18-79	CEMENTED DRUMS	88.20	955.50	8942.50	19,288.79

27

MONTH TOTAL

NOTE: Shipment #05 was contaminated equipment sent to Robinson Station

955.50

19,288.79

ZION GENERATING STATION UNIT 1/2

Month February Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

Date	Disposition of Material	Volume (ft3) Per Shipment	Volume (ft3) Per Month	Millicuries Per Shipment	Millicuries Per Month
07 2-9-79	Cemented Drums & Cask	545.8	545.80	436.2	436.20
08 2-14-79	Cemented Cask	170.0	715.80	9,207.0	9,643.20
09 2-15-79	Cemented Cask	170.0	885.80	17,297.0	26,940.20
10 2-18-79	Cemented Drums	132.3	1018.10	3,368.95	30,309.15
11 2-19-79	Cemented Drums	176.4	1194.50	2,332.35	32,641.50
MONTH TOTAL			<u>1194.50</u>		<u>32,641.50</u>

ZION GENERATING STATION UNIT 1/2

Month March Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft3) Per Shipment	Volume (ft3) Per Month	Millicuries Per Shipment	Millicuries Per Month
12	3-1-79	Cemented Cask	80.00	80.00	225,000.00	225,000.00
13	3-2-79	Cemented Drums	176.40	256.40	893.05	225,893.05
14	3-6-79	Cemented Cask	170.00	426.40	72,309.00	298,202.05
15	3-16-79	Cemented Drums	514.50	940.90	528.68	298,730.73
16	3-17-79	Cemented Cask	170.00	1,110.90	44,400.00	343,130.73
17		Not Shipped During	The Month of March			
18	3-21-79	Cemented Drums	514.50	1,625.40	728.72	343,859.45
19	3-23-79	Cemented Drums	132.30	1,757.70	3,517.70	347,377.15
20	3-24-79	Cemented Drums	88.20	1845.90	3,427.35	350,804.50
21	3-28-79	Cemented Drums	132.30	1978.20	5,412.95	356,217.45
MONTH TOTAL				<u>1978.20</u>		<u>356,217.45</u>

ZION GENERATING STATION UNIT 1/2

Month April Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft3) Per Shipment	Volume (ft3) Per Month	Millicuries Per Shipment	Millicurie Per Month
22	4-1-79	CEMENTED DRUMS	132.3	132.30	5,475.00	5,475.0
23	4-3-79	CEMENTED DRUMS	514.5	646.80	403.65	5,878.65
24	4-6-79	CEMENTED CASK	170.0	816.80	55,008.00	60,886.65
25	4-9-79	CEMENTED DRUMS	485.10	1,301.90	1,267.08	62,153.71
26	4-9-79	CEMENTED DRUMS	132.3	1,434.20	11,482.90	73,636.61
17	4-11-79	TUBE BUNDLE IN CASK	108.0	1,542.20	502.00	74,138.61
27	4-18-79	CEMENTED DRUMS	132.3	1,674.50	1,025.31	75,163.92
28	4-20-79	CEMENTED DRUMS	463.05	2,137.55	111.57	75,275.49
29	4-21-79	CEMENTED DRUMS	176.40	2,313.95	1,552.87	76,828.36
30	4-23-79	CEMENTED DRUMS	132.30	2,446.25	12,093.10	88,921.46
31	4-23-79	CEMENTED DRUMS	170.00	2,616.25	13,300.00	102,221.46
32	4-27-79	CEMENTED DRUMS	176.40	2,792.65	1,227.44	103,448.90
33	4-29-79	CEMENTED DRUMS	374.85	3,167.50	487.77	103,936.67
34	4-30-79	CEMENTED DRUMS	88.20	3,255.70	11,034.00	114,970.67
MONTH TOTAL				<u>3,255.70</u>		<u>114,970.67</u>

ZION GENERATING STATION UNIT 1/2

Month May Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicurie Per Month
35	5-02-79	Plywood Boxes (9)	1152.00	1152.00	191.30	191.30
36	5-02-79	Cemented Drums	132.30	1284.30	3,678.00	3869.30
37	5-05-79	Cemented Drums	441.00	1725.30	478.92	4348.22
38	5-07-79	Cemented Drums	36.75	1762.05	9,855.00	14,203.22
39*	5-09-79	Cemented Drums	44.15	1806.20	8.06	14,211.28
40	5-10-79	Cemented Drums	110.25	1916.45	3,973.00	18,134.28
31 41	5-11-79	Cemented Drums	88.20	2004.65	2,529.90	20,714.18
42	5-14-79	Cemented Cask	170.00	2174.65	40,911.00	61,625.18
43	5-15-79	Cemented Drums	110.25	2284.90	4,810.60	66,435.78
44	5-17-79	Cemented Drums	110.25	2395.15	3,820.00	70,255.78
45	5-17-79	Cemented Drums	485.45	2880.60	412.43	70,668.21
46	5-18-79	Cemented Drums	88.20	2968.80	7,074.00	77,742.21
47	5-19-79	Plywood Boxes (9)	1152.00	4120.80	466.60	78,208.81
48	5-21-79	Cemented Drums	88.20	4209.00	3,204.00	81,412.81

*Shipped to Dresden Station for compacting - Volume reduced to 29.4 ft³

ZION GENERATING STATION UNIT 1/2

Month May Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicurie Per Month
49	5-23-79	Cemented Cask	170.00	4379.00	67,152.00	148,564.81
50	5-25-79	Cemented Drums	88.2	4467.20	5,746.40	154,311.21
51		Not Shipped During The Month of May				
52	5-26-79	Cemented Drums	29.40	4496.60	9,000.00	163,311.2
53	5-30-79	Cemented Drums	176.40	4673.00	404.00	163,715.21
54	5-31-79	Plywood Boxes (4)	848.00	*5521.00	371.40	164,086.61
MONTH TOTAL				<u>5506.25</u>		<u>164,086.6</u>

* Subtracted 14.75 Ft³ Due to
#39 Compacting

ZION GENERATING STATION UNIT 1/2

Month June Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

No.	Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicuries Per Month
51	6-2-79	CEMENTED DRUMS	110.25	110.25	5,809.40	5809.40
55	6-1-79	CEMENTED DRUMS&PLYWOOD BOXES	475.50	585.75	365.11	6174.51
56	6-8-79	CEMENTED CASK	170.00	755.75	1,090.00	7264.51
57	6-13-79	CEMENTED DRUMS	132.30	888.05	5,756.40	13020.91
58	6-21-79	CEMENTED CASK	170.00	1058.05	175,000.00	188,020.91
59	6-24-79	CEMENTED DRUMS	88.20	1146.25	4,549.60	192,570.51
MONTH TOTAL				<u>1146.25</u>		<u>192,570.51</u>

ZION GENERATING STATION UNIT 1/2

Month July Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

No.	Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicuries Per Month
60	7-5-79	CEMENTED CASK	80.00	80.00	518,094.00	518,094.00
61	7-5-79	CEMENTED DRUMS	51.45	131.45	19,080.00	537,174.00
62	7-7-79	PLYWOOD BOXES (8)	1056.00	1,187.45	631.00	537,805.00
63A	7-11-79	CEMENTED DRUMS	51.45	1,238.90	3,960.00	541,765.00
63B	7-14-79	CEMENTED DRUMS	81.20	1,327.10	4,194.00	545,959.00
64	7-14-79	CEMENTED CASK	171.00	1,497.10	195,412.00	741,371.00
65	7-15-79	CEMENTED DRUMS	36.75	1,533.85	3,427.20	744,798.20
66	7-17-79	CEMENTED DRUMS	110.25	1,644.10	1,322.35	746,120.55
67	7-17-79	CEMENTED DRUMS	110.25	1,754.35	564.00	746,684.55
68	7-18-79	CEMENTED CASK	171.00	1,924.35	99,913.00	846,597.55
69	7-20-79	CEMENTED DRUMS	50.50	1980.85	9,398.00	855,995.55
70	7-22-79	CEMENTED DRUMS	80.20	2069.05	3,164.40	859,159.95
71	7-25-79	CEMENTED CASK	80.00	2149.05	66,382.00	925,544.95
72	7-26-79	CEMENTED DRUMS	411.95	2568.00	595.39	926,140.34

ZION GENERATING STATION UNIT 1/2

Month July Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

no.	Date	Disposition of Material	Volume (ft3) Per Shipment	Volume (ft3) Per Month	Millicuries Per Shipment	Millicuries Per Month
73	7-27-79	CEMENTED DRUMS	104.05	2,672.05	3,139.00	929,279.34
74	7-28-79	CEMENTED DRUMS	110.25	2,782.30	1,008.00	930,287.34
75	7-29-79	CEMENTED DRUMS	88.20	2,870.50	5,659.20	935,946.54
MONTH TOTAL				<u>2,870.50</u>		<u>935,946.54</u>

ZION GENERATING STATION UNIT 1/2

Month August Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft3) Per Shipment	Volume (ft3) Per Month	Millicuries Per Shipment	Millicurie Per Month
76	8-2-79	Cemented Cask	170.00	170.00	75,076.00	75,076.00
77	8-5-79	Cemented Drums	176.40	346.40	1,716.40	76,792.40
78	8-6-79	Cemented Cask	80.00	426.40	126,240.00	203,032.40
79	8-11-79	Cemented Cask	85.00	511.40	56,838.00	259,870.40
80	8-13-79	Cemented Drums	77.45	588.85	4,017.00	263,887.40
36 81	8-20-79	Cemented Cask	170.00	758.85	11,424.00	275,311.40
82	8-21-79	Cemented Drums	88.20	847.05	1,953.00	277,264.40
83	8-22-79	Cemented Cask	170.00	1017.05	11,031.00	288,295.40
84	8-24-79	Cemented Drums	147.70	1164.75	3,608.00	291,903.40
85	8-31-79	Cemented Drums	77.20	1241.95	2,377.80	294,281.20
				<u>1241.95</u>		<u>294,281.20</u>

POOR ORIGINAL

SOLID RADIOACTIVE WASTE
(Tech Spec 6.6A3g)

POOR ORIGINAL

37

[illegible]

ZION GENERATING STATION UNIT 1/2

Month October Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec. 6.5A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicuries Per Month
91	10-6-79	CEMENTED CASK	170.00	170.00	31,577.00	31,577.00
92	10-8-79	CEMENTED CASK	170.00	340.00	4,221.00	35,798.00
93	10-10-79	CEMENTED CASK	80.00	420.00	168,731.00	204,529.00
MONTH TOTAL				<u>420.00</u>		<u>204,529.00</u>

ZION GENERATING STATION UNIT 1/2

Month NOVEMBER Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec. 6.6A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicuries Per Month
94	11/20/79	CEMENTED DRUMS	135.00	135.00	916.00	916.00
95	11/21/79	CEMENTED DRUMS	90.00	225.00	876.00	1,792.00
96	11/27/79	CEMENTED CASK	170.00	395.00	7,084.00	8,876.00
97	11/27/79	CEMENTED CASK	80.00	475.00	77,399.00	86,275.00
39						
MONTH TOTAL				<u>475.00</u>		<u>86,275.00</u>

ZION GENERATING STATION UNIT 1/2

Month December Year 1979

SOLID RADIOACTIVE WASTE
(Tech Spec. 6.6A3g)

TABLE 2.0-1 (Cont.)

#	Date	Disposition of Material	Volume (ft ³) Per Shipment	Volume (ft ³) Per Month	Millicuries Per Shipment	Millicuries Per Month
98	12-3-79	Cemented Drums	180.00	180.00	1445.00	1445.00
99	12-6-79	Cemented Cask	80.00	260.00	206,500.00	207,945.00
100	12-13-79	Cemented Cask	80.00	340.00	14,681.00	222,626.00
101	12-14-79	Cemented Cask	170.00	510.00	24,698.00	247,324.00
102	12-16-79	Cemented Cask	80.00	590.00	3,645.00	250,969.00
103	12-31-79	Cemented Cask	80.00	670.00	6,000.00	256,969.00
104	12-31-79	Cemented Cask	170.00	840.00	19,752.00	276,721.00

MONTH TOTAL

840.00

276,721.00



FIGURE 3.1-1

Estimated Cumulative Gamma Dose (mrem) from Zion Station for the period January - December 1979.

Isopleth Labels:

Small Figure - multiply by 10^{-1}

Large Figure - multiply by 10^{-2}



05 25

10

RELEASE POINT

ILLINOIS

SCALE

0 1 2 MILES

0 1 2 3 KM

Isopleth Labels:

Small Figure - multiply by 10^{+4}
Large Figure - multiply by 10^{+2}




FIGURE 3.1-3

Estimated Total Concentration (pCi/m^3) of Iodine from Zion Station for the period January - December 1979.

Isopleth Labels:

Small Figure - multiply by 10^{-4}

Large Figure - multiply by 10^{-6}

POOR ORIGINAL





FIGURE 3.1-4

Estimated Total Concentration (pCi/m^3) of
Particulate Matter from Zion Station for
the period January - December 1979.

Isopleth Labels:

Small figure - multiply by 10^{-3}

Large Figure - multiply by 10^{-5}




TABLE 3.2-1

VALUES OF PARAMETERS USED TO MAKE DOSE ESTIMATES
RESULTING FROM ZION LIQUID WASTE DISCHARGES

Pathway	Parameter	Unit	Value or Source
Potable Water	M_p/F	CFS^{-1}	1/1.34 E-08x60x6F; (a)
	F^1	liters/month	Station Report
	U_p	liters/month	Max. Adult 61, Av Adult 31
	Q_i	Ci/month	Station Report
	D_{ipr}	mrem/pCi	From Regulatory Guide 1.109
	λ_i	hr^{-1}	Table of isotopes or other sources.
	t_p	hr	5.5, (b)
Aquatic Food	M_p/F	CFS^{-1}	1/4.0 E+5, (c)
	U_p	kg/month	Max. Adult 1.0, Av Adult 0.1
	Q_i, D_{ipr}, λ_i	---	See Potable Water
	B_{ip}	liter/kg	Site Data
	t_p	hr	72, (d)
Shoreline Activities	M_p	unitless	1/2 (current frequency factor)
	F	CFS	1.2 E+4, (e)
	W	unitless	0.3 (Table A-2, RG 1.109)
	T_i	d	0.029/ λ (λ - hr^{-1})
	t	hr	1.3 E+5 (midpoint of Plant operating lifetime)
	t_p	hr	0
	U_p	hr/month	Jun, Jul, Aug, Sep = 16 All other months = 0 (ref: HERMES)

- (a) 1/60 is the product of 1/2 (the current frequency factor), 1/10 (the initial entrainment factor), and 1/3 (the lake mixing factor).
- (b) It is 1.1 miles from the Plant to the Lake County Public Water intake and a current speed of 0.2 mph is assumed.
- (c) Based on the simplified assumption that the near-shore currents constitute a "river" of 5 miles (26,400 ft.) width, 50 ft. depth, and a flow rate at 0.2 mph.
- (d) HERMES, pg. 118.
- (e) Based on the simplified assumption that the near-shore currents constitute a "river" having a 2600' (to the intake) width, a 15' depth, and a flow rate of 0.2 mph.

TABLE 3.1-1
DOSES RESULTING FROM AIRBORNE RELEASES
ZION 12/79

TYPE	UNITS	DOSE (DIRECTION) BY QUARTER			
GAMMA AIR	(MRAD)	0.66 (N)	0.75 (N)	1.29 (NNE)	0.22 (NNE)
BETA AIR	(MRAD)	0.22 (N)	0.22 (N)	0.22 (NNE)	0.04 (NNE)
WHOLE BODY	(MREM)	0.05 (N)	0.07 (S)	0.07 (S)	0.01 (W)
SKIN DOSE	(MREM)	0.06 (N)	0.09 (S)	0.09 (S)	0.02 (N)
INFANT THYROID	(MREM)	0.00 ()	0.00 (W)	0.00 (W)	0.00 (W)
POP WHOLE BODY	(PREM)	1.89	3.86	3.79	0.43

TYPE		YEAR TO DATE		PERCENT
		MAX DOSE	MAX ALLOWABLE	
GAMMA AIR	(MRAD)	2.67	20	13.333
BETA AIR	(MRAD)	0.62	40	1.551
WHOLE BODY	(MREM)	0.17	10	1.733
SKIN DOSE	(MREM)	0.23	30	0.754
INFANT THYROID	(MREM)	0.00	30	0.003

TABLE 3.2-1

ZION NUCLEAR POWER PLANT LIQUID DOSE CALCULATIONS

DOSES RESULTING FROM EXPOSURE TO
RADIOACTIVITY DISCHARGED IN LIQUID WASTE

(DECEMBER 1979)

DOSE BY PATHWAY (MREM)

EXPOSED PERSON PERIOD	POTABLE WATER			AQUATIC FOODS			SHORELINE ACTIVITIES	
	TOTAL BODY	BONE	THYROID	TOTAL BODY	BONE	THYROID	TOTAL BODY	SKIN
"AVERAGE" ADULT								
1ST QTR	0.003	0.000	0.000	0.000	0.000	0.004	0.000	0.000
2ND QTR	0.000	0.000	0.000	0.000	0.000	0.003	0.000	0.000
3RD QTR	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000
4TH QTR	0.000	0.000	0.000	0.000	0.000	0.001	0.000	0.000
"MAXIMUM" ADULT								
1ST QTR	0.000	0.000	0.000	0.000	0.000	0.037	0.000	0.000
2ND QTR	0.000	0.000	0.000	0.000	0.000	0.034	0.000	0.000
3RD QTR	0.000	0.000	0.000	0.000	0.000	0.014	0.000	0.000
4TH QTR	0.000	0.000	0.000	0.000	0.000	0.007	0.000	0.000

TOTAL ORGAN DOSE SINCE JANUARY FOR "AVERAGE" ADULT

ORGAN	TOTAL DOSE	10CFR50 APP I	PERCENT OF APP I
TOTAL BODY	0.76E-03	6 MREM	0.013
SKIN	0.61E-03	20 MREM	0.003
BONE	0.22E-03	20 MREM	0.001
THYROID	0.96E-02	20 MREM	0.048

LOCATIONS OF FIXED ENVIRONMENTAL RADIOLOGICAL MONITORING STATIONS

FIGURE 5.0-1

- 1 - Onsite Station 1
- 2 - Onsite Station 2
- 3 - Onsite Station 3
- 4 - Zion (W)
- 5 - Zion (SW)
- 6 - Zion (WNW)
- 7 - Winthrop Harbor City Garage
- 8 - Kenosha Road Farm
- 9 - Waukegan
- 10 - North Chicago
- 11 - Sheridan Lanes Bowling Alley
- 12 - Flood Farm
- 13 - Pleasant Prairie





TABLE 5.0-1

ZION STANDARD RADIOLOGICAL MONITORING PROGRAM

<u>Sample Media</u>	<u>Collection Site *</u>	<u>Type of Analysis</u>	<u>Frequency</u>	<u>Non-Routine Reporting Levels</u> ☐
1. Air Monitoring	(a) Onsite and near field	1. Filter - gross beta ^a	1. Weekly	CS-134 10, Cs-137 20 pCi/m ³
	(1) Onsite Station #1	2. Charcoal - I-131	2. Bi-Weekly	0.9 pCi/m ³
	(2) Onsite Station #2			
	(3) Onsite Station #3	3. Sampling Train - Test and Maintenance	3. Weekly	
	(b) Far Field			
	(1) Zion (W)	1. Filter Exchange	1. Weekly	Same as 1(a)
	(2) Zion (SW)			
	(3) Zion (WNW)	2. Charcoal Exchange	2. Bi-Weekly	when analyses
	(4) Winthrop Harbor City Garage	3. Sampling Train - Test and Maintenance	3. Weekly	are made
	(5) Kenosha Road Farm			
	(6) Waukegan			
	(7) N. Chicago			
	(8) Southport Substation			
	(9) Flood Farm			
	(10) Pleasant Prairie DC			
2. GLD	Same as 1	Gamma Radiation	Quarterly	
3. Fish	Δ Lake Michigan near Zion Station	Gamma isotopic	Semi-annual	Mn-54 3x10 ⁴ , Fe-59 1x10 ⁴ Co-58 3x10 ⁴ , Co-60 1x10 ⁴ Zn-65 2x10 ⁴ , Cs-134 1x10 ³ Cs-137 2x10 ³ pCi/Kg wet weight
4. Milk	(a) Ames Dairy	I-131	1. Weekly - Grazing Season - May to Oct	I-131 3 pCi/l Cs-134 60 pCi/l Cs-137 70 pCi/l
	(b) Steinbrink Dairy		2. Monthly - Nov to Apr	Ba-La-140 300 pCi/l

Δ On notification provided by station personnel.

* Additional information giving the distance and direction of individual sampling locations may be found in Appendix III of the 1978 Annual Report.

TABLE 5.0-1 (Cont.)

ZION STANDARD RADIOLOGICAL MONITORING PROGRAM (CONT'D)

<u>Sample Media</u>	<u>Collection Site</u>	<u>Type of Analysis</u>	<u>Frequency</u>	<u>Non-Routine Reporting Levels</u> ☐
5. Public Water Supply	(a) Kenosha Water Works	1. Gamma Isotopic	1. Monthly Analysis Footnote**	
	(b) Lake County Water Works		of weekly Composites	
	(c) Waukegan Water Works	2. Tritium	2. Quarterly Composite	
	(d) N. Chicago Water Works			
	(e) Naval Training Center Water Works			
	(f) Lake Forest Water Works			
6. Cooling Water Sample	Δ (a) Inlet	1. Gross Beta	1. Weekly	
	Δ (b) Discharge	2. Tritium	2. Quarterly Composite	
7. Sediment	Lake Michigan	Gamma Isotopic	Annual	
	(a) Illinois Beach St. Park			
8. Dairy Census	(a) Site Boundary to 2 miles	(a) Enumeration by a door-to-door or equivalent counting technique	Annually, during grazing season	
	(b) 2 miles to 5 miles	(b) Enumeration by using referenced information from county agricultural agents or other reliable sources.		
	(c) At dairies listed in item 4			

TABLE 5.0-1 (Cont.)

ZION STANDARD RADIOLOGICAL MONITORING PROGRAM (CONT'D)

<u>Sample Media</u>	<u>Collection Site</u>	<u>Type of Analysis</u>	<u>Frequency</u>	<u>Non-Routine Reporting Levels</u> ☐
		(c) Inquire as to feeding practices.		
		(1) pasture only		
		(2) feed and chop only		
		(3) pasture and feed; if both, ask farmer to estimate fraction of food from pasture:		
			< 25%	
			25-50%	
			50-75%	
			≥ 75%	

Note:

*Bi-Weekly shall mean that the frequency is once every other week.

□ Average concentration over calendar quarter

*H-3 2×10^4 , Mn-54 1×10^3 , Fe-59 1×10^2 , Co-58 6×10^2 , Co-60 2×10^2 , Zn-65 2×10^2 , Zr-Nb-95 4×10^2 , I-131 2,
Cs-134 30, Cs-137 50, Ba-La-140 1×10^2 pCi/l.

°A gamma isotopic analysis shall be performed whenever the gross beta concentration in a sample exceeds by five times (5x)
the average concentration of the proceeding calendar quarter for the sample location.

△ Provided by station personnel.

Table 5.0-2

Environmental Radiological Monitoring ProgramName of Facility: Zion Generating StationDocket Number: 50-295, 50-304Location of Facility: Cook, Illinois
County StateReporting Period: 1st Quarter 1979

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Lower Limit of Detection (LLD)	All Indicator Locations Mean ¹ (Range)	Location with Highest Mean		Control Locations Mean ¹ (Range)	Number of Non-routine Reported Measurements
				Name, Distance and Direction	Mean (Range)		
Air Particulates (pCi/m ³)	Gross β 17	0.01	0.04 (12/17) 0.02-0.07	On Site 2 0.2 mi @ 270°	0.05 (2/5)	Not Measured	0
Airborne Iodine (pCi/m ³)	I-131 8	0.10	All LLD	Not Applicable		Not Measured	0
Gamma Background (mR/Qtr)	γ Dose 13	3	10.1 (3/3) 8.6-11.3	On Site 1 0.3 mi @ 200°	11.1 (1/1)	11.3 (10/10) 8.6-14.3	
Milk (pCi/l)	I-131 6	5	All LLD	Not Applicable		Not Measured	0
Cooling Water (pCi/l)	Gross β 26	5	15 (21/26) 4-100	Discharge Area 1	20 (12/13) 4-100	16 (13/13) 5-52	0
	HTO 3	500	All LLD	Not Applicable		All LLD	0
Public Water (pCi/l)	γ Spec. 18	10	All LLD	Not Applicable		Not Measured	0
	HTO 6	200	162 (6/6) 130-230	Navel Training Center 10 mi @ 180°	230 (1/1) 230	Not Measured	0

¹ Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-3

Environmental Radiological Monitoring ProgramName of Facility: Zion Generating StationDocket Number: 50-295, 50-304Location of Facility: Cook, Illinois
County StateReporting Period: 2nd Quarter 1979

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Lower Limit of Detection (LLD)	All Indicator Locations Mean ¹ (Range)	Location with Highest Mean		Control Locations Mean ¹ (Range)	Number of Non-routine Reported Measurements
				Name, Distance and Direction	Mean (Range)		
Air Particulates (pCi/m ³)	Gross β 39	0.01	0.04 (39/39) 0.01-0.08	On Site 2 0.2 mi @ 270°	0.04 (13/13) 0.02-0.08	Not Measured	0
Airborne Iodine (pCi/m ³)	I-131 21	0.10	All LLD	Not Applicable		Not Measured	0
Gamma Background (mR/Qtr)	γ Dose 13	3	11.3 (3/3) 8.6-14.3	On Site 1 0.3 mi @ 200°	14.3 (1/1) 14.3	13.7 (10/10) 10.3-19.5	0
Milk (pCi/l)	I-131 20	⁵ /0.5*	All LLD	Not Applicable		Not Measured	0
Cooling Water (pCi/l)	Gross β 38	5	6 (14/25) 4-11	Discharge Area 1	6 (7/13) 4-11	20 (13/13) 5-91	0
	HTO 3	500	1130 (2/2) 860-1400	Discharge Area 1	1400 (1/1) 1400	560 (1/1) 560	0
Public Water (pCi/l)	γ Spec. 18	10	All LLD	Not Applicable		Not Measured	0
	HTO 6	200	350 (2/6)	Lake County Waterworks 1.0 mi @ 0°	400 (1/1) 400	Not Measured	0
Fish (pCi/g)	Cs-137 7	0.1	0.2 (1/7) 0.2	Lk. Michigan near Station	0.2 (1/7) 0.2	Not Measured	0
	Other γ 7	0.1	All LLD	Not Applicable		Not Measured	0

¹ Mean and range based on detectable measurements only. Fractions indicated in parentheses.

* November - April, LLD=5; May - October, LLD=0.5.

Table 5.0-4

Environmental Radiological Monitoring ProgramName of Facility: Zion Generating StationDocket Number: 50-295, 50-304Location of Facility: Cook, Illinois
County StateReporting Period: 3rd Quarter 1979

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Lower Limit of Detection (LLD)	All Indicator Locations Mean ¹ (Range)	Location with Highest Mean		Control Locations Mean ¹ (Range)	Number of Non-routine Reported Measurements
				Name, Distance and Direction	Mean (Range)		
Air Particulates (pCi/m ³)	Gross β 39	0.01	0.03 (28/39) 0.01-0.05	On Site 1 0.3 mi @ 200°	0.03 (12/13)	Not Measured	0
Airborne Iodine (pCi/m ³)	I-131 18	0.10	All LLD	Not Applicable		Not Measured	0
Gamma Background (mR/Qtr)	γ Dose 13	3	11.6 (3/3) 9.4-13.0	On Site 3 0.2 mi @ 350°	13.0 (1/1) 13.0	11.7 (10/10) 8.6-15.6	0
Milk (pCi/l)	I-131 26	0.5	All LLD	Not Applicable		Not Measured	0
Cooling Water (pCi/l)	Gross β 39	5	4.8 (6/26) 4-6	Discharge Area 2	5.3 (3/3) 5-6	5.4 (7/13) 4-8	0
	HTO 3	500	415 (2/2) 330-500	Discharge Area 1	500 (1/1) 500	410 (1/1) 410	0
Public Water (pCi/l)	γ Spec. 18	10	All LLD	Not Applicable		Not Measured	0
	HTO 6	200	183 (6/6) 140-230	Kenosha Public Water Works 10 mi @ 0°	230 (1/1) 230	Not Measured	0
Fish (pCi/g)	γ Spec. 5	0.1	All LLD	Not Applicable		Not Measured	0
Sediment (pCi/g)	γ Spec. 2	0.2	All LLD	Not Applicable		Not Measured	0

¹ Mean and range based on detectable measurements only. Fractions indicated in parentheses.

Table 5.0-5

Environmental Radiological Monitoring Program

Name of Facility: Zion Generating StationDocket Number: 50-295, 50-304Location of Facility: Cook, Illinois
County StateReporting Period: 4th Quarter 1979

Medium or Pathway Sampled (Unit of Measurement)	Type and Total Number of Analyses Performed	Lower Limit of Detection (LLD)	All Indicator Locations Mean ¹ (Range)	Location with Highest Mean		Control Locations Mean ¹ (Range)	Number of Non-routine Reported Measurements
				Name, Distance and Direction	Mean (Range)		
Air Particulates (pCi/m ³)	Gross β 39	0.01	0.03 (35/39) 0.01-0.06	On Site 1 0.3 mi @ 200°	0.03 (13/13) 0.02-0.06	Not Measured	0
Airborne Iodine (pCi/m ³)	I-131 21	0.10	All LLD	Not Applicable		Not Measured	0
Gamma Background (mR/Qtr)	γ Dose 13	3	13.4 (3/3) 13.0-14.3	On Site 2 0.2 mi @ 290°	14.3 (1/1) 14.3	15.3 (10/10) 11.8-20.8	0
Milk (pCi/l)	I-131 14	0.5/5*	All LLD	Not Applicable		Not Measured	0
Cooling Water (pCi/l)	Gross β 39	5	7.4 (12/26) 3-20	Discharge Area 1	7.8 (6/13) 4-20	7.1 (9/13) 4-14	0
	HTO 3	500	515 (2/2) 410-620	Discharge Area 1	620 (1/1) 620	430 (1/1) 430	0
Public Water (pCi/l)	γ Spec. 18	10	All LLD	Not Applicable		Not Measured	0
	HTO 6	200	197 (6/6) 110-290	Lake County Water Works 1.0 mi @ 0°	290 (1/1) 290	Not Measured	0

¹ Mean and range based on detectable measurements only. Fractions indicated in parentheses.

GAMMA DOSE AS MEASURED BY THERMOLUMINESCENT DOSIMETERS

QUARTERLY BADGES

	1st Quarter	2nd Quarter	3rd Quarter	4th Quarter
Date Annealed:	12/11/78	03/19/79	06/18/79	09/27/79
Date Read:	03/26/79	06/20/79	10/03/79	12/19/79

Location	Average mR/quarter			
On-Site Indicator Stations				
Z-01 On-Site #1 Southside	11.3±2.8	14.3±3.9	12.4±1.6	13.0±2.6
Z-02 On-Site #2 Westside	10.3±1.0	10.9±2.0	9.4±2.1	14.3±3.9
Z-03 On-Site #3 Northside	8.6±0.9	8.6±2.0	13.0±1.3	13.0±5.2
Background Stations				
Z-04 Zion, SW	11.6±1.2	12.5±2.2	9.5±1.2	15.6±1.3
Z-05 Zion, WNW	10.8±1.7	13.0±2.6	11.4±2.2	15.6±3.9
Z-06 Winthrop Harbor City Garage	9.4±1.2	10.5±2.5	10.7±1.7	12.7±2.6
Z-07 Kenosha Road Farm	12.5±1.8	15.6±1.3	13.0±3.9	18.2±2.6
Z-08 Waukegan	10.3±2.2	14.3±3.9	10.2±2.5	14.3±2.6
Z-09 Zion, W	12.2±2.7	15.6±1.3	15.6±2.6	20.8±2.6
Z-10 North Chicago	11.2±1.2	12.5±1.2	11.8±1.6	13.0±1.3
Z-11 Sheridan Lanes Bowling Alley	8.6±0.9	10.3±1.0	8.6±2.3	11.8±2.5
Z-12 Flood Farm	14.3±1.3	19.5±5.2	14.3±2.6	18.2±2.6
Z-13 Pleasant Prairie DC	11.7±2.9	13.0±2.6	11.6±3.0	14.3±1.3
Average Readings				
On-Site (Z-01 to Z-03)	10.1±1.6	11.3±2.6	11.6±1.7	13.4±3.9
(1) Off-Site <5 miles	11.1±1.8	13.6±2.3	11.7±2.4	16.2±2.6
(2) Off-Site >5 miles	11.5±1.6	13.8±2.5	11.6±2.4	14.3±1.9

(1) Stations Z-04, Z-05, Z-06, Z-07, Z-08 and Z-09.

(2) Stations Z-10, Z-11, Z-12 and Z-13.

APPENDIX II
METEOROLOGICAL DATA

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JANUARY - MARCH 1979
 STABILITY CLASS - EXTREMELY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4- 7	8-12	13-18	19-24		
N	0	1	0	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	1	0	0	0	0	1
SSE	0	1	0	0	0	0	1
S	0	11	5	0	0	0	16
SSW	0	13	0	0	0	0	13
SW	0	0	0	0	0	0	0
WSW	0	0	0	0	0	0	0
W	0	8	0	0	0	0	8
WNW	0	8	0	0	0	0	8
NW	0	6	0	0	0	0	6
NNW	0	1	0	0	0	0	1
VARIABLE	0	10	0	0	0	0	10
TOTAL	0	61	5	0	0	0	66

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 4

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JANUARY - MARCH 1979
 STABILITY CLASS - EXTREMELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
-----	0-3	4-7	8-12	13-18	19-24	-----	-----
N	0	0	4	6	1	0	11
NNE	0	1	0	5	9	6	21
NE	0	5	2	2	0	0	9
ENE	0	0	2	4	0	0	6
E	0	6	2	11	3	0	22
ESE	0	3	2	8	2	0	15
SE	0	3	6	3	0	0	12
SSE	0	4	9	5	0	0	18
S	0	7	3	0	0	0	10
SSW	0	7	8	1	0	0	16
SW	0	6	6	10	0	0	22
WSW	0	13	22	11	0	0	46
W	0	19	19	16	4	0	58
WNW	0	16	21	15	2	0	54
NW	0	33	22	2	0	0	57
NNW	0	8	12	2	0	0	22
VARIABLE	0	2	0	0	0	0	2
TOTAL	0	133	140	101	21	6	401

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 2
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 4

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JANUARY - MARCH 1979
 STABILITY CLASS - MODERATELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	GT 24	-----
N	0	2	0	3	1	0	6
NNE	0	1	1	4	2	0	8
NE	0	2	0	1	2	0	5
ENE	0	0	0	5	2	0	7
E	0	0	1	3	1	0	5
ESE	0	4	7	1	3	0	15
SE	0	2	0	0	0	0	2
SSE	0	2	8	1	0	0	11
S	0	4	4	0	0	0	8
SSW	0	3	0	0	0	0	3
SW	0	7	4	6	0	0	17
WSW	0	5	4	2	0	0	11
W	0	3	3	2	0	0	8
WNW	0	3	2	2	0	0	7
NW	0	7	4	3	0	0	14
NNW	0	4	4	6	0	0	14
VARIABLE	0	1	0	0	0	0	1
TOTAL	0	50	42	39	11	0	142

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 4

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JANUARY - MARCH 1979
 STABILITY CLASS - SLIGHTLY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4- 7	8-12	13-18	19-24		
N	0	5	4	2	1	0	12
NNE	0	2	3	3	2	2	12
NE	0	1	2	4	3	0	10
ENE	0	1	2	0	0	0	3
E	0	2	1	0	0	0	3
ESE	0	1	1	0	0	0	2
SE	0	4	4	1	0	0	9
SSE	0	1	4	0	0	0	5
S	0	2	0	0	0	0	2
SSW	0	1	3	0	0	0	4
SW	0	5	4	4	0	0	13
WSW	0	4	3	2	1	0	10
W	0	4	2	1	0	0	7
WNW	0	8	0	1	0	0	9
NW	0	8	3	1	0	0	12
NNW	0	2	6	6	0	0	14
VARIABLE	0	3	0	0	0	0	3
TOTAL	0	54	42	25	7	2	130

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 4

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JANUARY - MARCH 1979
 STABILITY CLASS - NEUTRAL (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	-----	-----
N	0	9	8	18	7	3	45
NNE	0	14	13	15	9	1	52
NE	0	11	4	6	6	0	27
ENE	0	15	4	2	0	0	21
E	0	5	1	2	0	0	8
ESE	0	0	1	0	0	0	1
SE	0	10	4	0	0	0	14
SSE	0	7	12	16	3	0	38
S	0	26	26	18	1	0	71
SSW	0	23	23	3	0	0	49
SW	0	30	16	20	8	1	75
WSW	0	25	21	9	0	0	55
W	0	32	20	6	1	0	59
WNW	0	37	18	15	2	0	72
NW	0	70	26	14	0	0	110
NNW	0	21	30	35	3	0	89
VARIABLE	0	16	0	0	0	0	16
TOTAL	0	351	227	179	40	5	802

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 4

ZION NUCLEAR POWER STATION
PERIOD OF RECORD - JANUARY - MARCH 1979
STABILITY CLASS - SLIGHTLY STABLE (DELTA T 125-35 FT)
WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	GT 24	-----
N	0	6	2	1	6	0	15
NNE	0	11	1	1	1	1	15
NE	0	2	1	0	0	0	3
ENE	0	6	0	0	0	0	6
E	0	9	0	0	0	0	9
ESE	0	5	0	0	0	0	5
SE	0	1	1	0	0	0	2
SSE	0	7	3	2	0	0	12
S	0	25	20	2	0	0	47
SSW	0	18	10	5	0	0	33
SW	0	13	10	10	1	0	34
WSW	0	18	20	12	1	0	51
W	0	25	28	21	1	0	75
WNW	0	43	27	9	0	0	79
NW	0	51	12	2	0	0	65
NNW	0	14	6	4	3	0	27
VARIABLE	0	27	0	0	0	0	27
TOTAL	0	281	141	69	13	1	505

HOURS OF CALM IN THIS STABILITY CLASS - 0
HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 4

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JANUARY - MARCH 1979
 STABILITY CLASS - MODERATELY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4- 7	8-12	13-18	19-24		
N	0	1	0	0	0	0	1
NNE	0	0	0	0	0	0	0
NE	0	0	1	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	0	3	0	0	0	0	3
S	0	5	5	0	0	0	10
SSW	0	13	2	1	0	0	16
SW	0	1	0	1	0	0	2
WSW	0	1	1	0	0	0	2
W	0	13	1	0	0	0	14
WNW	0	27	2	0	0	0	29
NW	0	12	0	0	0	0	12
NNW	0	1	0	0	0	0	1
VARIABLE	0	17	0	0	0	0	17
TOTAL	0	94	12	2	0	0	108

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 4

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - APRIL - JUNE 1979
 STABILITY CLASS - EXTREMELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	-----	-----
N	0	3	4	15	9	4	35
NNE	0	4	29	13	3	0	49
NE	2	8	21	3	0	0	34
ENE	2	9	8	0	0	0	19
E	0	13	2	0	0	0	15
ESE	1	29	6	0	2	0	38
SE	0	33	7	2	0	0	42
SSE	1	12	4	1	0	0	18
S	1	6	19	2	0	0	28
SSW	0	2	0	6	7	0	15
SW	0	1	9	3	3	0	16
WSW	0	1	3	6	0	0	10
W	0	4	3	13	0	0	20
WNW	0	1	7	15	0	0	23
NW	0	5	17	8	0	0	30
NNW	0	3	8	3	0	0	14
VARIABLE	0	0	0	0	0	0	0
TOTAL	7	134	147	90	24	4	406

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 1
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 36

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - APRIL - JUNE 1979
 STABILITY CLASS - MODERATELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4- 7	8-12	13-18	19-24		
N	1	0	2	3	1	0	7
NNE	0	3	5	2	0	0	10
NE	0	6	2	0	0	0	8
ENE	0	5	3	1	0	0	9
E	0	5	0	0	0	0	5
ESE	0	6	0	0	0	0	6
SF	2	3	0	0	0	0	5
SSE	0	2	3	0	0	0	5
S	0	1	5	0	0	0	6
SSW	0	0	1	1	2	0	4
SW	0	1	1	3	1	0	6
WSW	0	1	2	1	0	0	4
W	0	0	1	3	0	0	4
WNW	0	0	0	0	0	0	0
NW	0	1	4	0	0	0	5
NNW	1	0	1	0	0	0	2
VARIABLE	1	0	0	0	0	0	1
TOTAL	5	34	30	14	4	0	87

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 36

ZION NUCLEAR POWER STATION
PERIOD OF RECORD - APRIL - JUNE 1979
STABILITY CLASS - SLIGHTLY UNSTABLE (DELTA T 125-35 FT)
WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4- 7	8-12	13-18	19-24		
N	0	2	7	5	0	1	15
NNE	0	6	5	1	0	0	12
NE	1	3	6	0	0	0	10
ENE	0	7	0	1	0	0	8
E	0	5	1	1	0	0	7
ESE	0	7	0	1	0	0	8
SE	1	7	0	2	0	0	10
SSE	0	1	2	1	0	0	4
S	0	0	4	0	0	0	4
SSW	0	0	1	1	2	0	4
SW	1	0	1	2	0	0	4
WSW	0	0	2	0	2	0	4
W	0	0	1	2	1	0	4
WNW	0	0	1	1	1	0	3
NW	1	1	2	0	0	0	4
NNW	0	1	2	0	0	0	3
VARIABLE	0	0	0	0	0	0	0
TOTAL	4	40	35	18	6	1	104

HOURS OF CALM IN THIS STABILITY CLASS - 0

HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 36

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - APRIL - JUNE 1979
 STABILITY CLASS - NEUTRAL (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.7-3	4- 7	8-12	13-18	19-24	GT 24	
N	2	8	20	21	6	1	58
NNE	3	39	32	16	0	0	90
NE	4	19	15	8	0	0	46
ENE	3	7	3	4	0	0	17
E	1	9	3	8	1	0	22
ESE	2	16	1	7	3	0	29
SE	4	20	2	8	0	0	34
SSE	1	8	7	4	0	0	20
S	2	9	21	6	0	0	38
SSW	0	3	0	9	4	0	16
SW	1	8	7	5	1	0	22
WSW	1	3	5	2	1	0	12
W	0	1	5	3	3	2	14
WNW	2	4	14	6	2	6	34
NW	1	8	12	2	2	0	25
NNW	2	9	7	8	0	0	26
VARIABLE	4	0	0	0	0	0	4
TOTAL	33	171	154	117	23	9	507

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 36

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - APRIL - JUNE 1979
 STABILITY CLASS - SLIGHTLY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4- 7	8-12	13-18	19-24		
N	6	24	36	16	4	0	86
NNE	6	22	7	4	0	0	39
NE	4	19	2	0	0	0	25
ENE	1	6	7	4	0	0	18
E	6	6	4	3	0	1	20
ESE	4	5	5	7	0	0	21
SE	5	22	0	0	0	0	27
SSE	4	10	23	5	0	0	42
S	5	40	28	1	0	0	74
SSW	11	16	17	23	4	0	71
SW	3	15	19	19	2	1	59
WSW	3	12	22	2	0	0	39
W	3	11	16	3	0	0	33
WNW	4	13	2	0	0	0	19
NW	2	3	6	0	0	0	11
NNW	2	7	2	0	0	0	11
VARIABLE	11	0	0	0	0	0	11
TOTAL	80	231	196	87	10	2	606

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 2
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 36

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - APRIL - JUNE 1979
 STABILITY CLASS - MODERATELY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	GT 24	-----
N	4	12	3	0	0	0	19
NNE	0	2	0	0	0	0	2
NE	0	0	0	0	0	0	0
ENE	1	0	0	0	0	0	1
E	0	2	1	0	0	0	3
ESE	2	1	0	0	0	0	3
SE	4	6	0	0	0	0	10
SSE	1	4	3	2	0	0	10
S	1	10	19	2	0	0	32
SSW	1	23	2	1	0	0	27
SW	5	24	6	0	0	0	35
WSW	6	7	3	0	0	0	16
W	4	12	1	0	0	0	17
WNW	7	11	0	0	0	0	18
NW	4	8	0	0	0	0	12
NNW	2	8	1	0	0	0	11
VARIABLE	6	0	0	0	0	0	6
TOTAL	48	130	39	5	0	0	222

HOURS OF CALM IN THIS STABILITY CLASS - 0

HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 1

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 36

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - APRIL - JUNE 1979
 STABILITY CLASS - EXTREMELY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.7-3	4- 7	8-12	13-18	19-24	GT 24	
N	3	2	0	0	0	0	5
NNE	2	2	0	0	0	0	4
NE	0	1	0	0	0	0	1
ENE	0	0	0	0	0	0	0
E	1	1	0	0	0	0	2
ESE	5	3	3	0	0	0	11
SE	1	3	2	0	0	0	6
SSE	3	1	4	0	0	0	8
S	7	23	24	0	0	0	54
SSW	8	29	5	0	0	0	42
SW	4	6	0	1	0	0	11
WSW	2	7	1	0	0	0	10
W	6	2	0	0	0	0	8
WNW	8	4	0	0	0	0	12
NW	6	6	0	0	0	0	12
NNW	4	4	0	0	0	0	8
VARIABLE	18	0	0	0	0	0	18
TOTAL	78	94	39	1	0	0	212

HOURS OF CALM IN THIS STABILITY CLASS - 0

HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 36

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JULY - SEPTEMBER 1979
 STABILITY CLASS - EXTREMELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	0-3	4-7	8-12	13-18	19-24	GT 24	
N	2	3	9	24	3	0	41
NNE	0	4	25	18	0	0	47
NE	0	16	12	1	0	0	29
NNE	0	15	11	0	0	0	26
E	0	24	7	0	0	0	31
ESE	0	31	3	0	0	0	34
SE	2	20	13	0	0	0	44
SSE	1	17	25	0	0	0	43
S	0	17	25	0	0	0	42
SSW	0	3	9	0	0	0	12
SW	0	1	17	6	0	0	24
WSW	0	2	7	2	0	0	11
W	0	9	23	4	0	0	36
WNW	1	11	12	1	0	0	25
NW	0	10	22	0	0	0	32
NNW	0	4	8	0	0	0	12
VARIABLE	1	0	0	0	0	0	1
TOTAL	7	196	228	56	3	0	490

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 198

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JULY - SEPTEMBER 1979
 STABILITY CLASS - MODERATELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
-----	0-3	4-7	8-12	13-18	19-24	-----	-----
N	0	1	0	2	0	0	3
NNE	1	3	1	0	0	0	5
NE	0	5	1	0	0	0	6
NNE	0	5	0	1	0	0	6
E	1	6	0	0	0	0	7
ESE	0	3	0	0	0	0	3
SE	0	5	0	0	0	0	5
SSE	0	3	1	1	0	0	5
S	1	3	2	0	0	0	6
SSW	0	0	0	0	0	0	0
SW	0	2	1	0	0	0	3
WSW	0	2	0	1	0	0	3
W	0	0	1	0	0	0	1
WNW	0	1	2	0	0	0	3
NW	2	0	0	0	0	0	2
NNW	0	2	1	0	0	0	3
VARIABLE	0	0	0	0	0	0	0
TOTAL	5	41	10	5	0	0	61

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 198

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JULY - SEPTEMBER 1979
 STABILITY CLASS - SLIGHTLY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	0-3	4-7	8-12	13-18	19-24	GT 24	
N	1	4	5	3	0	0	13
NNE	0	2	5	0	0	0	7
NE	0	4	2	0	0	0	6
NNE	2	0	1	0	0	0	3
E	1	2	0	0	0	0	3
ESE	0	4	1	0	0	0	5
SE	0	3	1	0	0	0	4
SSE	0	2	6	0	0	0	8
S	0	5	1	0	0	0	6
SSW	0	4	0	0	0	0	4
SW	1	1	0	1	0	0	3
WSW	0	1	1	0	0	0	2
W	0	1	1	0	0	0	2
WNW	0	2	1	0	0	0	3
NW	1	0	2	0	0	0	3
NNW	0	0	2	0	0	0	2
VARIABLE	0	0	0	0	0	0	0
TOTAL	6	35	29	4	0	0	74

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 198

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JULY - SEPTEMBER 1979
 STABILITY CLASS - NEUTRAL (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
	.7-3	4- 7	8-12	13-18	19-24	GT 24	
N	0	22	11	5	0	0	38
NNE	1	8	18	7	0	0	34
NE	3	10	3	0	0	0	16
ENE	3	8	7	1	0	0	19
E	1	7	3	5	0	0	16
ESE	3	9	1	1	0	0	14
SE	5	21	0	0	0	0	26
SSE	2	12	19	0	0	0	33
S	3	25	8	0	0	0	36
SSW	0	13	4	1	0	0	18
SW	1	6	11	8	0	0	26
WSW	2	10	10	4	0	0	26
W	3	13	9	0	0	0	25
WNW	1	7	3	0	0	0	11
NW	1	6	4	0	0	0	11
NNW	0	10	6	0	0	0	16
VARIABLE	2	0	0	0	0	0	2
TOTAL	31	187	117	32	0	0	367

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 198

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JULY - SEPTEMBER 1979
 STABILITY CLASS - SLIGHTLY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
-----	7-3	4- 7	8-12	13-18	19-24	-----	-----
N	5	19	11	1	0	0	36
NNE	3	12	25	4	0	0	44
NE	2	10	9	5	0	0	26
ENE	4	5	3	1	0	0	13
E	2	8	3	1	0	0	14
ESE	1	10	3	1	0	0	15
SE	4	17	4	0	0	0	25
SSE	3	12	8	1	0	0	24
S	4	38	7	0	0	0	49
SSW	10	47	15	0	0	0	72
SW	2	29	15	6	0	0	52
WSW	4	28	16	2	0	0	50
W	5	22	4	1	0	0	32
WNW	1	22	4	0	0	0	27
NW	7	39	4	0	0	0	50
NNW	7	21	7	0	0	0	35
VARIABLE	16	0	0	0	0	0	16
TOTAL	80	339	138	23	0	0	580

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 198

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JULY - SEPTEMBER 1979
 STABILITY CLASS - MODERATELY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	1-3	4-7	8-12	13-18	19-24		
N	2	5	0	0	0	0	7
NNE	0	2	0	0	0	0	2
NE	1	0	1	0	0	0	2
NNE	1	0	0	0	0	0	1
E	2	0	2	0	0	0	4
ESE	0	1	1	0	0	0	2
SE	0	5	0	0	0	0	5
SSW	0	1	0	0	0	0	1
S	2	13	0	0	0	0	15
SSW	9	31	2	0	0	0	42
SW	5	24	8	0	0	0	37
WSW	8	17	1	0	0	0	26
W	6	13	1	0	0	0	20
WNW	6	9	1	0	0	0	16
NW	6	14	0	0	0	0	20
NNW	6	9	0	0	0	0	15
VARIABLE	11	0	0	0	0	0	11
TOTAL	65	144	17	0	0	0	226

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 198

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - JULY - SEPTEMBER 1979
 STABILITY CLASS - EXTREMELY STABLE
 WINDS MEASURED AT 35 FEET
 (DELTA T 125-35 FT)

WIND DIRECTION	WIND SPEED (IN MPH)					
	7-3	4-7	8-12	13-18	19-24	GT 24
N	1	0	0	0	0	0
NNE	0	0	0	0	0	0
NE	0	0	0	0	0	0
ENE	0	0	0	0	0	0
E	1	0	0	0	0	0
ESE	0	0	0	0	0	0
SE	0	4	0	0	0	0
SSE	1	0	0	0	0	0
S	3	7	0	0	0	0
SSW	10	16	0	0	0	0
SW	22	28	1	0	0	0
WSW	14	18	0	0	0	0
W	12	8	0	0	0	0
WNW	15	15	0	0	0	0
WW	13	4	0	0	0	0
NNW	3	3	0	0	0	0
VARIABLE	13	0	0	0	0	0
TOTAL	108	103	1	0	0	0

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 0

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 198

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - OCTOBER - DECEMBER 1979
 STABILITY CLASS - EXTREMELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	GT 24	-----
N	1	2	4	10	0	4	21
NNE	0	1	7	2	4	0	14
NE	0	1	3	2	0	0	6
NNE	0	1	3	1	2	3	10
E	0	5	2	0	1	0	8
ENE	0	3	2	3	0	0	8
SE	0	6	9	0	0	0	15
SSE	0	4	7	1	0	0	12
S	0	3	9	0	0	0	12
SSW	1	1	10	10	4	0	26
SW	1	5	15	29	7	0	57
WSW	0	10	38	22	6	0	76
W	0	14	32	10	0	0	56
WNW	1	18	23	6	0	0	48
NW	1	18	35	1	0	0	55
NNW	1	7	10	10	0	0	28
VARIABLE	0	0	0	0	0	0	0
TOTAL	6	99	209	107	24	7	452

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 21
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 20

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - OCTOBER - DECEMBER 1979
 STABILITY CLASS - MODERATELY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	7-3	4-7	8-12	13-18	19-24		
N	1	1	2	0	4	1	9
NNE	0	0	4	0	1	2	7
NE	0	0	1	4	2	0	7
NNE	0	0	0	1	0	0	1
E	0	0	3	1	0	0	4
ESE	0	2	1	0	0	0	3
SE	1	0	0	0	0	0	1
SSE	0	1	3	2	0	0	6
S	0	3	0	0	0	0	3
SSW	0	1	3	2	1	0	7
SW	0	1	7	3	0	0	11
WSW	0	2	7	5	0	0	14
W	0	3	5	7	0	0	15
WNW	0	1	10	2	0	0	13
NW	1	1	11	2	0	0	15
NNW	0	8	4	6	1	0	19
VARIABLE	0	0	0	0	0	0	0
TOTAL	3	24	61	35	9	3	135

HOURS OF CALM IN THIS STABILITY CLASS - 0

HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 3

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 20

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - OCTOBER - DECEMBER 1979
 STABILITY CLASS - SLIGHTLY UNSTABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	GT 24	-----
N	0	1	5	1	1	5	13
NNE	0	0	3	3	2	3	11
NE	0	1	0	0	0	0	1
NNE	0	2	1	0	0	0	3
E	0	0	0	0	0	0	0
ESE	0	1	0	0	1	0	2
SE	1	0	0	0	0	0	1
SSE	0	0	3	1	0	0	4
S	0	1	1	0	0	0	2
SSW	1	2	1	4	0	0	8
SW	1	2	6	7	0	0	16
WSW	0	4	16	5	1	0	26
W	1	0	5	5	0	0	11
WNW	0	3	2	3	0	0	8
NW	0	5	9	3	0	0	17
NNW	0	4	5	1	0	0	10
VARIABLE	0	0	0	0	0	0	0
TOTAL	4	26	57	33	5	8	133

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 4
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 20

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - OCTOBER - DECEMBER 1979
 STABILITY CLASS - NEUTRAL (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	-----	-----
N	0	9	6	10	1	0	26
NNF	0	9	9	5	1	0	24
NE	1	6	3	1	1	0	12
ENE	2	1	1	1	0	0	5
E	1	3	4	0	0	0	8
ESE	0	2	3	2	0	0	7
SE	1	5	5	1	0	0	12
SSE	0	5	20	6	1	0	32
S	0	21	15	7	0	0	43
SSW	4	20	34	21	1	0	80
SW	5	21	33	42	20	1	122
WSW	2	16	31	22	1	0	72
W	1	20	15	12	0	0	48
WNW	3	14	18	6	0	0	41
NW	4	35	36	8	0	0	83
NNW	1	13	19	4	0	0	37
VARIABLE	0	0	0	0	0	0	0
TOTAL	25	200	252	148	26	1	652

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 9
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 20

710N NUCLEAR POWER STATION
 PERIOD OF RECORD - OCTOBER - DECEMBER 1979
 STABILITY CLASS - SLIGHTLY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4- 7	8-12	13-18	19-24		
N	2	1	2	4	0	0	9
NNF	1	2	2	2	0	0	7
NE	1	3	0	0	1	1	6
ENE	1	5	1	1	0	0	8
E	0	3	1	0	0	0	4
ESE	1	1	2	1	0	0	5
SE	2	3	7	0	0	0	12
SSE	0	10	4	3	1	1	19
S	8	36	17	0	1	0	62
SSW	8	45	31	13	0	0	97
SW	7	37	27	10	2	0	83
WSW	3	18	13	3	0	0	37
W	3	26	12	5	0	0	46
WNW	2	62	24	3	0	0	91
NW	4	37	11	0	0	0	52
NNW	1	8	1	1	0	0	11
VARIABLE	1	0	0	0	0	0	1
TOTAL	45	297	155	46	5	2	550

HOURS OF CALM IN THIS STABILITY CLASS - 0

HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 6

HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 20

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - OCTOBER - DECEMBER 1979
 STABILITY CLASS - MODERATELY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)					GT 24	TOTAL
	.7-3	4-7	8-12	13-18	19-24		
N	0	3	0	0	0	0	3
NNE	0	0	0	0	0	0	0
NE	0	0	0	0	0	0	0
NNE	0	1	0	0	0	0	1
E	0	0	0	0	0	0	0
ESE	0	1	0	0	0	0	1
SE	0	0	0	0	0	0	0
SSE	1	0	0	1	0	0	2
S	0	15	7	2	0	0	24
SSW	2	12	1	0	0	0	15
SW	2	7	0	0	0	0	9
WSW	2	8	0	0	0	0	10
W	2	7	0	0	0	0	9
WNW	3	16	0	0	0	0	19
NW	4	14	0	0	0	0	18
NNW	1	4	0	0	0	0	5
VARIABLE	5	0	0	0	0	0	5
TOTAL	22	88	8	3	0	0	121

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 1
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 20

ZION NUCLEAR POWER STATION
 PERIOD OF RECORD - OCTOBER - DECEMBER 1979
 STABILITY CLASS - EXTREMELY STABLE (DELTA T 125-35 FT)
 WINDS MEASURED AT 35 FEET

WIND DIRECTION	WIND SPEED (IN MPH)						TOTAL
-----	.7-3	4- 7	8-12	13-18	19-24	GT 24	-----
N	0	0	0	0	0	0	0
NNE	0	0	0	0	0	0	0
NE	1	0	0	0	0	0	1
ENE	0	0	0	0	0	0	0
E	0	0	0	0	0	0	0
ESE	0	0	0	0	0	0	0
SE	0	0	0	0	0	0	0
SSE	1	0	0	0	0	0	1
S	2	8	12	0	0	0	22
SSW	3	4	0	0	0	0	7
SW	0	10	0	0	0	0	10
WSW	3	7	0	0	0	0	10
W	2	17	0	0	0	0	19
WNW	5	10	0	0	0	0	15
NW	5	4	0	0	0	0	9
NNW	2	1	0	0	0	0	3
VARIABLE	3	0	0	0	0	0	3
TOTAL	27	61	12	0	0	0	100

HOURS OF CALM IN THIS STABILITY CLASS - 0
 HOURS OF MISSING WIND MEASUREMENTS IN THIS STABILITY CLASS - 1
 HOURS OF MISSING STABILITY MEASUREMENTS IN ALL STABILITY CLASSES - 20