

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | A | R | A | N | 0 | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5

7 8 9 14 15 25 26 57 58

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T

01 | R | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 3 | 7 | 0 | 3 | 0 | 7 | 8 | 0 | 0 | 0 | 4 | 0 | 8 | 8 | 0 | 9

7 8 60 61 68 69 74 75 81

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Based on system reviews per I.E. Bulletin 79-14, the attached list of

03 | hangers were determined to be inoperable. Immediate actions were to

04 | modify and restore hanger operability within the specified time frame

05 | per Tech. Spec. LER 50-313/79-010 was a similar occurrence.

06 | Reportable per T.S. 6.12.3.2.b.

07 | _____

08 | _____

09 | X | X | 11 | R | 12 | A | 13 | S | U | P | O | R | T | 14 | X | 15 | Z | 16

7 8 9 10 11 12 13 18 19 20

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP SUBCODE VALVE SUBCODE

17 | 18 | 19 | 20 | 21 | 22 | 23 | 24 | 25 | 26 | 27 | 28 | 29 | 30 | 31 | 32

LER-NO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO OCCURRENCE CODE REPORT TYPE REVISION NO

10 | F | 11 | Z | 12 | Z | 13 | Z | 14 | 0 | 0 | 0 | 0 | 15 | Y | 16 | Y | 17 | A | 18 | 9 | 9 | 9 | 19

33 34 35 36 37 40 41 42 43 44 47

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NFRD-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The affected hangers were repaired/modified within the time interval

11 | set forth per Tech. Spec. Modifications were made by revision to

12 | DCP 80-D-1207.

13 | _____

14 | _____

15 | E | 26 | 1 | 0 | 0 | 27 | NA | 28 | Z | 29 | Notification from Architect Engr. | 30

7 8 9 10 11 12 13 44 45 46 80

FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

16 | Z | 33 | Z | 34 | NA | 35 | NA | 36 | LOCATION OF RELEASE | 37

7 8 9 10 11 44 45 80

ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY

17 | 0 | 0 | 0 | 37 | Z | 38 | NA | 39

7 8 9 11 12 13 40

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

18 | 0 | 0 | 0 | 40 | NA | 41

7 8 9 11 12 40

PERSONNEL INJURIES NUMBER DESCRIPTION

19 | Z | 42 | NA | 43

7 8 9 11 12 43

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

20 | N | 44 | NA | 45

7 8 9 10 11 45

ISSUED DESCRIPTION

PUBLICITY

NAME OF PREPARER Lindsley S. Bramlett PHONE: 501/968-2519

8004140360

<u>HGR. NO.</u>	<u>DATE</u>	<u>TIME</u>	<u>SYSTEM</u>
MU-265	3/7/80	11:30	Makeup & Purif.
DH-112	3/13/80	14:45	Decay Heat
DH-113	3/13/80	14:45	Decay Heat
EFW-77 (PS-1)	3/17/80	11:30	Emerg. Feedwater
MU-228	3/18/80	11:15	Makeup & Purif.
HBD-14-H18	3/19/80	12:35	Service Water
HBD-14-H26	"	"	" "
HBD-14-H27	"	"	" "
EFW-49	3/19/80	12:35	Emerg. Feedwater
EFW-50	"	"	" "
EFW-75	"	"	" "
EFW-55	3/21/80	12:35	" "
EFW-57	"	"	" "
EFW-30	3/24/80	12:45	" "
BS-69	3/24/80	12:45	Building Spray
BS-48	"	"	" "
DH-109	3/25/80	12:45	Decay Heat
BS-39	3/25/80	12:45	Building Spray
MU-216	3/26/80	11:15	Makeup & Purif.
MU-225	"	"	" "
HBD-20-H9A	3/26/80	11:15	Service Water
HBD-20-H12A	"	"	" "
HBD-20-H52A	3/26/80	11:15	Service Water
HBD-14-H19A	3/27/80	13:15	Service Water
HBD-20-H8	3/28/80	08:50	Service Water
HBD-20-SW2	3/31/80	09:30	Service Water
HBD-20-H10A	3/31/80	09:30	Service Water
HBD-38-H49	3/31/80	09:30	Penet. Rm. Vent