

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | N | P | T | N | 1 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ 5
7 8 9 14 15 25 26 57 CAT 58

CON'T
0 1 | L | 0 | 5 | 0 | 0 | 0 | 2 | 8 | 2 | 0 | 3 | 1 | 1 | 8 | 0 | 0 | 4 | 1 | 0 | 8 | 0 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During surveillance test, No. 11 containment vacuum breaker isolation valve opened
0 3 | at 0.57 psi, this is outside the limit of 0.5 psi set in Tech Spec 4.4.C. Not
0 4 | repetitive. No effect on public health and safety. Redundant device was operable.
0 5 | _____
0 6 | _____
0 7 | _____
0 8 | _____

0 9 | S | A | X | Z | I | N | S | T | R | U | S | Z | 8 | 0 | 0 | 1 | 0 | 0 | 3 | L | 0 | E | Z | Z | Z | 0 | 0 | 0 | 0 | N | Y | A | 1 | 2 | 0 | 4
7 8 9 10 11 12 13 18 19 20 21 22 23 24 26 27 28 29 30 31 32 33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | Apparent drift in a Barton Model 288A differential pressure switch. Setpoint was
1 1 | adjusted and valve retested satisfactorily.
1 2 | _____
1 3 | _____
1 4 | _____

1 5 | E | 1 | 0 | 0 | NA | B | SURVEILLANCE TEST
7 8 9 10 12 13 44 45 46 80

1 6 | Z | Z | NA | NA | NA
7 8 9 10 11 44 45 80

1 7 | 0 | 0 | 0 | Z | NA
7 8 9 10 11 12 13 80

1 8 | 0 | 0 | 0 | NA
7 8 9 10 11 12 80

1 9 | Z | NA
7 8 9 10 80

2 0 | N | NA
7 8 9 10 80

NAME OF PREPARER A A Hunstad

PHONE: 612-388-4767

8004150603