

TEXAS UTILITIES GENERATING COMPANY

2001 BRYAN TOWER · DALLAS, TEXAS 75201

R. J. GARY
EXECUTIVE VICE PRESIDENT
AND GENERAL MANAGER

April 15, 1980
TXX-3123

Mr. W. C. Seidle, Chief
Reactor Construction & Engineering
Support Branch
U. S. Nuclear Regulatory Commission
Office of Inspection & Enforcement
611 Ryan Plaza Dr., Suite 1000
Arlington, Texas 76012

Docket Nos. 50-445
50-446

COMANCHE PEAK STEAM ELECTRIC STATION
1981-83 2300 MW INSTALLATION
PIPING MINIMUM WALL
FILE NO: 10110

Dear Mr. Seidle:

This progress report supplements our letters TXX-3088 and TXX-3092, dated January 14 and 23, 1980, respectively, relative to a violation of piping minimum wall thicknesses previously reported to your office in accordance with 10 CFR 50.55(e).

A total of twenty (20) safety-related systems had welds evaluated based on either physical or ultrasonic testing measurements. Of the systems evaluated, five (5) systems had measured wall thicknesses equal to or greater than the specified minimum wall requirement. Those systems are the:

Service Air
Instrument Air
Steam Generator Blowdown and Cleanup
Vents and Drains
Liquid Waste Processing

The review of weld and base metal repair records is continuing and a subsequent progress report will be submitted to your office by June 20, 1980.

Very truly yours,

R. J. Gary
R. J. Gary

RJG:df
cc: NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
c/o Distribution Services Branch, DDC, ADM.
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

8004220423