

SNUPPS

Standardized Nuclear Unit
Power Plant System5 Choke Cherry Road
Rockville, Maryland 20850
(301) 869-8010Nicholas A. Petrick
Executive Director

May 16, 1980

SLNRC 80-24 FILE: 0491.10.2/M-627B
SUBJ: Ruskin Manufacturing Co. Fire
Dampers: SNUPPS Units 1 (Wolf
Creek) and 2 (Callaway 1)Mr. Boyce Grier
Director, Region I
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, Pennsylvania 19406Re: STN 50-482
STN 50-483
STN 50-486Ref: a) SLNRC 80-8 dated 2/15/80: Subject as Above
b) SLNRC 80-16 dated 4/3/80: " "

Dear Mr. Grier:

The Ref. a) letter forwarded to the NRC per 10CFR50.55(e) regulations, a report concerning deficiencies in the vertical fire dampers furnished by Ruskin Manufacturing Co. to the Callaway and Wolf Creek jobsites. The Ref. b) follow-up letter indicated that, as a result of continuing investigations, additional problems had been identified in the Ruskin dampers requiring further design modification and qualification testing. The additional problems experienced since the initial Ref. a) report are described in a supplemental 10CFR50.55(e) report, enclosed herewith. This supplement describes modifications established and implemented by Ruskin Manufacturing Co. and which ultimately will be qualified on the basis of performance tests prior to and during site installation. A follow-up program to ensure proper implementation of these modifications has since been established at each SNUPPS jobsite and will be monitored by cognizant site personnel.

The attached supplement is being treated as a final report under current 10CFR50.55(e) definition. In the event additional actions are found to


THIS DOCUMENT CONTAINS POOR QUALITY PAGES
--

Bo 19
5/11

May 16, 1980

be necessary to fully resolve this matter, these will be communicated to the NRC. In the interim, further questions can be addressed to Mr. S. J. Seiken, SNUPPS QA Manager, at (301) 869-8010.

Very truly yours,



Nicholas A. Petrick

SJS:dck/A7

Attachment: Supplement to the Final Report on Vertical Fire Dampers

cc: Mr. J.A. Keppler, Director, Region III, USNRC
Mr. Karl Seyfrit, Director, Region IV, USNRC
Mr. Victor Stello, Jr., Director, Office of Inspection and
Enforcement, USNRC, Washington, D.C.
-Document Management Branch, USNRC, Washington, D.C.