8005200 457

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A R A N O 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T 0 1 REPORT SOURCE L (6) | 0 5 0 0 0 3 6 8 (7) | 0 1 2 9 8 0 (8) | 0 5 1 3 8 0 (9)
DOCKET NUMBER | EVENT DATE | REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During the recovery from a planned unit transient per Power Escalation
0 3 100 percent Turbine Trip Test, the RCS depressurized to a minimum of
0 4 1350 psia (Saturation Margin = 57°F). ECCS Subsystem, Safety Injection
0 5 Actuation Signal (SIAS) activated at 1740 psia per design Engineering
0 6 evaluation determined that one (1) cycle of the 160 allowable safety
0 7 injection nozzle thermal cycles was experienced during the transient.
0 8 ECCS actuation and injection of water is reported per T.S.3.5.2.a pursuant to T.S.6.9.2.a.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	S F (11)	X (12)	Z (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 1 5	/	9 9	X	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
X (18)	Z (19)	Z (20)	Z (21)	0 0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The Reactor Coolant System pressure excursion was larger than normal
1 1 (after a turbine trip) due to Pressurizer Spray Valve, 2CV-4651, and
1 2 Steam Dump & Bypass Valve, 2CV-0301, not fully reclosing on demand from
1 3 their respective controllers. The spray valve operator & the dump valves
1 4 are being modified for increased reliability.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	B (28)	0 0 0 0 (29)	Pwr Esc Testing	A (31)	NA

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)
2 0	N (44)	NA

NRC USE ONLY

NAME OF PREPARER Chris N. Shively PHONE 501/968-2519

POOR ORIGINAL