

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

830 Power Building

NOV 16 1978

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

Dear Mr. Denton:

In the Matter of the Applications of ) Docket Nos. STN 50-553  
Tennessee Valley Authority ) STN 50-554

In a November 13, 1978, telephone conversation, Jerry Wills of my staff notified Sydney Miner of your staff that an additional fault had been discovered at the Phipps Bend Nuclear Plant in the unit 2 fuel building area. A conference call was subsequently made to the NRC geologist, Sandy Wastler, on November 14, 1978, to discuss the fault. The enclosure provides a detail description of this feature.

We do not consider this minor fault to be capable within the meaning of Appendix A to 10 CFR Part 100. In compliance with our previous commitments, evidence of this feature in the unit 2 fuel building area will be held for your investigation until December 1, 1978.

Very truly yours,

*J. E. Gilleland*  
for J. E. Gilleland  
Assistant Manager of Power

Enclosure

7811220211

BOOSE  
111

ENCLOSURE

PHIPPS BEND NUCLEAR PLANT  
DOCUMENTATION OF FAULT IN UNIT 2 FUEL BUILDING EXCAVATION

The fault is located in the northern half of the unit 2 fuel building area on the east wall of the spent fuel storage pool excavation (see attached sketch).

The fault is a reverse fault dipping  $84^{\circ}$  to the north and striking  $N45^{\circ}E$ , coinciding with the regional orientation of the rock strata. The fault extends 65 feet to the west of the east wall where it is covered with debris and extends eastwardly beyond the excavation. The fault is defined by a calcite filled fracture offsetting beds which dip  $68^{\circ}$  to the south approximately 6 inches. It is located 95 feet north of the first fault reported in unit 2 reactor building and 106 feet north of unit 2 east-west baseline.


The fault shows no evidence which would indicate that it did not occur during the early tectonic development of the Paleozoic (250+ million years) folding and faulting in this area.

The strike of the fault ( $N.45^{\circ}E.$ ) conforms with the regional trend of the Paleozoic rock strata (about  $N.50^{\circ}E.$ ) and trends beneath undisturbed Quaternary high-level terrace deposits located to the northeast. Folding and minor faulting within the foundation bedrock was expected and is considered to be typical of the well-documented regional folding and faulting of Paleozoic age. Because of the minor offset and the overlying Quaternary terrace deposits, it is not considered capable of producing ground offsets or of generating earthquakes. Therefore, we do not classify it as a capable fault within the meaning of Appendix A to 10 CFR Part 100.



View East. Fault located on north end of  
spent fuel storage pool - Unit 2 Fuel Building.  
Approximately 106 feet north of east-west baseline.

POOR ORIGINAL



Area not cleaned

Fault

Area covered

Photo

ASSUMED NORTH

E-W BASE LINE  
N 59° 30' 00" E

Phipps Bend  
Nuclear Plant  
Unit 2  
Scale: 1" ≈ 50'

POOR ORIGINAL

M

K

J