

METROPOLITAN EDISON COMPANY SUBSIDIARY OF GENERAL PUBLIC UTILITIES CORPORATION

ST OFFICE BOX 460 MIDDLETOWN, PENNSYLVANIA 17057 TELEPHONE 717-344-4041

June 14, 1974

*DK Central File*

Mr. J.P. O'Reilly, Director  
Directorate of Regulatory  
Region I  
631 Park Avenue  
King of Prussia, Pa. 19406

*[Handwritten signatures]*

Operating License DPR-50  
Docket 50-289

POOR ORIGINAL

Subject: Abnormal Occurrence No. AG 74-10

Dear Mr. O'Reilly:

This telegram is to confirm the telecon between Lee Spessard (Region I-AEC), and J.G. Herbein (TNI-Superintendent) at 1430 HRS. 13 June 1974.

The following report is submitted in accordance with paragraph 6.7.2.a (page 6-11) of the Technical Specifications.

On 13 June the IC Make-up Pump failed as a result of being operated with a closed suction valve.

At the time of failure the IC Make-up Pump was being placed in service to enable shutdown of the IB Make-up Pump.

The IB Make-up Pump was supplying reactor coolant system make-up water and RC pump seal injection water when the IC Make-up Pump failed.

The IC Make-up Pump was immediately shutdown when the normal motor start current was not indicated following control switch closure.

A thorough investigation is presently being conducted to determine all circumstances surrounding the recent Make-up Pump failures.

Very truly yours,

*[Handwritten signature of J.G. Herbein]*

J.G. Herbein  
Station Superintendent  
TNI Nuclear Station