

DK

ST OFFICE BOX 480 MIDDLETON, PENNSYLVANIA 17057

TELEPHONE 717-944-4041

June 6, 1974

Mr. J.P. O'Reilly, Director
Directorate of Regulatory Operations
Region I
631 Park Avenue
King of Prussia, Pa. 19406

Operating License DPR-50
Bucket 50-289

Subject: Environmental Incident No. EI 74-4

Dear Mr. O'Reilly:

This telegram is to confirm a conversation between D. Sterberg (Region I-DRO), and J.G. Herbein (TMI Superintendent) at 1030 HRS. 6 June 1974.

Violation of the Environmental Technical Specification 2.2.1.a (page 7) in that the total chlorine component measured at the plant river discharge exceeded .2 ppm on 6 June 1974.

Analysis of the total chlorine component in the plant river discharge 10 minutes after the start of a chlorination cycle indicated .215 ppm, at 30 minutes indicated .22 ppm and at 50 minutes indicated .25 ppm.

The chlorine addition rate has been reduced from 250 #/day to 200 #/day.

Very truly yours,

J.G. Herbein
Station Superintendent
TMI Nuclear Station

JGH/dan

POOR ORIGINAL

af

7910250 681

5