

Central Files



METROPOLITAN EDISON COMPANY A DIVISION OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 489, HADDONFIELD, NEW JERSEY 07033 TELEPHONE 717,921-4041

January 12, 1978

Mr. Bruce H. Grier
Directorate of Regulatory Operation
Region -1
Nuclear Regulatory Commission
630 Park Avenue
King of Prussia, PA 19406

POOR ORIGINAL

Operating License DPR-50
Docket 50-289

Subject: Reportable Occurrence No. 78-2/1P

Dear Mr. Grier:

This telegram is to document the conversation between Mr. P. J. Kellogg, (NRC Inspector) and Mr. J. P. O'Hanlon (TMI-1 Superintendent) at 1045 hours on January 12, 1978.

A violation of the Technical Specification 3.18.3.2.a was recognized at 0730 on January 12, 1978, in that a continuous fire watch was not established for a period of about 63 hours after the "A" Emergency Diesel Room Sprinkler Isolation Valve was closed. This incident is considered Reportable under T.S. 6.9.2A.2.

FS-V-156 was closed at about 0500 on January 10, 1978, but due to an incorrect interpretation of the recently issued Fire Service Technical Specification, only a periodic diesel room fire inspection was made until about 1030 on January 12, 1978, at which time a continuous fire watch was established.

Further details of this incident and the corrective actions taken will be forwarded to you in the 14 day report.

Very truly yours,

J. P. O'Hanlon
Unit Superintendent

JPO:dws

7910250 743
504