

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

October 23, 1979

Director of Nuclear Reactor Regulation
Attention: Mr. L. S. Rubenstein, Acting Chief
Light Water Reactors Branch No. 4
Division of Project Management
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Rubenstein:

In the Matter of the Application of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

Enclosed is Revision 4 of TVA's response to the Auxiliary Systems Branch (ASB) fire protection review questions for the Sequoyah Nuclear Plant. This information was requested in your letter to N. B. Hughes dated September 1, 1978. The original information, Revision 1, Revision 2, and Revision 3 were submitted by my letters to you dated November 9, 1978, December 19, 1978, January 19, 1979, and March 8, 1979, respectively. This revision includes:

1. Revisions to our responses to ASB questions 1, 3, 7, 9, 15, 18, 20, and 27. These revisions answer open items that remained after your subsequent evaluation of our responses.
2. Revised responses to additional discussion items.
3. Various figures to supplement our responses.
4. Revised commitment schedule.


Very truly yours,

TENNESSEE VALLEY AUTHORITY

[Handwritten signature]

L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosure



THIS DOCUMENT CONTAINS
POOR QUALITY PAGES

910260159

Handwritten notes:
B002
3/10/10
DEWETS TO:
P.M.
FILES
NRE POR
LPOR
AD/PLANT SYS
AUX SYS BR(2)
Q AB
PWR SYS BR
TERA
ALL OTHERS RE-
CEIVE LTR
REPRODUCTION
ENCL

POOR ORIGINAL

AUXILIARY SYSTEMS BRANCH
FIRE PROTECTION REVIEW
SEQUOYAH NUCLEAR PLANT - UNITS 1 AND 2
DOCKET NUMBERS 50-327/328

11/9/78
R1- 12/15/78
R2--1/16/79
R3--3/5/79
R4--10/19/79

1. Your submittal provides only part of the information requested in Enclosure 2 to our letter dated September 30, 1976. A fire hazards analysis should be conducted for each plant fire area, and the effects of postulated fire involving permanent and/or transient combustibles on systems, circuits, or equipment required for safe plant cold shutdown should be evaluated. The fire detection and primary and secondary fire suppression systems for each area should also be indicated. In the fire hazards analysis you should identify all the redundant mechanical and electrical systems necessary for safe cold shutdown which are separated only by distance (no fire barriers). The fire hazards analysis should demonstrate that, assuming failure of the primary suppression system, a fire in installed or transient combustibles will not damage redundant trains or divisions of systems required for safe plant cold shutdown. Where this cannot be demonstrated, an alternate means of assuring safe plant shutdown (cold shutdown) should be provided.

TVA Response

Sequoyah Nuclear Plant's fire protection system design was based on the results of a fire hazards analysis covering those areas where an unmitigated fire could affect a unit's ability to reach and maintain a safe cold shutdown. The analysis involved a detailed review of the plant design and an evaluation of the effects of postulated fires.

The results of the analysis are provided in part in the Sequoyah Nuclear Plant Fire Protection Program Reevaluation forwarded to the NRC by letter from J. E. Gilleland to R. S. Boyd dated January 24, 1977. The following discussion supplements the original documentation.

Based upon the fuel loading and compartmentation of fire cells, fire suppression and detection systems have been provided in the various plant areas as identified in Table 1-1. When fixed suppression systems are provided in an area, they are considered the primary systems. Backup protection is provided by standpipe systems or yard hydrants. When manual systems are used exclusively in an area, they are considered the primary systems and are backed up by manual systems in adjacent areas.

Figure 1.1 is a safe shutdown logic diagram for a fire at Sequoyah Nuclear Plant. This figure and its comment sheet identify those plant features necessary to achieve and maintain a safe plant shutdown in the event of a fire. TVA has conducted an analysis of the plant based upon this diagram and its comment sheet assuming a postulated exposure fire with a zone of influence requiring a minimum 20-foot spatial separation of redundant equipment, circuits, or components in all plant areas outside of containment. This analysis has identified where additional protection

and/or reparation is required to assure that the hot shutdown condition is reached during a fire using only existing hardware and no extraordinary operating action (i.e., the operator's response will not be required in less than 15 minutes and will consist of plant manipulations typical of those required for normal operation). The analysis does not consider inside primary containment because transient fire loads in this area, when the plant is at power, are not credible, and fixed hazards which pose an exposure threat to equipment components or circuits required for safe shutdown (i.e., reactor coolant pumps) are provided with fixed automatic water suppression systems, automatic detection capability, and an oil collection pan with drains to prevent spilled oil from contacting hot piping. Note that terms such as inadequate separation and unacceptable interaction when used in this discussion refer to the inability to achieve 20-foot spatial separation within a fire cell. These terms do not imply violation of separation as specified in the plant design criteria.

Throughout this discussion an asterisk (*) will be used to identify the title of a function block on the shutdown logic diagram (Figure 1.1). This diagram and its keyed comments are germane and are an integral part of the following discussion.

Hot Shutdown

Each of the six conditions necessary to achieve hot shutdown are discussed separately. Refer to the six conditions which provide input into the AND block that leads to the hot shutdown condition on the shutdown logic diagram.

Secondary Side Pressure Control - The Secondary Safety Valves* and the Secondary Relief Valves* can satisfy this plant condition. The spring-loaded secondary safety valves used for short-term control are considered immune to fire damage. The secondary relief valves used for long-term control are adequately separated so that access to the required two valves for manual actuation can be assured during a fire. The redundant circuits for the steam generator pressure instrumentation were found to be inadequately separated. TVA will provide the required instrumentation integrity in accordance with Table 1.3. Since this satisfies the required condition, TVA has not evaluated control via the Main Steam System* nor remote electrical control of the power-operated secondary relief valves.

Steam Generator Inventory Control - This plant condition requires an auxiliary feedwater pump capable of feeding any two steam generators, level control for these steam generators, and suction to the pump. This analysis has identified areas where the postulated exposure fire described above would affect both the A and B train sections of the Motor-Driven Auxiliary Feedwater Pump* function. Other areas were identified where a separate postulated exposure fire would affect both trains of the Turbine-Driven Auxiliary Feedwater Pump* function. However, no single postulated fire exists which would affect both of these functions.

Interactions also exist for the automatic control of the Steam Generator Level Control* function. These interactions have been deemed acceptable because the control valves themselves are adequately separated and manual control is achievable. Unacceptable interactions were found to exist for the steam generator level signal which is necessary for both manual or automatic level control. TVA will provide the necessary protection of this function in accordance with Table 1.3. Suction from the ERCW* (essential raw cooling water system) was not evaluated because suction from the Condensate Storage Tank* is assured due to the tank being immune to fire damage.

Reactor Coolant System Inventory Control - This condition requires that RCS letdown be controlled, that RCS makeup be provided, and that reactor coolant pump seal integrity be assured. These three conditions are discussed separately.

RCS Letdown Control - This condition can be satisfied by closure of any one of a number of Letdown Isolation Valves* in each of two series strings of valves. Since all of the valves involved are air-operated valves which would fail in the desired position should their control cable be damaged, these control circuits were not evaluated for separation.

RCS Makeup - This condition requires the availability of a charging pump, pump suction, and a flow path into the RCS. Of these, water, via Volume Control Tank Suction* and Refueling Water Storage Tank Suction*, is assured since the tanks themselves perform only a passive function which would not be jeopardized by a fire, and manual handwheel operation of the RWST suction valves is acceptable.

The analysis noted that the single postulated exposure fire described above could cause the loss of both trains of the CVCS Centrifugal Charging Pump* and the Positive Displacement Charging Pump*. TVA will correct this unacceptable condition by rerouting the wiring for the positive displacement charging pump and the positive displacement pump room cooler in accordance with Table 1.2. This pump was chosen for rerouting because it is the pump used in normal operation; hence, its flow path is already properly aligned. The ECCS charging Flow Path* associated with the centrifugal pumps contains interactions which can affect both A and B train sections. These interactions are acceptable because they do not affect the positive displacement charging pump; hence, either the positive displacement pump via the normal charging path or the centrifugal charging pump(s) via the ECCS path(s) are available during any postulated fire.

Control of RCS makeup via either the ECCS (centrifugal) pumps or the normally operating (positive displacement) pumps requires a pressurizer level signal. Unacceptable interactions were found to exist between conduits associated with the required instrumentation wiring. TVA will correct this condition in accordance with Table 1.3. The component cooling water and

essential raw cooling water systems are identified in the keyed comments as being required for RCS makeup. Unacceptable interactions do exist in both of these systems. The CCS mechanical system interactions and how they are resolved are discussed in the response to question 13. The CCS and ERCW electrical system interactions will be protected in accordance with Table 1.4.

RCP Seal Integrity - Seal integrity for the reactor coolant pumps can be assured if either the positive displacement charging pump or the centrifugal charging pump and the associated Charging Flow Control Valve, FCV62-93*, are available to provide injection water to the seals. The modifications proposed to upgrade the system in the preceding paragraph will assure RCP seal integrity. RCP Thermal Barrier Cooling* also would assure this required condition. This path does contain interactions which would affect both its A and B train sections. These interactions are deemed acceptable because RCP seal injection is assured.

Secondary Side Isolation - The Main Steam Isolation Valves* are stored-energy, fail-closed valves which require both A and B control signals to remain in the open position. A postulated fire which would affect the control cables would cause the valves to shut, assuring this function. Hence, these control cables and those for the parallel path, Steam Load Isolation*, were not evaluated.

Analysis of the Main Feedwater Isolation Valves* indicated that at least one of the two valves in each feedwater line could be shut for the postulated fire. Hence, the Main Feedwater Pump* function, a parallel path to feedwater isolation, was not evaluated.

Each steam generator blowdown line contains an A and B train blowdown Isolation Valve* in series. Both valves would fail in the desired, closed position if there was fire damage to the control cables; hence, this feature is considered to be assured and was not evaluated.

RCS Pressure Control - Trained power cables outside primary containment for the Pressurizer Heaters* were found to interact within 20 feet in two locations. Within the reactor building annulus, the two trains are separated by 19 feet for most of their routing, but approach 13 feet at the primary containment penetration. This interaction has been deemed acceptable because of the low probability for transient fire loads within the annulus area and because all exposed surfaces of cable within this area have been provided with a flame-retardant mastic coating.

The second interaction involves opposite trains approaching to within three feet at an orthogonal crossing on elevation 759 of the auxiliary building near the pressurizer transformers and switchgear. The divisional medium-voltage (6900 volts) power cables for the supply to the 6.9-kV/480V stepdown pressurizer heater transformer are routed in cable trays located above power cables of the redundant division. TVA will reroute the unit 1 and unit 2 pressurizer heater 6900V power cables to achieve a minimum 20 feet separation from the redundant division in accordance with Table 1.2. Automatic sprinkler protection will be provided in the area of the power cables in trays.

Instrumentation conduits which contain the pressure signals necessary for control interact within the auxiliary building. TVA will correct this condition in accordance with Table 1.3.

Initial Reactivity Control - The trained Reactor Trip System* which provides this condition is a fail-safe system which will respond to the postulated fire by causing the control rods to be inserted. Thus, no evaluation was considered necessary.

Cold Shutdown

The dashed section of the shutdown logic diagram identifies two additional plant conditions, Long Term Heat Removal and Long Term Reactivity Control, which must be established to place the plant in the cold shutdown condition. This section of the shutdown logic diagram has been analyzed to assure that all required plant conditions can be established within 72 hours of a postulated fire having a zone of influence requiring a minimum 20-foot separation. It should be noted that unlike the hot shutdown analysis, the cold shutdown analysis does take credit for damage control measures which cannot be considered typical of normal plant operation. These extraordinary actions are described below.

Long Term Heat Removal - The condition requires the Residual Heat Removal (RHR) system to be operable. It is realized when an RHR Shutdown Cooling Flow Path* is established and the RHR Pumps* are operational. Manual handwheel operation of all required valves is acceptable with no further evaluation. All other features were found to be adequately separated except the cables which supply the RHR pump room coolers. TVA's resolution of this interaction is described in table 1.5. (Note: Unacceptable interactions do exist within the component cooling water--CCS--system. These interactions and their resolutions have been discussed in the hot shutdown analysis above and also in the response to question 13.)

Long Term Reactivity Control - To establish an acceptable shutdown margin under cold conditions, the contents of the boron injection tank (BIT) must be charged into the reactor coolant system. The Flow Path Through the BIT* can be established by manual handwheel operation of the required valves and was not evaluated further. Analysis of RCS Makeup Capability* has been made above as part of RCS INVENTORY CONTROL analysis. Please refer to this discussion for interactions and their resolution.

Conclusion


As a result of the preceding analysis and the identification of areas where 20-foot spatial separation of redundant circuits required for safe shutdown within a fire cell has not been achieved, protective measures described in Tables 1.2, 1.3, and 1.4 shall be implemented. TVA has provided by separate submittal, marked drawings showing the new cable routing for relocated cables and conduits listed in Table 1.2 and the relative locations of the redundant counterpart cables and/or conduits. These modifications will assure the ability to achieve the hot shutdown condition as discussed previously in this response. The cold shutdown condition can be achieved within 72 hours through the implementation of temporary damage control measures and extraordinary operator actions described in table 1.5.


Strict administrative procedures have been established to control transient combustibles and are included in the Sequoyah Physical Instruction, PHYSI-13. The procedure requires identification of the routes for transient combustibles and the procedure takes no credit

for the fixed suppression system in regard to its extinguishing capability for transient fire loads. The procedure requires provisions for additional fire protection that is capable of suppressing the transient fire load.

With the defense-in-depth as described above, protection to redundant divisions of systems from installed or transient combustibles has been provided to ensure capability of safe shutdown of the plant.

FIRE





KEYED COMMENTS

1. Requires auxiliary lube oil pump AND power to pump room cooler AND ERCW to pump oil cooler AND ERCW to pump room cooler AND CCS water to ERCW heat exchangers.
2. Requires appropriate section of pressurizer level control system AND EITHER B auxiliary air compressor OR station air compressor.
3. Requires ERCW to pump room cooler AND power to pump room cooler AND CCS water to pump oil cooler AND CCS water to pump speed control AND ERCW to CCS exchanger AND EITHER automatic speed control from appropriate section of pressurizer level control system OR manual speed control using pressurizer level instrumentation.
4. Short-term make up source, normally aligned, no action required.
5. Long-term make up source requires opening of FCV62-135 OR FCV62-136, hand wheel operation acceptable.
6. Flow path requires opening an inlet valve (EITHER FCV63-25 OR FCV63-26) AND an outlet valve (EITHER FCV63-39 OR FCV63-40) for the boron injection tank.
7. Termination of normal letdown requires closure of FCV62-77 OR FCV62-70 OR FCV62-69 OR all three valves FCV62-72, FCV62-73 and FCV62-74.
8. Termination of excess letdown requires closure of FCV62-54 OR FCV62-55 OR FCV62-56.
9. Requires CCS water to thermal barrier booster pump AND ERCW to CCS heat exchangers.
10. IF B train is selected, an additional requirement is opening capability for FCV70-9, FCV70-10, FCV70-195 and FCV70-196.
11. Requires automatic control AND hydraulic motor for back pressure regulating valve (A train PCV3-122, B train PCV3-132).
12. Requires automatic control signal to level control valves (A train LCV3-156 AND LCV3-164, B train LCV3-148 AND LCV3-171) OR steam generator level instrumentation for manual control (A train steam generator 1 AND 2, B train steam generator 3 AND 4). Manual control consists of on/off operation of the pump.
13. IF automatic control is selected, an additional requirement is the appropriate train of auxiliary air compressor OR service air compressor.
14. Not a true A and B train system--the turbine-driven auxiliary feedwater subsystem may be considered to be a separate single train, which can be supplied with control and power from either of the traditional A and B trains.

15. Requires turbine trip and throttle valves (FCV1-51), AND governor valve (FCV1-52).
16. Requires automatic signal to any two level control valves (LCV3-172, LCV3-173, LCV3-174, LCV3-175) OR steam generator level instrumentation for manual control of any two steam generators. Manual operation consists of handwheel operation of the level control valves.
17. Normally aligned, no action required.
18. IF automatic speed control is selected, an additional requirement is B train auxiliary air compressor OR service air compressor.
19. Requires suction valves to open AND ERCW system availability.
20. Requires closure of all main steam isolation AND isolation bypass valves (FCV1-4, FCV1-11, FCV1-22, FCV1-29, FCV1-147, FCV1-148, FCV1-149, FCV1-150).
21. Requires closure of main steam dump valves AND main turbine trip and throttle valve AND main feedwater pump turbine trip and throttle valves.
22. Requires closure of a feedwater isolation valve (FCV3-33, FCV3-47, FCV3-87, FCV3-100) OR closure of a feedwater control and bypass valve pair in each feed line (FCV3-35 AND FCV3-35A, FCV3-48, AND FCV3-48A, FCV3-90 AND FCV3-90A, FCV3-103 AND FCV3-103A).
23. Requires trip of main feedwater pump turbine.
24. Requires closure of one valve in each blowdown line (FCV1-7 OR FCV1-181) AND (FCV1-14 OR FCV1-182) AND (FCV1-25 OR FCV1-183) AND (FCV1-32 OR FCV1-184).
25. Self actuating, short-term control.
26. Long-term control, requires operability of any two relief valves (PCV1-5, PCV1-12, PCV1-23, PCV1-30 manual control acceptable) AND pressure instrumentation for same two steam generators.
27. Requires opening of two main steam isolation OR isolation bypass valves AND control of main steam dump valves AND condenser circulating water.
28. Manual control requires RCS wide range temperature and pressure instrumentation.
29. Requires reactor shutdown by driving in control rods OR manual scram signal OR manual opening of scram breakers OR de-energizing of rod drive motor generator.
30. Requires opening FCV74-1 AND FCV74-2. Handwheel operation is acceptable.

31. Requires RHR pump operability (temporary cables are acceptable) AND CCS water to RHR heat exchanger (handwheel operation of A train valve FCV70-156 or B train valve FCV70-153 is acceptable) AND CCS water to RHR pump seal cooler AND RHR pump room cooling (portable blower is acceptable).
32. Flow path requires opening an inlet valve (EITHER FCV63-25 OR FCV63-26) AND an outlet valve (EITHER FCV63-39 OR FCV63-40) for the boron injection tank. Handwheel operation is acceptable.
33. Requires (water to charging pump via Volume Control Tank Suction* (key 4) or RWST Suction* (key 5)) AND (CVCS Centrifugal Charging Pump* (key 1) OR (Positive Displacement Charging Pump* (key 3) AND Charging Flow Control Valve FCV 62-94*, (this valve may be manually opened by isolating and venting control air from its operator)).

TABLE 1-1

The following table summarizes the fire protection systems provided in the Sequoyah Nuclear Plant. The table covers only those areas where an unmitigated fire could affect a unit's ability to reach and maintain a safe cold shutdown condition.

- Notes:
- (1) Refer to the SK-1000 series of compartmentation drawings for location of the tabulated areas.
 - (2) The compartmentation fire rating column identifies the rating of the most limiting component in the compartmentation boundary. Refer to the response to question 3 for additional compartmentation information.
 - (3) Refer to the response to question 12 for a discussion of the fire retardant coating of exposed cable trays.
 - (4) Legend:

- I - Ionization smoke detector
- IR - Infrared flame detector
- LT - Linear thermistor
- PE - Photoelectric smoke detector
- RC - Rate compensated thermal detector
- T - Fixed temperature thermal detector

LOCATION				FIRE PROTECTION							TYPE OF FIRE DETECTORS		
BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS		YARD HYDRANTS	
CONTROL	669.0	C1	MECHANICAL EQUIPMENT	1-1/2 HR.		X			X	X		I, RC	
		C2	MECHANICAL EQUIPMENT	1-1/2 HR.		X			X	X		I, RC	
		C3	250V BATTERY RM NO. 1	1-1/2 HR.		X			X	X		I, RC	
		C4	250V BATTERY BOARD RM NO. 1	1-1/2 HR.					X	X		I	
		C5	250V BATTERY BOARD RM NO. 2	1-1/2 HR.					X	X	X		I
		C6	250V BATTERY RM NO. 2	1-1/2 HR.			X			X	X		I, RC
		C7	24V & 48V BATTERY RM	1-1/2 HR.			X			X	X		I, RC
		C8	24V & 48V BAT. BD. & CHARGER RM	1-1/2 HR.						X	X		I
		C9	COMMUNICATIONS RM	1-1/2 HR.			X			X	X		I
		C10	MECHANICAL EQUIPMENT	1-1/2 HR.						X	X		I, RC
		C11	CORRIDOR	1-1/2 HR.			X			X	X		I
		C12	SECONDARY ALARM STATION	1-1/2 HR.			X			X	X		I
		C13	STAIR	1-1/2 HR.						X	X		
		C14	STAIR	1-1/2 HR.						X	X		
	C15	UNIT 1 AUX. INSTRUMENT RM	1-1/2 HR.	X				X	X	X			I, RC
	C16	CORRIDOR	1-1/2 HR.						X	X			I
	C17	COMPUTER RM	1-1/2 HR.	X				X	X	X			I, RC
	C18	UNIT 2 AUX. INSTRUMENT RM	1-1/2 HR.	X				X	X	X			I, RC
	C19	STAIR	1-1/2 HR.						X	X			
	C20	STAIR	1-1/2 HR.						X	X			
	C21	CHART STORAGE	1-1/2 HR. *			X		X	X	X			I
C22	SPREADING RM	1-1/2 HR. *	X		X		X	X	X			I	
C23	STAIR	1-1/2 HR.						X	X				
C24	STAIR	1-1/2 HR.						X	X				

85414

*3 hour separation maintained between fire area containing chart storage and spreading room and other plant areas.

POOR ORIGINAL

LOCATION			FIRE PROTECTION										
BUILDING	ELEV.	CCTV NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	FIXED			PORTABLE			TYPE OF FIRE DETECTORS	
						PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS		
CONTROL	732.0	C1	MECHANICAL EQUIPMENT RM	1-1/2 HR.		X	X***		X	X		I*	
		C2	JANITOR'S CLOSET	1-1/2 HR.		X			X	X		I	
		C3	CORRIDOR	1-1/2 HR.		X			X	X		I, RC	
		C4	KITCHEN	1-1/2 HR.		X			X	X		RC	
		C5	TOILET	1-1/2 HR.		X			X	X		I, RC	
		C6	LOCKER RM	1-1/2 HR.		X			X	X		I, RC	
		C7	SHOWER	1-1/2 HR.					X	X			
		C8	SHOWER	1-1/2 HR.					X	X			
		C9	INST. CALIB.	1-1/2 HR.			X			X	X		I, RC
		C10	SHIFT ENGR. OFFICE	1-1/2 HR.			X			X	X		I, RC
		C11	SHIFT ENGR. OFFICE	1-1/2 HR.			X			X	X		I, RC
		C12	MAIN CONTROL RM.	1-1/2 HR.						X	X		I**
		C13	RELAY RM	1-1/2 HR.						X	X		I
		C14	RECORD STORAGE	1-1/2 HR.			X			X	X		I, RC

*LOCATED IN FILTER DUCTWORK AND GENERAL AREA.
 **LOCATED IN CABINETS AND GENERAL AREA
 ***CLOSED HEAD SPRAY IN CHARCOAL FILTERS.

85413

POOR ORIGINAL

LOCATION				FIRE PROTECTION							
BUILDING	ELEV. NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PRECATION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS	TYPE OF FIRE DETECTORS
CONTROL	732.0	C15 CORRIDOR	1-1/2 HR.					X	X		I
		C16 P.S.O. ENGR. SHOP	1-1/2 HR.					X	X		I, RC
		C1 STAIR	1-1/2 HR.					X	X		
		C2 STAIR	1-1/2 HR.					X	X		

85413

POOR ORIGINAL

LOCATION				FIRE PROTECTION									
BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN HOZ/LE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS	TYPE OF FIRE DETECTORS	
AUXILIARY	551.0	A1	WASTE HOLDUP TANK						X	X			
		A2	WASTE EVAP FEED PUMP						X	X			
	553.0	A1	CORRIDOR							X	X		I
		A2	HOLDUP TANK ROOM A	1-1/2 HR.						X	X		
		A3	HOLDUP TANK ROOM B	1-1/2 HR.						X	X		
		A4	FLOOR DRAIN COLL PUMP & FILTER ROOM							X	X		
		A4/	FLOOR DRAIN COLL TANK ROOM							X	X		
		A5	GAS STRIPPER FEED PUMP							X	X		I
		A6	SUMP PUMP ROOM							X	X		I
		A7	SUMP TANK ROOM							X	X		
		A8	CONTAINMENT SPRAY 1B-B	1-1/2 HR.						X	X		I
		A9	CONTAINMENT SPRAY PUMP 1A-A	1-1/2 HR.						X	X		I
		A10	RHR PUMP ROOM 1B-B	1-1/2 HR.						X	X		I
		A11	RHR PUMP ROOM 1A-A	1-1/2 HR.						X	X		I
		A12	RHR PUMP ROOM 2A-A	1-1/2 HR.						X	X		I
		A13	RHR PUMP ROOM 2B-B	1-1/2 HR.						X	X		I
		A14	CONTAINMENT SP " " PUMP 2A-A	1-1/2 HR.						X	X		I
		A15	CONTAINMENT SPRAY PUMP 2B-B	1-1/2 HR.						X	X		I
		569.0	A16	PIPE GALLERY	1-1/2 HR.						X	X	
	A17		PIPE GALLERY	1-1/2 HR.						X	X		
A1	CORRIDOR				X				X	X		I	
85407	A2	VALVE GALLERY							X	X			
	A3	GAS DECAY ROOM							X	X			

POOR ORIGINAL

LOCATION					FIRE PROTECTION								
BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS	TYPE OF FIRE DETECTORS	
AUXILIARY	669.0	A4	CHEMICAL DRAIN TANK ROOM			X			X	X			
		A5	GAS DECAY ROOM						X	X			
		A6	AUX FEEDWATER PUMP 1A-A	1-1/2 HR.		X			X	X			I, RC
		A7	PIPE GALLERY	1-1/2 HR.		X			X	X			I
		A8	PIPE GALLERY & CHASE						X	X			
		A9	CHARGING PUMP 1A-A	1-1/2 HR.		X			X	X			I, RC
		A10	CHARGING PUMP 1B-B	1-1/2 HR.		X			X	X			I, RC
		A11	CHARGING PUMP 1C-C	1-1/2 HR.		X			X	X			I, RC
		A12	SAFETY INJECTION PUMP 1B-B	1-1/2 HR.		X			X	X			I, RC
		A13	SAFETY INJECTION PUMP 1A-A	1-1/2 HR.		X			X	X			I, RC
		A14	CASK DECONTN. COLL. TANK ROOM			X			X	X			I
		A15	SPENT RESIN TANK ROOM			X			X	X			I
		A16	VALVE GALLERY			X			X	X			
		A17	WASTE EVAP PACKAGE			X			X	X			I
		A18	AUX WASTE EVAP PACKAGE			X			X	X			I
		A19	SAFETY INJECTION PUMP 2A-A	1-1/2 HR.		X			X	X			I, RC
		A20	SAFETY INJECTION PUMP 2B-B	1-1/2 HR.		X			X	X			I, RC
		A21	CHARGING PUMP 2C-C	1-1/2 HR.		X			X	X			I, RC
		A22	CHARGING PUMP 2B-B	1-1/2 HR.		X			X	X			I, RC
		A23	CHARGING PUMP 2A-A	1-1/2 HR.		X			X	X			I, RC
		A24	PIPE GALLERY & CHASE						X	X			
		A25	PIPE GALLERY	1-1/2 HR.		X			X	X			I
		A26	AUX. FEEDWATER PUMP 2A-A	1-1/2 HR.		X			X	X			I, RC
		A27	CONCENTRATE FILTER						X	X			

85406

POOR ORIGINAL

BUILDING	ELEV.	LOCATION		COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	FIRE PROTECTION					TYPE OF FIRE DETECTORS	
		ROOM NO.	ROOM NAME			PREACTION SPRINKLER SYSTEM	OPEN ICGZALE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS		YARD HYDRANTS
AUXILIARY	690.0	A1	CONTROL AREA	1-1/2 HR.	X							
		A2	AIR LOCK	****		X			X	X		I
		A3	TITRATION ROOM	****		X			X	X		I
		A4	RADIO CHEM LAB.	****		X			X	X		I
		A5	COUNTING ROOM	****		X			X	X		I
		A6	PIPE GALLERY UNIT 1	1-1/2 HR.		X	X*		X	X		I
		A7	VOL CONTROL TANK ROOM	1-1/2 HR.		X			X	X		I**, PE***
		A8	REACTOR BLDG. ACCESS ROOM	3-HR.					X	X		I
		A9	VALVE GALLERY						X	X		
		A10	SEAL WATER HEAT EXCHANGER 1A						X	X		
		A11	HEAT EXCHANGERS 1B	1-1/2 HR.					X	X		
		A12	HEAT EXCHANGERS 1A	1-1/2 HR.					X	X		
		A13	SAMPLE ROOM I	1-1/2 HR.					X	X		
		A14	SAMPLE ROOM II	1-1/2 HR.		X			X	X		I
		A15	HEAT EXCHANGERS 2A	1-1/2 HR.		X			X	X		I
		A16	HEAT EXCHANGERS 2B	1-1/2 HR.					X	X		
		A17	SEAL WATER HEAT EXCHANGER 2A						X	X		
		A18	VALVE GALLERY						X	X		
		A19	PIPE GALLERY UNIT 2	1-1/2 HR.		X			X	X		
		A20	VOL CONTROL TANK ROOM	1-1/2 HR.		X			X	X		I
		A21	REACTOR BLDG. ACCESS RM.	3 HR.					X	X		I**, PE***

85405

*IN CHARCOAL FILTERS
 **LOCATED IN GENERAL AREA.
 ***LOCATED IN CHARCOAL FILTER DUCTS.
 ****LABORATORY COMPLEX SEPARATED FROM AUXILIARY BLDG BY A 3-HR. FIRE BARRIER.

POOR ORIGINAL

LOCATION				FIRE PROTECTION						TYPE OF FIRE DETECTORS				
BUILDING	ELEV.	SEC. NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	REACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARGON DIOXIDE SYSTEM	STANDPIPE SYSTEM		PORTABLE EXTINGUISHERS	YARD HYDRANTS		
TARY	690.0	A22	VALVE GALLERY						X	X				
		A23	CVCS VALVE GALLERY						X	X				
		A23	CVCS VALVE GALLERY							X	X			
		A2	VALVE GALLERY							X	X			
		A25	WASTE GAS COMP B							X	X			
		A26	WASTE GAS COMP A							X	X			
		A27	DECONTAMINATION ROOM					X			X	X		I
		A28	PIPE CHASE		1-1/2 HR.						X	X		
		A29	PIPE CHASE		1-1/2 HR.						X	X		
		A30	AIR LOCK								X	X		
		A31	WASTE GAS ANALYZER ROOM								X	X		
		706.0	A1	MAIN STEAM VALVE ROOM							X	X		
			A2	MAIN STEAM VALVE ROOM							X	X		
			A3	WASTE PACKAGE AREA		1-1/2 HR.			X		X	X		I
	A4		WASTE PACKAGE AREA					X		X	X		I	
	A5		CASK LOADING AREA		1-1/2 HR.			X		X	X		I	
	A6		N ₂ STORAGE AREA		1-1/2 HR.					X	X		I	
	705.0	A7	CASK DECON ROOM							X	X			
	706.0	A8	FUEL TRANSFER VALVE ROOM							X	X		I	
		A9	FUEL TRANSFER VALVE ROOM							X	X		I	
		A10	MAIN STEAM VALVE ROOM							X	X			
		A11	MAIN STEAM VALVE ROOM							X	X			
		A12	STEAM VALVE INST. ROOM A							X	X			
		A13	STEAM VALVE INST. ROOM B							X	X			
		A14	UHI EQUIP		1-1/2 HR.	X				X	X		I	
		A15	UHI EQUIP		1-1/2 HR.	X				X	X		I	

POOR ORIGINAL

LOCATION		FIRE PROTECTION							TYPE OF FIRE DETECTORS	
BUILDING	ELEV. NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PRECINCTOR SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM		PORTABLE EXTINGUISHER
AUXILIARY	714.0	A1 COMMON AREA	1-1/2 HR.	X	X			X	X	
		A2 HOT INSTRUMENT SHOP	1-1/2 HR.		X			X	X	
		A3 HGT. & VENT ROOM	1-1/2 HR.	X				X	X	
		A4 AIR LOCK						X	X	
		A5 VENT. & PURGE AIR ROOM	1-1/2 HR.	X				X*	X	
		A6 AIR LOCK						X	X	
		A7 LETDOWN HEAT EXCHANGER						X	X	
		A8 LETDOWN HEAT EXCHANGER						X	X	
		A9 VENT. & PURGE AIR ROOM	1-1/2 HR.	X				X*	X	
		A10 AIR LOCK						X	X	
		A11 AIR LOCK						X	X	
		A12 HTG. & VENT ROOM	1-1/2 HR.					X	X	
		A13 AIR LOCK						X	X	
		A14 AIR LOCK						X	X	
		A15 FUEL DETECTOR ROOM						X	X	
		A16 FUEL DETECTOR ROOM						X	X	

*CLOSED NOZZLE SPRAY SYSTEM LOCATED IN CHARCOAL FILTERS
 **LOCATED IN CHARCOAL FILTER DUCTS AND GENERAL AREA.
 ***LOCATED IN CHARCOAL FILTER DUCTS.

POOR ORIGINAL

BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	FIRE PROTECTION					TYPE OF FIRE DETECTORS	
						REACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS		YARD HYDRANTS
AUXILIARY	734.0	A1	AUXILIARY CONTROL ROOM	1-1/2 HR.	X	X			X	X		I
		A2	6.9 KV SHUTDOWN BD. ROOM A	1-1/2 HR.	X	X			X	X		I
		A3	125V VITAL BATT. BD. RM II	1-1/2 HR.	X	X****			X	X		I
		A4	125V VITAL BATT. BD. RM I	1-1/2 HR.	X	X****			X	X		I
		A5	480V SHUTDOWN BD. ROOM 1B2	1-1/2 HR.	X	X			X	X		I
		A6	480V SHUTDOWN BD. ROOM 1B1	1-1/2 HR.	X	X			X	X		I
		A7	480V SHUTDOWN BD. ROOM 1A1	1-1/2 HR.	X	X			X	X		I
		A8	480V SHUTDOWN BD. ROOM 1A2	1-1/2 HR.	X	X			X	X		I
		A9	PERSONNEL & EQUIP ACCESS	1-1/2 HR.	X	X			X	X		I
		A10	STEAM GEN. BLOWDOWN	1-1/2 HR.	X	X			X	X		I
		A11	REACTOR BLDG. EQUIP HATCH	3 HR.		X			X	X		I
		A12	REACTOR BLDG. ACCESS RM.	1-1/2 HR.	X	X			X	X		I
		A13	REFUELING ROOM	1-1/2 HR.					X	X		I
		A14	REACTOR BLDG. ACCESS RM.	1-1/2 HR.	X	X			X	X		I
		A15	REACTOR BLDG. EQUIP. HATCH	3 HR.		X			X	X		I
		A16	EMERGENCY GAS TREATMENT FILTER	1-1/2 HR.	X	X	X*		X	X		I
		A17	PERSONNEL & EQUIP. ACCESS	1-1/2 HR.	X	X			X	X		I***, PE****
		A18	480V SHUTDOWN BD. ROOM 2B2	1-1/2 HR.	X	X			X	X		I
		A19	480V SHUTDOWN BD. ROOM 2B1	1-1/2 HR.	X	X			X	X		I
		A20	480V SHUTDOWN BD. ROOM 2A1	1-1/2 HR.	X	X			X	X		I
		A21	480V SHUTDOWN BD. ROOM 2A2	1-1/2 HR.	X	X			X	X		I

*CLOSED NOZZLE SPRAY IN FILTER
 **LOCATED IN FILTER DUCTS AND GENERAL AREA
 ***LOCATED IN FILTER UNIT
 ****MANUAL ACTUATION

501386

POOR ORIGINAL

BUILDING	ELEV.	FLOOR NO.	LOCATION ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	FIRE PROTECTION					TYPE OF FIRE DETECTORS		
						PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS		YARD HYDRANTS	
AUXILIARY	734.0	A22	125V VITAL BATT BD. ROOM IV	1-1/2 HR.	X	X*			X	X		I	
		A23	125V VITAL BATT BD. ROOM III	1-1/2 HR.	X	X*			X	X		I	
		A24	6.9 KV SHUTDOWN BD. RM B	1-1/2 HR.	X	X			X	X		I	
		A25	AUX CONTROL INST. RM 1A	1-1/2 HR.	X	X			X	X		I	
		A26	AUX CONTROL INST. RM 1B	1-1/2 HR.	X	X			X	X		I	
		A27	AUX CONTROL INST. RM 2A	1-1/2 HR.	X	X			X	X		I	
		A28	AUX. CONTROL INST. RM 2B	1-1/2 HR.	X	X			X	X		I	
		749.0	A1	480V BOARD RM. 1A	1-1/2 HR.	X	X		X	X		I	
	A2		480V BOARD RM. 1B	1-1/2 HR.	X	X		X	X	X		I	
	A3		125V VITAL BATT. RM II	1-1/2 HR.		X*			X	X		I	
	A4		125V VITAL BATT. RM. I	1-1/2 HR.		X*			X	X		I	
	A6		480V TRANSFORMER RM 1B	1-1/2 HR.	X	X			X	X		I	
	A7		480V TRANSFORMER RM 1A	1-1/2 HR.	X	X			X	X		I	
	A8		MECH. EQUIPMENT RM.	1-1/2 HR.	X	X			X	X		I	
	A8A		HEPA FILTER PLENUM RM.	1-1/2 HR.		X			X	X		I	
	A9		MECH. EQUIPMENT ROOM	1-1/2 HR.	X	X			X	X		I	
	A9A		HEPA FILTER PLENUM RM.	1-1/2 HR.	X	X			X	X		I	
	A10		480V TRANSFORMER RM. 2B	1-1/2 HR.	X	X			X	X		I	
	A11		480V TRANSFORMER RM. 2A	1-1/2 HR.	X	X			X	X		I	
	A13		125V VITAL BATT. RM. IV	1-1/2 HR.		X*			X	X		I	
	A14		125V VITAL BATT. RM. III	1-1/2 HR.		X*			X	X		I	
	A15		480V BOARD RM. 2B	1-1/2 HR.	X	X			X	X		I	

501383

*MANUAL ACTUATION

POOR ORIGINAL

LOCATION				FIRE PROTECTION									
BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	FIRE					YARD HYDRANTS	TYPE OF DETECTORS	
						PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS			
AUXILIARY	749.0	A16	400V BOARD RM. 2A	1-1/2 HR.	X	X				X	X		I
	759.0	A1	CONTROL ROD DRIVE EQUIP. RM.	1-1/2 HR.	X	X			X	X			I
		A2	PRESSURE HTR. TRANSF. ROOM 1	1-1/2 HR.	X	X			X	X			I
		A3	CONTROL ROD DRIVE EQUIP RM	1-1/2 HR.	X	X			X	X			I
		A4	PRESSURE HTR. TRANSF ROOM 2	1-1/2 HR.	X	X			X	X			I
	763.0	A1	FAN ROOM*						X	X			I
		A2	ROOF ACCESS AIR LOCK	3 HR.					X	X			

*EXTENSION OF RM. 734.0-A13

87038

POOR ORIGINAL

LOCATION			FIRE PROTECTION									
BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHER	YARD HYDRANTS	TYPE OF FIRE DETECTORS
REACTOR			ANNULUS PRIMARY CONTAINMENT EQUIPMENT WITHIN PRIMARY CONTAINMENT REQUIRING FIRE PROTECTION AND/OR DETECTION	*	X	**			X	X		PE
			LOWER COMPARTMENT COOLER A-A	*								PE
			LOWER COMPARTMENT COOLER B-B	*								PE
			LOWER COMPARTMENT COOLER C-A	*								PE
			LOWER COMPARTMENT COOLER D-B	*								PE
			UPPER COMPARTMENT COOLER UNIT A	*								PE
			UPPER COMPARTMENT COOLER UNIT B	*								PE
			UPPER COMPARTMENT COOLER UNIT C	*								PE
			UPPER COMPARTMENT COOLER UNIT D	*								PE
			REACTOR COOLANT PUMP NO. 1	*			X			X	X	RC, IR
			REACTOR COOLANT PUMP NO. 2	*			X			X	X	RC, IR
			REACTOR COOLANT PUMP NO. 3	*			X			X	X	RC, IR
			REACTOR COOLANT PUMP NO. 4	*			X			X	X	RC, IR
		CABLE TRAYS				**			X	X		

*THE REACTOR BUILDING IS RATED AS A 3-HOUR FIRE AREA, WITH NO INTERNAL FIRE CELLS CONSIDERED
 **PREACTION SPRINKLER SYSTEM PROVIDED FOR DIVISIONAL CABLE TRAY INTERACTIONS ONLY

85417

POOR ORIGINAL

LOCATION			FIRE PROTECTION						TYPE OF FIRE DETECTORS
BUILDING	ELEV. NO.	ROOM NAME	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	HAZARD HYDRAULICS	
ADDITIONAL EQUIPMENT	706.5	STORAGE	X			X	X	I	
	740.5	EQUIPMENT WITHIN THIS FLOOR ELEVATION REQUIRING FIRE PROTECTION AND/OR DETECTION							
	A1	UHI EQUIP RM				X	X	I	
	A2	ICE BAY EQUIP RM				X	X	I	
	752.25 A1	ICE MACHINE EQUIP. RM				X	X	I	
	753.0 A1	ELEVATOR MACHINE RM				X	X	I	
763.5 A1	PACKAGE CHILLER EQUIP.				X	X	I		
*THE ADDITIONAL EQUIPMENT BUILDING IS RATED AS A 3-HOUR FIRE AREA WITH NO INTERNAL FIRE CELLS CONSIDERED.									

POOR ORIGINAL

LOCATION				FIRE PROTECTION										
BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS	TYPE OF FIRE DETECTORS		
DIESEL GEN.	722.0	1	CO ₂ STORAGE RM.	1-1/2 HR.					X	X				
		2	LUBE OIL STORAGE RM.	3 HR.				X	X	X		RC		
		3	TOILET							X	X			
		4	UNIT 1A-A	**					X	X	X		RC, I*	
		5	UNIT 2A-A	**					X	X	X		RC, I*	
		6	UNIT 1B-B	**					X	X	X		RC, I*	
		7	UNIT 2B-B	**					X	X	X		RC, I*	
		8	FUEL OIL TRANSFER RM.	1-1/2 HR.					X	X	X		RC	
		9	PIPE GALLERY & CORRIDOR	1-1/2 HR.			X			X	X		RC	
	740.5	D1	STAIR	3 HR.						X	X			
		1	CORRIDOR	3 HR.						X	X			
		2	RADIATION SHELTER RM.	1-1/2 HR.						X	X			
		3	AIR EXHAUST RM.	**						X	X		RC	
		4	480V BOARD RM. 1A	**					X	X	X		I, RC	
		5	AIR INTAKE RM.	**						X	X		RC	
		6	AIR EXHAUST RM.	**						X	X		RC	
		*LOCATED IN ELECTRICAL PANELS												
		** THREE-HOUR FIRE RATED CONSTRUCTION HAS BEEN MAINTAINED BETWEEN REDUNDANT DIESEL GENERATOR UNITS.												
85420														

POOR ORIGINAL

LOCATION				FIRE PROTECTION							TYPE OF FIRE DETECTORS		
BUILDING	ELEV.	NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STAGPIPE SYSTEM	PORTABLE EXTINGUISHERS		YARD HYDRANTS	
DIESEL GEN.	740.9	7	480V BOARD RM. 2A	**				X	X	X		I, RC	
		8	AIR INTAKE RM.	**					X	X		RC	
		9	AIR EXHAUST RM.	**						X	X		RC
		10	480V BOARD RM. 1B	**				X	X	X	X		I, RC
		11	AIR INTAKE RM.	**						X	X		RC
		12	AIR EXHAUST RM.	**						X	X		RC
		13	480V BOARD RM. 2B	**				X	X	X	X		I, RC
		14	AIR INTAKE RM.	**						X	X		RC
		D1	STAIR	3 HR.						X	X		

**THREE-HOUR FIRE RATED CONSTRUCTION HAS BEEN MAINTAINED BETWEEN REDUNDANT DIESEL GENERATOR UNITS.

85419

POOR ORIGINAL

LOCATION			FIRE PROTECTION						TYPE OF FIRE DETECTORS	
BUILDING	ELEV. (FT.)	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM		PORTABLE EXTINGUISHER
ERCW PUMPING STATION	625.0	ENTIRE ELEVATION	3 HR.					X	X	
	668.0	MECHANICAL EQUIP. RM 1A	*					X	X	
		MECHANICAL EQUIP. RM 2A	*					X	X	
		MECHANICAL EQUIP. RM B	*					X	X	
	704.0	ELEC. EQUIP. RM 1A	*					X	X	
		ELEC. EQUIP. RM 2A	*					X	X	
		ELEC. EQUIP. RM B	*					X	X	
	720.0	ENTIRE ELEVATION	*					X	X	
<p>*3-HOUR FIRE RATED CONSTRUCTION HAS BEEN MAINTAINED BETWEEN REDUNDANT EQUIPMENT. **DETECTORS WITH HEAT COLLECTORS PROVIDED ABOVE EACH ERCW PUMP.</p>										

85415

POOR ORIGINAL

LOCATION			FIRE PROTECTION									
BUILDING	ELEV.	COMP. NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTIC SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS	TYPE OF FIRE DETECTORS
INTAKE PUMPING STATION	658.0 -		ENTIRE ELEVATION						X	X		
	680.5 -		ENTIRE ELEVATION						X	X		
	690.0 -		ENTIRE ELEVATION						X	X		Y
	705.0 -		ENTIRE ELEVATION	*					X	X		RC**
			*3-HOUR COMPARTMENTATION PROVIDED FOR ERCW PUMP TRAINS. **DETECTORS WITH HEAT COLLECTORS PROVIDED ABOVE EACH ERCW PUMP.									

85416

POOR ORIGINAL

LOCATION				FIRE PROTECTION									
BUILDING	ELEV.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PREACTION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STAIRPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS	TYPE OF DETECTORS	
TURBINE	662.5		ENTIRE FLOOR	*					X	X		RC	
			No. 7 HEATER DRAIN PUMPS	*					X	X		RC	
			No. 3 HEATER DRAIN PUMPS	*						X	X		RC
			CONDENSATE BOOSTER PUMPS	*						X	X		RC
			HOTWELL PUMPS	*						X	X		RC
	685.0		CABLE INSULATION	*						X	X		RC
			ENTIRE FLOOR	*						X	X		RC
			CABLE INSULATION	*						X	X		RC
			ELEVATOR MACHINERY ROOM	1-1/2 HR.						X	X		RC
			PURIFICATION ROOM	1-1/2 HR.					X	X	X		RC
	690.0		DIRTY LUBE OIL TRANSFER PUMP	*						X	X		RC
			STATION AIR COMP.	*						X	X		RC
			ENTIRE FLOOR	*						X	X		RC
			FEEDWATER PUMP TURBINE	*				X		X	X		RC
			ENTIRE FLOOR	*						X	X		RC
	706.0		CABLE INSULATION	*						X	X		RC
			LUBE OIL DISPENSING ROOM	1-1/2 HR.				X		X	X		RC
			MAIN TURBINE LUBE OIL TANKS	*				X		X	X		RC
			TURBINE LUBE OIL COOLERS	*						X	X		RC
			ELECTRO-HYDRAULIC CONTROL PUMPS	*						X	X		RC
		MAIN OIL PUMPS AND PIPING	*						X	X		RC	
		HYDROGEN SEAL OIL UNIT	*				X		X	X		RC	
*THE TURBINE BUILDING IS ONE FIRE AREA WITH NO INTERNAL FIRE CELLS, EXCEPT THE LUBE OIL DISPENSING ROOM AND THE PURIFICATION ROOM.													

85412

POOR ORIGINAL

LOCATION			FIRE PROTECTION						FIRE DETECTORS			
BUILDING	ELEV. NO.	ROOM NO.	ROOM NAME	COMPARTMENT FIRE RATING	FIRE RETARDANT COATING OF EXPOSED CABLES	PRECATION SPRINKLER SYSTEM	OPEN NOZZLE SPRAY SYSTEM	CARBON DIOXIDE SYSTEM	STANDPIPE SYSTEM	PORTABLE EXTINGUISHERS	YARD HYDRANTS	TYPE OF FIRE DETECTORS
TURBINE	732.0		ENTIRE FLOOR TURBINE HEAD ENDS AUXILIARY BOILER	* * *			X X**		X X X	X X X		RC RC RC
			*THE TURBINE BUILDING IS ONE FIRE AREA WITH NO INTERNAL FIRE CELLS. ROOM. **CLOSED HEAD SPRAY SYSTEM OVER AUXILIARY BOILER.				EXCEPT THE LUBE OIL DISPENSING ROOM AND THE PURIFICATION					

85411

POOR ORIGINAL

TABLE 1.2

CIRCUITS TO BE RELOCATED FOR UNIT 1 OPERATION

<u>Cable or Conduit No.</u>	<u>Function</u>	<u>Resolution</u>
1PL4742B 1PL4743B	CCS Pump 1B-B Supply	Relocate conduit to provide minimum 20' separation from train A
2PL4742B 2PL4743B	CCS Pump 2B-B Supply	Relocate conduit to provide minimum 20' separation from train A
1PL4748B 2PL4748B	CCS Pump 1B-B Control CCS Pump 2B-B Control	Route in conduit from 480V S/D Brds. to pumps with 20' minimum separation from redundant train A circuits
1PL5025	Reciprocal Charging Pump Supply	Route in conduit from 480V S/D Brd. to pump with 20' minimum separation from redundant train A circuits
1PL5026	Reciprocal Charging Pump Control	Route in conduit from 480V S/D Brd. to pump with 20' minimum separation from redundant train A circuits
1PL3021 1PL3023	Reciprocal Charging Pump Room Cooler	Route in conduit from 480V vent Brd to Room Cooler with 20' minimum separation from redundant train A circuits
1PP800A 2PP800A	Pressurizer Heater Transformer Supplies	Route in conduit from cable trays AT-A and AS-A at elev 759.0 to elev 734.0 out of area containing train B circuits and back up to press. htrs. on elev 759.0.

TABLE 1.2 (Continued)
 CIRCUITS TO BE RELOCATED FOR UNIT 2 OPERATION

<u>Circuit No.</u>	<u>Function</u>	<u>Resolution</u>
2PL5025	Reciprocal Charging Pump Supply	Route in conduit from 480V S/D Brd. to pump with 20' minimum separation from redundant train A circuits.
2PL5026	Reciprocal Charging Pump Control	Route in conduit from 480V S/D Brd. to pump with 20' minimum separation from redundant train A circuits.
2PL3021	Reciprocal Charging Pump Room Cooler	Route in conduit from 480V vent Brd. to Room Cooler with 20' minimum separation from redundant train A circuits.

TABLE 1.3

CIRCUITS TO BE PROTECTED BY A 1/2 HOUR FIRE RATED BARRIER

The following conduits for unit 1 operation shall be wrapped in a 1-inch-thick B&W Kaolwool Blanket in the auxiliary building, from the reactor building containment penetrations at auxiliary building EL 734.0 to the control building Q-line wall penetrations at auxiliary building EL 714.0. These conduits are protected by an automatic sprinkler system.

<u>Conduit No.</u>	<u>Function</u>
1PM1001I	Pressurizer level and pressure indication, loops 2 and 3 steam generator instrumentation
1PM1002II	
1PM1003III	
1PM1004IV	
1PM1068I	
1PM850II	
1PM1066III	
1PM1065III	
1PM2142III	
1PM1067I	
1PM2128I	
1PM2111II	
1PM851II	
1PM2145IV	
1PM2080I	
1PM2084I	
1PM2132I	
1PM2136I	
1PM2087II	
1PM2091II	
1PM2104II	
1PM2121II	
1PM2118II	
1PM2107II	
1PM2094III	
1PM2098III	
1PM2100IV	
1PM2103IV	
1PM2124IV	

TABLE 1.3 (Continued)

CIRCUITS TO BE PROTECTED BY A 1/2 HOUR FIRE RATED BARRIER

The following conduits for unit 2 operation shall be wrapped in a 1-inch-thick B&W Kao wool Blanket in the auxiliary building, from the reactor building containment penetrations at auxiliary building E1 734.0 to the control building Q-line wall penetrations at auxiliary building E1 714.0. These conduits are protected by an automatic sprinkler system.


<u>Conduit No.</u>	<u>Function</u>
2PM1001I	Pressurizer level and pressure indication, loops 2 and 3 steam generator instrumentation 
2PM1002II	
2PM1003III	
2PM1004IV	
2PM2080I	
2PM2084I	
2PM2087II	
2PM2091II	
2PM2094III	
2PM2098III	
2PM2100IV	
2PM2103IV	
2PM2107II	
2PM2111II	
2PM2114II	
2PM2124IV	
2PM2128I	
2PM2136I	
2PM2142III	
2PM2145IV	

TABLE 1.4

CIRCUITS TO BE PROTECTED BY 1-1/2 HOUR FIRE RATED BARRIERS

The following conduits shall be enclosed by 1-1/2 hour fire rated barriers utilizing a UL-approved configuration from the junction box at UA1, auxiliary building EL 690.0 to UA6, auxiliary building EL 734.0, or to the point where the conduits transition to cable trays where 20-foot minimum separation between trains is achieved. These enclosures are protected by automatic sprinkler systems.



<u>Conduit No.</u>	<u>Function</u>
1PP780A	6900V Power Feed to ERCW 480V XFMR 1A-A
1PP785B	6900V Power Feed to ERCW 480V XFMR 1B-B
2PP780A	6900V Power Feed to ERCW 480V XFMR 2A-A
2PP785B	6900V Power Feed to ERCW 480V XFMR 2B-B
1PP712B	ERCW Pump N-B Supply
1PP700B	ERCW Pump C-B Supply
2PP700B	ERCW Pump M-B Supply
2PP712B	ERCW Pump F-B Supply
1PP675A	ERCW Pump A-A Supply
1PP687A	ERCW Pump Q-A Supply
2PP675A	ERCW K-A Supply
2PP687A	ERCW H-A Supply

TABLE 1.5

INTERACTIONS IDENTIFIED FOR COLD SHUTDOWN


<u>Interaction Location</u>	<u>Redundant Functions Lost</u>	<u>Cable Numbers</u>	<u>Fix Required in the Event of Fire Causing Loss of Redundancy</u>
Col. S,A3 El. 669.0			*Provide portable blower for room cooling
	Power to both RHR pump room coolers	1PL3041B 1PL3031A	
	Automatic and local control to both RHR pump room coolers	1PL3043B 1PL3033B	
Col U,A7 El. 669.0			
	Power to both RHR pump room coolers	1PL3041B 1PL3031A	
	Automatic and local control to both RHR pump room coolers	1PL3043B 1PL3033A	
Col. Q-S, A3-A8			*Provide portable blower for room cooling
	Automatic and local control for both RHR pump room air coolers	1PL3043B 1PL3033A	

*Attachment A to Emergency Operating Instruction EOI 10 has been written to define procedures for providing and placing into operation a portable blower for room cooling.





PLAN E. 653.0

POOR ORIGINAL



PLAN E.

POOR ORIGINAL



ROOM NO.	ROOM NAME	FLOOR	BASE	WALLS	CEILING	FINISH ELEV.	REMARKS
653-0-41	Waste Hold Up Tank	Conc	---	Conc	---	---	
653-0-42	Waste Emp Feed Pump	Conc	---	Conc	---	---	
653-0-41	Corridor	Conc	---	Conc	---	---	
653-0-42	Hold-Up Tank Rm A	Conc	---	Conc	---	---	
653-0-43	Hold-Up Tank Rm A	Conc	---	Conc	---	---	
653-0-44	Floor Drain Tank 4 Filter	Conc	---	Conc	---	---	
653-0-44	Floor Drain Tank Room	Conc	---	Conc	---	---	
653-0-45	Gas Stripper Feed Pump	Conc	---	Conc	---	---	
653-0-46	Pump Pump Room	Conc	---	Conc	---	---	
653-0-47	Waste Tank Room	Conc	---	Conc	---	---	
653-0-48	Containment Spray Pump 18-B	Conc	---	Conc	---	---	
653-0-49	Containment Spray Pump 18-A	Conc	---	Conc	---	---	
653-0-410	RHR Pump Rm 18-B	Conc	---	Conc	---	---	
653-0-411	RHR Pump Rm 18-A	Conc	---	Conc	---	---	
653-0-412	RHR Pump Rm 24-A	Conc	---	Conc	---	---	
653-0-413	RHR Pump Rm 24-B	Conc	---	Conc	---	---	
653-0-414	Containment Spray Pump 24-A	Conc	---	Conc	---	---	
653-0-415	Containment Spray Pump 24-B	Conc	---	Conc	---	---	
653-0-416	Pipe Gallery	Conc	---	Conc	---	---	
653-0-417	Pipe Gallery	Conc	---	Conc	---	---	
669-0-41	Corridor	---	---	Conc	---	---	
669-0-42	Waste Gallery	---	---	Conc	---	---	
669-0-43	Waste Tank Rm	---	---	Conc	---	---	
669-0-44	Chemical Drain Tank Rm	---	---	Conc	---	---	
669-0-45	Gas Delay Tank Rm	Conc	---	Conc	---	---	
669-0-46	Aux Feedwater Pump 18-A	---	---	Conc	---	---	
669-0-47	Pipe Gallery	---	---	Conc	---	---	
669-0-48	Pipe Gallery & Chase	---	---	Conc	---	---	
669-0-49	Charging Pump 18-A	---	---	Conc	---	---	
669-0-50	Charging Pump 18-B	---	---	Conc	---	---	
669-0-51	Charging Pump 18-C	---	---	Conc	---	---	
669-0-52	Safety Injection Pump 18-B	---	---	Conc	---	---	
669-0-53	Safety Injection Pump 18-A	---	---	Conc	---	---	
669-0-54	Cont. Dr. with Coll. Fe. Rm	---	---	Conc	---	---	
669-0-55	Spent Resin Tank Rm	---	---	Conc	---	---	
669-0-56	Waste Gallery	---	---	Conc	---	---	
669-0-57	Waste Emp Pump	---	---	Conc	---	---	
669-0-58	Aux. Waste Emp Packag.	---	---	Conc	---	---	
669-0-59	Safety Injection Pump 24-A	---	---	Conc	---	---	
669-0-60	Safety Injection Pump 24-B	---	---	Conc	---	---	
669-0-61	Charging Pump 24-C	---	---	Conc	---	---	
669-0-62	Charging Pump 24-B	---	---	Conc	---	---	
669-0-63	Charging Pump 24-A	---	---	Conc	---	---	
669-0-64	Pipe Gallery & Chase	---	---	Conc	---	---	
669-0-65	Pipe Gallery	---	---	Conc	---	---	
669-0-66	Aux Feedwater Pump 24-A	---	---	Conc	---	---	
669-0-67	Conc. Rate Filter	---	---	Conc	---	---	

- NOTES:
- 1/2 HR FIRE CELL BARRIER
 - 3 HR FIRE CELL BARRIER
 - DENOTES AREA OF INSIGNIFICANT FIRE LOAD (SAFETY RELATED OR NON SAFETY RELATED)
 - SAFETY RELATED.
 - NON SAFETY RELATED.



NOTE:
 3 THESE FIRE PROTECTION STUDY COMPARTMENTATION - FIRE CELL DRAWINGS ARE TO BE USED AS ENGINEERING AND COORDINATION STUDY DRAWINGS TO IMPLEMENT THE SEQUOYAH NUCLEAR PLANT SUPPLEMENTAL FIRE PROTECTION PROGRAM.
 4 ALL PENETRATIONS (ELEC AND MECH) INCLUDING DOORS AND FIRE DOOR DMPS THRU 3 HR RATED BARRIERS SHALL BE EQUIV. 3 HR RATED PENETRATIONS. ALL PENETRATIONS (ELEC AND MECH) INCLUDING DOORS AND DMPS THRU 1/2 HR RATED BARRIERS SHALL BE MINIMUM EQUIV. 1/2 HR RATED PENETRATIONS

1. THIS DWG. IDENTIFIES THE COMPARTMENTATION OF FIRE CELLS ONLY.
2. FOR ARCHITECTURAL DRAWING DETAILS REFER TO 46W401-4.


(COMPANION DWG - SK-1001 THRU SK-1003)

Scale 1/4" = 1'-0"


2	2121	REV. ELM. IN.	
BOUNDARIES UPDATED PER ECN			
3 18-12-77 (RDR) (CSP) (L) (L) - 1/2" = 1' - 0"			
REVISED NOTES			
REV. NO.	ECN NO.	DATE	DESCRIPTION
1			
DRAWN BY: G.B. HUSSEY		INSP: R.W. BURNETTE	
CHKD BY: J.C. LAY		EMITTED BY: James J. Hall	
COPY: J.W. FENDER			
POWERHOUSE AUXILIARY BLDG. UNITS 1 & 2			
FIRE PROTECTION STUDY COMPARTMENTATION - FIRE CELLS PLAN EL. 653.0 & 669.0			
SEQUOYAH NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN			
SUBMITTED: J.C. Lay		RECOMMENDED: R.W. Burnette	
APPROVED: R.W. Burnette			
KNOXVILLE	12-14-76	45	M SK-1001 R2
RECORD DRAWING AS CONSTRUCTED			



OR ORIGINAL



POOR ORIGINAL



KEY PLAN

ROOM FINISH SCHEDULE						
ROOM No	ROOM NAME	FLOOR	BASE	WALLS	SUSP. CLG. FINISH ELEV.	REMARKS
690.0-41	Spent Fuel Pit	Conc		Conc		
690.0-41	Auxiliary Building	Conc		Conc		
690.0-42	Air Lock	Conc		Conc		
690.0-43	Titration Room	Res tile	Vinyl tile	Conc	SF plus 699'-0"	46N452-3
690.0-44	Radiochemical Lab	Res tile	Vinyl tile	Conc	SF plus 699'-0"	46N452-3
690.0-45	Counting Room	Res tile	Vinyl tile	Conc	SF plus 698'-0"	46N452-3
690.0-46	Pipe Gallery	Conc		Conc		
690.0-47	Control Tank Room	Conc		Conc		
690.0-48	Reactor Bldg Access Rm	Conc		Conc		
690.0-49	Valve Gallery	Conc		Conc		
690.0-40	Seal Water Heat Exchgr A	Conc		Conc		
690.0-41	Heat Exchangers 1B	Conc		Conc		
690.0-42	Heat Exchangers 1A	Conc		Conc		
690.0-43	Sample Room I	Conc		Conc & Conc dia		46N405-10 & 46N452-6
690.0-44	Sample Room II	Conc		Conc dia		46N405-10 & 46N452-6
690.0-45	Heat Exchangers 2A	Conc		Conc		
690.0-46	Heat Exchangers 2B	Conc		Conc		
690.0-47	Seal Water Heat Exchgr 2A	Conc		Conc		
690.0-48	Valve Gallery	Conc		Conc		
690.0-49	Pipe Gallery	Conc		Conc		
690.0-40	Control Tank Room	Conc		Conc		
690.0-41	Reactor Bldg Access Rm	Conc		Conc		
690.0-42	Valve Gallery	Conc		Conc		
690.0-43	Valve Gallery	Conc		Conc		
690.0-44	W.C. & Lvs. Gallery	Conc		Conc		
690.0-45	W.C. & Lvs. Gallery	Conc		Conc		
690.0-46	W.C. & Lvs. Gallery	Conc		Conc		
690.0-47	White Gas Comp. A	Conc		Conc		
690.0-48	White Gas Comp. B	Conc		Conc		
690.0-49	White Gas Comp. C	Conc		Conc		
690.0-40	W.C. & Lvs. Gallery	Conc		Conc & Conc dia		46N405-3
690.0-41	Pipe Chase	Conc		Conc		
690.0-42	Pipe Chase	Conc		Conc		
690.0-43	Air Lock	Conc		Conc		
690.0-44	WASTE GAS ANALYZER RM	CONC		CONC	*STEEL GRD. @ 8" STL. DICK CLG. BY CIVIL	

NOTES:
 1. FOR CEILING AND WALL FINISH SCHEDULE REFER TO 46N401-5
 2. FOR ADDITIONAL NOTES SEE SHEET 1

2121	REVISION								
BOUNDARIES UPDATED PER ECN									
ESTABLISHED IRR RATING ON ALL WALLS									
ISSN	ECN NO.	DATE	DESIGNER	CHECKED	SUPV	ENGR	INSP	SUBMITTER	APPR
6900			G.R. WISEMAN						P. N. BUKHETIC
CHKD			G.R. WISEMAN						
SUPV			L. F. MURDER						J. W. MASH



POWERHOUSE
 AUXILIARY BLDG. UNITS 1&2



FIRE PROTECTION STUDY
 COMPARTMENTATION - FIRE CELLS
 PLAN EL. 685.0 & 690.0

SEQUOYAH NUCLEAR PLANT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF ENGINEERING DESIGN

SUBMITTED: J. W. MASH
 RECOMMENDED: J. C. FAY
 APPROVED: P. M. BUKHETIC

Scale: 1/8" = 1'-0"





ROOM FINISH SCHEDULE						
ROOM No	ROOM NAME	FLOOR	BASE	WALLS	CEILING	REMARKS
706-0-41	Main Steam Valve Room	Conc		Conc		
706-0-42	Main Steam Valve Room	Conc		Conc		
706-0-43	Water Package area	Conc		Conc		
706-0-44	Water Package area	Conc		Conc		
706-0-45	Water Cooling Area	Conc		Conc		
706-0-46	Na Storage Area	Conc		Conc		
706-0-47	Water Drain Room	Conc		Conc		
706-0-48	Water Drain - Walk-Rm	Conc		Conc		
706-0-49	Water Drain - Walk-Rm	Conc		Conc		
706-0-40	Main Steam Valve Room	Conc		Conc		
706-0-41	Main Steam Valve Room	Conc		Conc		
706-0-42	Steam Valve Instr Rm A	Conc		Conc		
706-0-43	Steam Valve Instr Rm B	Conc		Conc		
706-0-44	UHI Equip	Conc		Conc		
706-0-45	UHI Equip	Conc		Conc		
714-0-1	Auxiliary Building	Conc		Conc		
714-0-2	Hot Instrument shop	Res tile	Fac Tile	Res Tile		See note below 46N452-5
714-0-3	Htg & Vent	Conc		Conc		
714-0-4	Air Lock	Conc		Conc		
714-0-5	Air Lock	Conc		Conc		
714-0-6	Air Lock	Conc		Conc		46N405-4
714-0-7	Let Down Heat Exch	Conc		Conc		
714-0-8	Let Down Heat Exch	Conc		Conc		
714-0-9	Ventilator & Purg Air	Conc		Conc		
714-0-10	Air Lock	Conc		Conc		46N405-4
714-0-11	Air Lock	Conc		Conc		
714-0-12	Heating Stand	Conc		Conc		
714-0-13	Air Lock	Conc		Conc		
714-0-14	Air Lock	Conc		Conc		
714-0-15	Fuel Detector Rm	Conc		Conc		
714-0-16	Fuel Detector Rm	Conc		Conc		

NOTES
 1 FOR CEILING AND WALL FINISH SCHEDULE REFER TO 46N401-6
 2 FOR ADDITIONAL NOTES SEE SHEET 1

Scale 1/4" = 1'-0"

DESIGN	DATE	ISSUED	BY	CHKD	SUPV	ENGR	INSP	REVIEW	APPV
DRN									
CHKD									
SUPV									


POWERHOUSE
 AUXILIARY BLDG. UNITS 1 & 2



FIRE PROTECTION STUDY
 COMPARTMENTATION - FIRE CELLS
 PLAN EL. 706.0 & 714.0

SEQUOYAH NUCLEAR PLANT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF ENGINEERING DESIGN

SUBMITTED: *J.J. Nash* RECOMMENDED: *J.C. Key* APPROVED: *P.W. Burnett*

KNOXVILLE 12-14-76 45 M 4 SK-1003 RI





ROOM FINISH SCHEDULE						
ROOM No	ROOM NAME	FLOOR	BASE	HALLS	SUSPD CLG FINISH ELEV	REMARKS
734.0-A1	Auxiliary Control Room	Conc				46W405-G
734.0-A2	63KV Shtdn Bd Rm A	Conc				46W405-G
734.0-A3	25V Vital Batt Bd Rm II	Conc				46W405-G
734.0-A4	25V Vital Batt Bd Rm I	Conc				46W405-G
734.0-A5	480V Shtdn Bd Rm 1B2	Conc				46W405-G
734.0-A6	480V Shtdn Bd Rm 1B1	Conc				46W405-G
734.0-A7	480V Shtdn Bd Rm 1A1	Conc				46W405-G
734.0-A8	480V Shtdn Bd Rm 1A2	Conc				46W405-G
734.0-A9	Personnel & Equip Access	Conc		Conc		46W405-G
734.0-A10	Steam Gen Blowdown	Conc		Conc		
734.0-A11	Reactor Bldg Equip Hatch	Conc		Conc		
734.0-A12	Reactor Bldg Access Rm	Conc		Conc		
734.0-A13	Refueling Room	Conc		Conc		
734.0-A14	Reactor Bldg Access Rm	Conc		Conc		
734.0-A15	Reactor Bldg Equip Hatch	Conc		Conc		
734.0-A16	Emer Gas Treatment Filter	Conc		Conc		
734.0-A17	Personnel & Equip Access	Conc		Conc		46W405-5
734.0-A18	480V Shtdn Bd Rm 2B2	Conc		Conc & CONC BR		46W405-5
734.0-A19	480V Shtdn Bd Rm 2B1	Conc		Conc & CONC BR		46W405-5
734.0-A20	480V Shtdn Bd Rm 2A1	Conc		Conc & CONC BR		46W405-5
734.0-A21	480V Shtdn Bd Rm 2A2	Conc		Conc & CONC BR		46W405-5
734.0-A22	25V Vital Batt Bd Rm III	Conc		Conc & CONC BR		46W405-5
734.0-A23	25V Vital Batt Bd Rm III	Conc		Conc & CONC BR		46W405-5
734.0-A24	63KV Shtdn Bd Rm B	Conc		Conc & CONC BR		46W405-5
734.0-A25	Aux Control Inst Rm 1A	Conc		Conc & CONC BR		46W405-G
734.0-A26	Aux Control Inst Rm 1B	Conc		Conc & CONC BR		46W405-G
734.0-A27	Aux Control Inst Rm 2A	Conc		Conc & CONC BR		46W405-5
734.0-A28	Aux Control Inst Rm 2B	Conc		Conc & CONC BR		46W405-5
7405-A1	UHI Equipment Rm	Conc		Conc		
7405-A2	Ice Bin Equipment Rm	Conc		Conc		

- NOTES:
 1. FOR CEILING AND WALL FINISH SCHEDULE REFER TO 46W402-2
 2. FOR ADDITIONAL NOTES SEE SHEET 1



2	2121	46W405-5	BOUNDARIES UPDATED PER ECN
1	31	8-18-77	REVISOR: J. L. BROWN
REV	NO	DATE	DESCRIPTION
1	1	8-18-77	REVISOR: J. L. BROWN
2	2	8-18-77	REVISOR: J. L. BROWN
3	3	8-18-77	REVISOR: J. L. BROWN
4	4	8-18-77	REVISOR: J. L. BROWN
5	5	8-18-77	REVISOR: J. L. BROWN
6	6	8-18-77	REVISOR: J. L. BROWN
7	7	8-18-77	REVISOR: J. L. BROWN
8	8	8-18-77	REVISOR: J. L. BROWN
9	9	8-18-77	REVISOR: J. L. BROWN
10	10	8-18-77	REVISOR: J. L. BROWN

POWERHOUSE
 AUXILIARY BLDG UNITS 1 & 2
 FIRE PROTECTION STUDY
 COMPARTMENTATION - FIRE CELLS
 PLAN EL 732.0 & 734.0



SEQUOYAH NUCLEAR PLANT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF ENGINEERING DESIGN

SUBMITTED	RECOMMENDED	APPROVED
<i>J. L. Brown</i>	<i>J. L. Brown</i>	<i>R. M. Burnett</i>
KNOXVILLE 12/14/76	45 M	SK1004 82


Scale 1/8" = 1'-0"
 Except as noted




PLAN EL 749.0



PLAN EL 763.0



KEY PLAN





ROOM FINISH SCHEDULE						
ROOM No	ROOM NAME	FLOOR	BASE	WALLS	SUSPD CLG FINISH ELEV	REMARKS
749.0-A1	480V Board Rm 1A	Conc		Conc & Gypsum		46W405-9
749.0-A2	480V Board Rm 1B	Conc		Conc & Gypsum		46W405-9
749.0-A3	125V Vital Batt Rm II	Conc		Conc & Gypsum		46W405-8
749.0-A4	125V Vital Batt Rm I	Conc		Conc & Gypsum		46W405-8
749.0-A6	480V Transformer Rm 1B	Conc		Conc & Gypsum		46W405-8
749.0-A7	480V Transformer Rm 1A	Conc		Conc & Gypsum		46W405-8
749.0-A8	Mech Equipment Rm	Conc		Conc & Gypsum		46W405-8
749.0-A8A	HEPA Filter Plenum Rm	Conc		Conc & Gypsum		46W405-8
749.0-A9	Mech Equipment Rm	Conc		Conc & Gypsum		46W405-7
749.0-A9A	HEPA Filter Plenum Rm	Conc		Conc & Gypsum		46W405-7
749.0-A10	480V Transformer Rm 2B	Conc		Conc & Gypsum		46W405-7
749.0-A11	480V Transformer Rm 2A	Conc		Conc & Gypsum		46W405-7
749.0-A11	25V Vital Batt Rm III	Conc		Conc & Gypsum		46W405-7
749.0-A14	125V Vital Batt Rm III	Conc		Conc & Gypsum		46W405-7
749.0-A15	480V Board Rm 2B	Conc		Conc & Gypsum		46W405-7
749.0-A16	480V Board Rm 2A	Conc		Conc & Gypsum		46W405-7
752.25-A1	Ice Machine Equip Rm	Conc		Conc		
753.0-A1	Elevator Machine Rm	Conc		Conc		
759.0-A1	Control Rod Drive Equip Rm	Conc		Conc		
759.0-A2	Pressure Air Transf Rm	Conc		Conc		
759.0-A3	Control Rod Drive Equip Rm	Conc		Conc		
759.0-A4	Pressure Air Transf Rm	Conc		Conc		
763.0-A1	Fan Rooms	Conc		Conc		
763.0-A2	Roof Access Air Lock	Conc		Conc		
763.5-A1	Package chiller equip	Conc		Conc		
	STAIR No 7			Conc		46W405-4
	STAIR No 8			Conc		46W405-4
	STAIR No 9			Conc & Gypsum		46W405-4
	SPIRAL STAIR No 1			Conc & Gypsum		46W405-4
	SPIRAL STAIR No 2			Conc & Gypsum		46W405-4
	SPIRAL STAIR No 3			Conc & Gypsum		46W405-4


NOTES:
 1. FOR CEILING AND WALL FINISH SCHEDULE REFER TO 46W401-8.
 2. FOR ADDITIONAL NOTES SEE SHEET 1.

I. 200		WITH SCHEDULE	
BOUNDARIES UPDATED PER ECA			
REV	ECN NO	DATE	ISSN/OPEN/CHG/SUPP/ENGR/NEP/SUBM/REC/APPV
001			
DESIGN	G.R. WIREMAN		INSP. P.W. BURNETTE
DRAWN	L.F. DEARE		
CHECKED	L.F. DEARE		ENGINEER
SUPV	L.F. DEARE		
POWERHOUSE AUXILIARY BLDG. UNIT 1 & 2			
FIRE PROTECTION STUDY COMPARTMENTATION - FIRE CELLS PLAN EL. 749.0, 759.0 & 763.0			
SEQUOYAH NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN			
SUBMITTED	RECOMMENDED	APPROVED	
<i>J. H. H. H.</i>	<i>J. C. Key</i>	<i>R. M. Burch</i>	
KNOXVILLE	12-14-76	45 M 4 SK-1005	RI



Scale: 1/4" = 1'-0"



ROOM NO.	NAME OF ROOM	FLOOR	BASE	WALLS	SUSPD CLG		REMARKS	ROOM NO	NAME OF ROOM	FLOOR	BASE	WALLS
					FINISH	ELEV						
669.0-C1	Mechanical Eqpt	Conc	---	Conc	---	---	---	685.0-C1	Unit 1 Auxiliary Inst Rm	Conc	---	Conc & Conc blk
669.0-C2	Mechanical Eqpt	Conc	---	Conc	---	---	---	685.0-C2	Corridor	Conc	---	Conc & Conc blk
669.0-C3	Battery Room	Conc	---	Conc	---	---	---	685.0-C3	Computer Room	Res tile	Vinyl	Conc & Conc blk
669.0-C4	250v Battery Rm No 1	Conc	---	Conc	---	---	---	685.0-C4	Unit 2 Auxiliary Inst Rm	Conc	---	Conc & Conc blk
669.0-C5	250v Battery Bd Rm No 2	Conc	---	Conc	---	---	---	C1	Stair	Conc	---	Conc & Conc blk
669.0-C6	250v Battery Rm No 2	Conc	---	Conc	---	---	---	C2	Stair	Conc	---	Conc & Conc blk
669.0-C7	24v & 48v Battery Rm	Conc	---	Conc	---	---	---					
669.0-C8	24v & 48v Bat Bd & Chgr Rm	Conc	---	Conc	---	---	---					
669.0-C9	Communications Rm	Res tile	Vinyl	Conc	---	---	---					
669.0-C10	Mechanical Eqpt	Conc	---	Conc	---	---	---					
669.0-C11	Corridor	Conc	---	Conc	---	---	---					
C1	Stair	Conc	---	Conc	---	---	---					
C2	Stair	Conc	---	Conc	---	---	---					
669.0-C12	SBC ALARM STA	Conc	---	Conc	---	---	---					




PLAN-EL. 685.0



PLAN-EL. 669.0

NOTES
 1 FOR CEILING AND WALL FINISH SCHEDULE REFER TO 46W402-1
 2 FOR ADDITIONAL NOTES SEE SHEET 1


SUSP. CLG. FINISH	ELEV.	REMARKS
187/MS	655.5	
		CAT FLOOR TRASH
		CAT FLOOR TRASH
		STAIRWELL




KEY PLAN

Scale 1/4" = 1'-0"
 Except as noted

2	2/21	46W 404-7
BOUNDARIES UPDATED FOR ECN		
18-12 THIRD FLOOR/UNIT 1 & 2 - WITH 21 REV		
REVISED NON-SAFETY RELATED AREAS		
REV. NO.	ECN NO.	DATE
DESIGN	W. S. WISEMAN	INSPECTOR
DRAWN	J. C. BURDETTE	
CHECKED	J. C. BURDETTE	
COPY	J. A. L. G. O. C. A.	
POWERHOUSE CONTROL BLDG. UNIT 1 & 2		
FIRE PROTECTION STUDY COMPARTMENTATION-FIRE CELLS		
PLAN EL. 669.0 & 685.0		
SEQUOYAH NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN		
SUBMITTED	REVISIONS	APPROVED
J. A. L. G. O. C. A.	J. C. BURDETTE	R. M. BURDETTE



PLAN EL 732 0
(46W 404-7)
B7




PLAN EL 706 0
B7


SECTION B2-B2
Scale 3/16"

SECTION A2-A2
Scale 3/16"

ROOM FINISH SCHEDULE												
ROOM NUMBER	NAME OF ROOM	FLOOR	BASE	WALLS	SUSP. CLG FINISH	ELEV.	REMARKS	ROOM NUMBER	NAME OF ROOM	FLOOR	BASE	WALLS
706 0-C1	Spreading Room	Rest tile	Vinyl	Conc	SF plus	715'-0"		732 0-C8	Shower	Cer T	Cer T	Cer T
706 0-C2	Spreading Room	Conc	—	Conc	—	—		732 0-C9	Inst Cab	Res tile	Vinyl	Conc
C1	Stair	Conc	—	Conc	—	—	cast iron tread & nosing	732 0-C10	Ship's Eng. OFF.	Res tile	Vinyl	Conc
C2	Stair	Conc	—	Conc	—	—	cast iron tread & nosing	732 0-C11	Ship's Eng. Office	Res tile	Vinyl	Conc
732 0-C1	Mechanical Eqp Room	Conc	—	Conc	—	—		732 0-C12	Main Control Room	Res tile	Vinyl	Conc
732 0-C2	Janitors Closet	Res tile	Vinyl	Conc	—	—		732 0-C13	Relay Room	Res tile	Vinyl	Conc
732 0-C3	Corridor	Res tile	Vinyl	Conc	SF plus	740'-0"		732 0-C14	Record Storage	—	—	Conc
732 0-C4	Kitchen	Res tile	Vinyl	Conc	SF plus	740'-0"	See dg wall	C1	Stair	Conc	—	Conc
732 0-C5	Toilet	Cer T	Facing T	Conc	SF plus	740'-0"	See dg wall	C2	Stair	Conc	—	Conc
732 0-C6	Locker Room	Cer T	Facing T	Facing T	Cem. plus	740'-0"	See dg wall	732 0-C15	CORRIDOR	Res tile	Vinyl	Conc
732 0-C7	Shower	Cer T	Cer T	Cer T	Cem. plus	740'-0"	See dg wall	732 0-C16	P.S.O. Engr Shop	Res tile	Vinyl	Plas



NO.	DESCRIPTION	REMARKS
1	FINISH	See 46W411
2	3 F. pias	See 46W411
3	5 F. pias	See 46W411
4	Acct pias	See 46W411
5	Acct pias	See 46W411
6	Acct pias	See 46W411
7	Acct pias	See 46W411
8	Acct pias	See 46W411
9	Acct pias	See 46W411
10	Acct pias	See 46W411



NOTES:
 1. FOR CEILING AND WALL FINISH SCHEDULE REFER TO 46W402-2
 2. FOR ADDITIONAL NOTES SEE SHEET 1

REV. NO.	DATE	DESCRIPTION	BY	CHKD	APP'D
1	12-17-77	BOUNDARIES UPDATED PER ECN	J. H. KIM	J. H. KIM	
2	12-17-77	REVISED NON-SAFETY RELAY'S AREA	J. H. KIM	J. H. KIM	


POWERHOUSE
 CONTROL BLDG UNIT 1 & 2
 FIRE PROTECTION STUDY
 COMPARTMENTATION-FIRE CELLS
 PLANEL. 7060 & 7320

SEQUOYAH NUCLEAR PLANT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF ENGINEERING DESIGN


SUBMITTED: *J. H. Kim*
 DESIGNED BY: *J. C. Key*
 CHECKED BY: *J. H. Kim*
 APPROVED BY: *J. H. Kim*

Scale 1/4" = 1'-0"
 Except as noted

Assumed North




PLAN - EL. 722.0




SECTION A2-A2 Scale 1/4" = 1'-0"


B2-B2 Scale 1/4" = 1'-0"



PLAN ROOM 722.0-3 Scale 1/4" = 1'-0"



PLAN ROOM 722.0-8 Scale 1/4" = 1'-0"



PLAN - EL 740.5

ROOM FINISH SCHEDULE						
ROOM NO.	NAME OF ROOM	FLOOR	BASE	WALLS	SUSPD CLG FINISH ELEV.	REMARKS
722.0-1	CO ₂ Storage	Conc	---	Conc	---	
722.0-2	Lube Oil Storage	Conc	---	Conc	---	
722.0-3	Toilet	Conc	---	Conc	---	
722.0-4	Unit 1A-A	Conc	---	Conc	---	
722.0-5	Unit 2A-A	Conc	---	Conc	---	
722.0-6	Unit 1B-B	Conc	---	Conc	---	
722.0-7	Unit 2B-B	Conc	---	Conc	---	
722.0-8	Fuel Oil Transfer Room	Conc	---	Conc	---	
722.0-9	Pipe Gallery & Corridor	Conc	---	Conc	---	
D1	Stair	Conc	---	Conc	---	
740.5-1	Corridor	Conc	---	Conc	---	
740.5-2	Radiation Shelter	Conc	---	Conc	---	
740.5-3	Air Exhaust Room	Conc	---	Conc	---	
740.5-4	480V Board Room 1A	Conc	---	Conc	---	
740.5-5	Air Intake Room	Conc	---	Conc	---	
740.5-6	Air Exhaust Room	Conc	---	Conc	---	
740.5-7	480V Board Room 2A	Conc	---	Conc	---	
740.5-8	Air Intake Room	Conc	---	Conc	---	
740.5-9	Air Exhaust Room	Conc	---	Conc	---	
740.5-10	480V Board Room 1B	Conc	---	Conc	---	
740.5-11	Air Intake Room	Conc	---	Conc	---	
740.5-12	Air Exhaust Room	Conc	---	Conc	---	
740.5-13	480V Board Room 2B	Conc	---	Conc	---	
740.5-14	Air Intake Room	Conc	---	Conc	---	
D1	Stair	Conc	---	Conc	---	

NOTES
 1. FOR CEILING AND WALL FINISH SCHEDULE REFER TO 46W418-2
 2. FOR ADDITIONAL NOTES SEE SHEET 1.

DESIGNER	G. R. WISEMAN	INSP	P. W. BURNETTE
DRWN	J. E. DEASE	ENGR	J. L. FENDLER
CHKD	J. L. FENDLER	ENGR	J. L. FENDLER
SUPV	J. L. FENDLER		



POWERHOUSE
 DIESEL GENERATOR BUILDING

FIRE PROTECTION STUDY
 COMPARTMENTATION - FIRE CELLS
 PLAN EL. 722.0 & 740.5


SEQUOYAH NUCLEAR PLANT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF ENGINEERING DESIGN

SUBMITTED	REVISIONS	APPROVED
J. L. Fendler	J. L. Fendler	P. W. Burnette
KNOXVILLE	12-7-76	45 M 4 SK-1008

SCALE 1/8" = 1'-0"
 EXCEPT AS NOTED



PLAN EL 688.0 AND ABOVE



PLAN EL 625.0 AND ABOVE
NTS



SCALE: 1/4" = 1'-0"

COMPANION DWGS.

SEE SHEET 1.


REV NO	ECN NO.	DATE	ISSN	DNWN	CHKD	SUPV	ENGR	INSP	SUBM	REC'D	APP'D	FILED
1												
BOUNDARIES UPDATED PER ECN												
DESIGN	J. G. GARDNER										INSP	P. W. BURNETT
CHKD	J. G. GARDNER										ENGINEER	J. G. GARDNER
SUPV	J. G. GARDNER											

WATER SUPPLY UNITS 1&2
ERCW PUMPING STATION


FIRE PROTECTION STUDY
COMPARTMENTATION-FIRE CELLS
PLAN EL. 625.0 & 688.0


SEQUOYAH NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

SUBMITTED: J. G. Gardner
RECOMMENDED: J. G. Gardner
APPROVED: P. W. Burnett




1 2 3 4 5 6





KEY PLAN
SCALE 1"=30.0'



PLAN EL 704.0

- NOTES
1. FOR CEILING AND WALL FINISH SCHEDULE REFER TO 37M201-1.
 2. FOR ADDITIONAL NOTES SEE SHEET 1.



SCALE 1/8"=1'-0"


REV	DATE	BY	CHKD	APPD	REASON
1					BOUNDARIES UPDATED PER ECR
DESIGN	G. S. SWEETMAN			R. W. BURNETTE	
DRAWN	J. L. FENDER			ENGINEER	
SUPV	J. L. FENDER			J. J. Neel	

WATER SUPPLY UNIT 182
ERCW PUMPING STATION


FIRE PROTECTION STUDY
COMPARTMENTATION - FIRE CELLS
PLAN EL. 704.0 & 720.0

SEQUOYAH NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN



INSPECTED AND APPROVED FOR ISSUE	SUBMITTED	RECOMMENDED	APPROVED
	J. L. Fender	J. J. Neel	R. W. Burnette



PLAN E1 7




PLAN E1



KEY PLAN
Scale 1" = 200'

SPECIAL NOTE
THOSE AREAS PERTAINING TO THE ERCW PUMPS SHALL BE DESIGNATED SAFETY RELATED ONLY, DURING THAT INTERING PERIOD OF ERCW UNIT ONE OPERATION B PRIOR TO UNIT TWO OPERATION AFTER THIS PERIOD THIS PUMPING STATION SHALL BE DESIGNATED NON-SAFETY RELATED FOR ERCW PUMPING STATION SEE DRWSS SK1009-1010.



SCALE 1/8" = 1'-0"

COMPANION DRAWING S. 1001

REV	DATE	DESCRIPTION	BY	CHKD	APPD
1					
2					
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					
16					
17					
18					
19					
20					
21					
22					
23					
24					
25					
26					
27					
28					
29					
30					
31					
32					
33					
34					
35					
36					
37					
38					
39					
40					
41					
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52					
53					
54					
55					
56					
57					
58					
59					
60					
61					
62					
63					
64					
65					
66					
67					
68					
69					
70					
71					
72					
73					
74					
75					
76					
77					
78					
79					
80					
81					
82					
83					
84					
85					
86					
87					
88					
89					
90					
91					
92					
93					
94					
95					
96					
97					
98					
99					
100					

WATER SUPPLY UNITS 1 & 2
PUMPING STATION


FIRE PROTECTION STUDY
COMPARTMENTATION FIRE CELLS
PLAN EL 690.0 & 705.0

SEQUOYAH NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN


SUBMITTED: [Signature]
RECOMMENDED: [Signature]
APPROVED: [Signature]

KNOXVILLE 12/4/72 45 M 4 SK 1011 RI

AZ ↙




Trash racks
 PLAN BELOW EI 680.5
 AZ ↙




Notes
 A Added fire protection service
 symbols ECN 1288
 Minor Revisions ECN 5-1

Trash racks
 PLAN BELOW EI 658.0
 AZ ↙

ERCW pump wells
Sump pumps
MH



CCW pump
Fire pump wells
Screen wash pump wells
Traveling water screens



ELEVATION A2-A2

SPECIAL NOTE:
THOSE AREAS PERTAINING TO THE ERCW PUMPS SHALL BE DESIGNATED SAFETY RELATED ONLY DURING THAT INTERIM PERIOD OF ERCW UNIT ONE OPERATION & PRIOR TO UNIT TWO OPERATION - AFTER THIS PERIOD THIS PUMPING STATION SHALL BE DESIGNATED NON-SAFETY RELATED. FOR ERCW PUMPING STATION SEE DRWS. X1009-1010

CCW pump
Fire pump wells
Screen wash pump wells
Traveling water screens

SCALE 1/4" = 1'-0"

COMPANION DRAWING - SK1001

E-21		BOUNDARIES UPDATED PER ECR									
NO.	ECN NO.	DATE	DESIGN	DRWN	CHKD	SUPV	ENGR	INSP	REVIEW	APPR	
DESIGN	G.R. WISEMAN						INSP. R.W. BURNETTE				
DRWN	S. SALHOUN						ENGINEER				
CHKD	L. PENNINGTON						APPROVED				
SUPV	L. PENNINGTON						[Signature]				
WATER SUPPLY UNITS 1 & 2 PUMPING STATION											
FIRE PROTECTION STUDY COMPARTMENTATION - FIRE CELLS PLAN EL. 658.0 & 680.5											
SEQUOYAH NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN											
SUBMITTED			RECOMMENDED			APPROVED					
[Signature]			[Signature]			[Signature]					

2. Item B - Administrative Procedures, Controls, and Fire Brigade -
You plan to use administrative procedures, controls, and fire brigade programs previously accepted by the staff for the return to service of Browns Ferry, Units Nos. 1 and 2. We request that you review these procedures against the staff supplemental guidance contained in "Nuclear Plant Fire Protection Function Responsibilities, Administrative Controls, and Quality Assurance," dated June 14, 1977. It is our position that you either (1) confirm that your existing administrative procedures and fire brigade program meet the staff supplement guidelines, or (2) provide a commitment that they will be revised accordingly.

TVA Response

We are presently reviewing our administrative procedures, controls, and fire brigade programs against the staff supplemental guidance contained in "Nuclear Plant Fire Protection Function Responsibilities, Administrative Controls, and Quality Assurance," dated June 14, 1977. We plan to revise these procedures accordingly.

3. Item D, General Guidelines for Plant Protection

- A. You state that the majority of the materials used will conform to NFPA definitions of noncombustible or limited combustible material. During our site visit, we noted that some materials such as ventilation duct insulation were not UL listed or FM approved. Therefore, modify your fire hazard analysis to include the limited combustibles or show that these materials will meet the criteria of Section C.4.a(4), BTP ASB 9.5-1, Revision 1.
- B. For the following listed items substantiate their fire resistance capabilities as they pertain to safety-related areas or high hazard areas by verifying that their construction will be in accordance with a particular fire tested design. Identify the design, test method, and acceptance criteria.
- (i) Rated fire barriers including floor, ceiling, wall systems, structural members and doors. Indicate the type of protective material used and the design number in reference to ASTM E-119.
 - (ii) Fire dampers and fire doors, including the installation of the same in ventilating ducts penetrating fire barriers of safety related areas; fire door dampers are required in a 3 hr. rated fire barrier penetration.
 - (iii) Fire barrier penetration seals around ducts, pipes, cables, cable trays, and conduit or any other openings. Verify that the seals will meet the 3 hr. requirements for ASTM E-119. Verify that the inplant cable tray supports are similar to the ones used in the fire tests and that, in case of collapse of the trays, the resultant unsupported load and torque on the penetration seal will not affect the integrity of the seal.
- C. It is our position that where the fire loadings exceed a 1-1/2 hr. duration (see Table 6-8A, Fire Protection Handbook) and thus, exposes safety related conduit-cables or equipment that such barriers be upgraded to a 3 hr. fire resistance. Confirm that your design will meet this position.
- D. You have not responded to the Appendix A guidelines concerning fire doors being locked and alarmed. Confirm that you will meet this position. In particular, all fire doors used to protect openings in the wall separating the control building from the turbine building be alarmed and annunciated in the control room. These circuits should be electrically supervised.

TVA Response

- A. The duct insulation installed in safety-related plant areas has been tested by Underwriters Laboratories and has a flame spread rating of 25 and smoke developed rating of 50. TVA did not require the manufacturer to label the duct insulation.

- B. (i) Compartmentation will be provided in accordance with the SK-1000 series compartmentation drawings. These drawings indicate the boundaries where fire-resistive construction and assemblies will be utilized to maintain the integrity of fire areas and fire cells. Additional information is provided in Table 1-1 showing the minimum fire resistive rating of the most limiting structural components in each area or cell.

A minimum three-hour fire resistive rating has been assigned to the construction between the following buildings:

Reactor Building and Auxiliary Building
Control Building and Auxiliary Building
Service Building and Auxiliary Building
Control Building and Turbine Building

The three-hour and 1-1/2-hour rated construction consists of reinforced concrete, reinforced concrete block, or metal lath and plaster. Construction ratings are assigned based on the equivalency to similar construction denoted by Figure 6-7H of the NFPA Fire Protection Handbook and/or Data Sheet 1-21, Table 2, of Factory Mutual Loss Prevention Data for reinforced concrete and reinforced concrete block walls; and Data Sheet 1-21, Table 4, of Factory Mutual Loss Prevention Data for plaster partitions.

A minimum three-hour fire rated coating of Pyrocrete 102 is applied to all exposed structural steel within the cable spreading room. Applications are in accordance with UL Design No. X-716 and Code approved design based on Design D-717 (BOCA R.R. 73-42-I-C-1-b).

UL-labeled fire door assemblies are provided in opening in most fire cell and fire area boundaries. The assemblies are tested in accordance with UL Standard 10B and have a fire resistance rating at least equivalent to the designated rating of the boundary. The nonlabeled boundary doors are listed in Tables 3.B.(i)-1, 3.B.(i)-2, and 3.B.(i)-3. These doors are identified by number in the SK-1000 series compartmentation drawings.

Table 3.B.(i)-1 lists Auxiliary Building special purpose doors which are designed to ASME standards and are of heavy welded steel construction. The doors have multiple side hinges and multiple latch points on the sides, top and bottom. TVA has evaluated these doors and determined that they provide an equivalent fire rating commensurate to the fuel loading in the areas or cells they separate.

Table 3.B.(i)-2 lists the security doors in the Main Control Room. The doors are made of bullet-resistant, heavy gauge steel and have not been tested by UL. However, the door manufacturer has certified that the doors are equivalent to UL tested fire doors rated for three hours.

Table 3.B.(i)-3 lists Auxiliary Building fire-rated door assemblies which will be added in fire wall openings presently containing nonrated doors or no doors.

- B. (ii) Fire dampers or fire doors will be provided in ventilation ducts when the ducts penetrate fire barriers. The fire dampers/doors will have a fire resistance rating equivalent to the designated rating of the installed barrier as identified on the SK-1000 series compartmentation drawings.

Fire damper/doors provided after the submission of TVA's Fire Protection Program Reevaluation (forwarded to the NRC by letter from J. E. Gilleland to R. S. Boyd dated January 24, 1977) are UL listed and tested in accordance with UL Standards 10B or 555.

Fire dampers procured and installed prior to the submission of TVA's Fire Protection Program Reevaluation are not UL labeled. These dampers are listed in Tables 3.B.(ii)-1 and 3.B.(ii)-2.

The nonlabeled fire dampers identified in Table 3.B.(ii)-1 conform to the standards of the National Fire Protection Association that existed when the dampers were procured. These fire dampers have since been certified by the manufacturer to be equivalent to their presently manufactured UL-listed and labeled models. The location of these dampers is shown on flow diagrams 47W866-2, -3, -4, and -11.

The fire dampers identified in Table 3.B.(ii)-2 are non-labeled fire dampers procured under identical specifications as the fire dampers in Table 3.B.(ii)-1, but provided by a different manufacturer. These fire dampers comply with the 1966-1967 requirements of NFPA No. 90A. A detailed comparison of construction features of these dampers with the certified dampers identified in Table 3.B.(ii)-1 is presented in Table 3.B.(ii)-4. Construction features such as the frame design, blade dimensions, blade shaft and bearings, linkage, and materials compare favorably. Therefore, TVA feels that the dampers identified in Table 3.B.(ii)-2 are adequate in their installed configuration to provide the required compartmentation. The location of these dampers is shown on flow diagrams 47W866-2, -3, -4, and -11.

Table 3.B.(ii)-3 lists fire dampers which will be added in ventilation ducts penetrating fire barriers presently containing nonrated dampers or no dampers. The location of these dampers is shown on flow diagrams 47W866-2, -3, -4, -8, -9, and -11.

As a result of NRC concerns raised during the Sequoyah Nuclear Plant Fire Protection Review Meeting of February 12, 1979, additional fire dampers shall be installed in ventilation ducts penetrating the unit 1 auxiliary instrument room in C.B. and the refueling purification filter rooms in the auxiliary building. The installation schedule is indicated in the SCHEDULE FOR COMMITMENTS.

None of the fire dampers or fire doors have been installed in ventilation ducts in strict compliance with UL 555 or manufacturer's instructions. TVA discussed the installation details for these dampers/doors with the NRC Staff on February 12, 1979. It was agreed that the installation details meet the intent of UL 555 with one exception. TVA has installed two dampers, PCO-39-17A and O-31A-148, in ventilation ducts immediately below fire rated ceilings. Each damper will be enclosed in a 1-1/2-hour fire rated barrier that will extend around the ventilation duct to the ceiling.

- B. (iii) The design of the Sequoyah electrical penetration fire stops (EPFS) for cables and cable trays and their installation are based on TVA tests of full-scale mockups that must seal against air pressure. The tested design was modified to provide a greater depth of sealant material to give protection equivalent to a 3-hour fire resistance rating. The modification was based on a similar design, using the same type of cables and sealant material, and tests conducted by others to the standard time-temperature curve of ASTM E-119.

The design of the wall and floor electrical penetration fire stops through a fire barrier utilize a separate cable sleeve or slot for each cable tray. The design and installation of these penetration fire stops employ Dow Corning 3-6548 silicone RTV (room temperature vulcanizing) foam as the sealant material and inorganic fire barrier materials. From each side of the wall or floor opening, the cables are separated within the cable sleeve or slot using an inorganic fiber. The sealant material is then installed within the cable sleeve or slot. The cable sleeve opening is covered with a fire barrier board that is cut to fit around the cables and cable tray configuration.

In addition, the exposed surfaces of cables are coated from the fire barrier board for a minimum distance of five feet or to the nearest electrical panel or enclosure with material similar to Flamemastic 77 that is approved by Factory Mutual Research Corporation. Typical electrical penetration firestops through walls and floors are shown in Figures 3.B.(iii)-1 and 3.B.(iii)-2, respectively. The bare metal barrier plate in the cable tray wall penetration shown in Figure 3.B.(iii)-1 will be protected or modified to afford a fire rating at least equivalent to that assigned to the installed fire barrier.

Conduit penetrations, containing cables, through designated fire barriers, utilize RTV silicone rubber as the sealant material. This material is installed around the cables

in either the end of the conduit termination or in the nearest available conduit box on each side of the barrier. Inorganic fiber is used on each side of the sealant material. Spare conduits are plugged or capped until used.

The sealant material used in cable tray penetration fire stops is Dow Corning's 3-6548 silicone RTV foam (components A and B). This material in its cured foam state is noncorrosive and fire resistant. A sample of this material has been tested by an independent laboratory according to ASTM E84, standard method of testing of "Surface Burning Characteristics of Building Materials." The result of the test was that the material has a flame spread rating of 20.

The fire barrier material used in the design and installation of the penetration fire stops employ a combination of inorganic fiber and fiber board similar to Johns-Manville Cerafiber and Cera Form Board. These materials are made from exceptionally high purity alumina and silica constituents and are capable of withstanding continuous exposure to a temperature range of 2000° to 2300° F.

TVA has conducted fire tests on full-scale assemblies of electrical penetration fire stops that must seal against air pressure. The required differential air pressure across the penetration under test was maintained by adjusting a normal damper together with an exhaust fan in the exhaust duct. An external gas burner was located under the cables outside the area of coated cables. The burner was ignited on the fire side of test facility and allowed to burn for 30 minutes before shutoff. The fire was allowed to self-extinguish; therefore, no water spray test was conducted.

The results of the tests were that no fire burned through the penetration onto the cold side of the test facility and pressure seal maintained its integrity. The results from the tests demonstrate that the design provides an effective fire stop and pressure seal under simulated conditions when tested as a completed system.

In addition, fire tests on similar designs using the same type of cables and sealant material have been conducted

by others. Test results are recorded in report serial No. 26543 dated October 28, 1975, of Factory Mutual Research Corporation. TVA has done a comparative study between the Sequoyah design of cable-cable tray penetration fire stops and cable penetration assemblies tested to ASTM E-119 in Factory Mutual (FM) report No. 26543. From this study TVA has determined that the Sequoyah cable penetration fire stops are equivalent to those portions of the FM test No. 26543 that passed a 3-hour ASTM E-119 fire test.

The installed cable tray supports are similar to those used in the fire tests. From a review of the design of the cable trays supports together with post-test observations of the TVA mockup, we have determined that in case of collapse of trays on the fire side of the barrier, no loss of seal integrity will occur.

The design of the inplant cable tray supports are typically shown in Figures 3.B.(iii)-1 and 3.B.(iii)-2 for wall and floor penetrations with cable trays, respectively. During the tests conducted by TVA, warpage of the cable trays and supports was observed to occur outside the cable coated area. No visual distortion of the cable trays or their supports was observed at the wall opening following the test.

The design of the mechanical penetration fire stops are based on similar designs that use the same type of sealant and damming materials and that have been tested by others to the standard time-temperature curve of ASTM E-119.

The design of the mechanical fire stops utilize pipe sleeves for each penetration. Fire stops for pipe and duct penetrations consist of foamed-in-place Dow Corning 3-6548 silicone RTV foam installed to a depth of 12 inches or the thickness of the wall (minimum 8 inches). A typical pipe penetration fire stop is shown in Figure 3.B.(iii)-4.

In those pipe penetrations where pipe movements are present, a fire stop assembly consisting of a rolled silicone foam coated ceramic fiber blanket is wrapped around the pipe and stuffed into the sleeve on each side of the penetration. Airtight bellows seals are then installed over these fire stops. A typical fire stop of this type is shown in Figure 3.B.(iii)-5.

Fire tests on similar mechanical penetration fire stop designs have been conducted by Factory Mutual Research Corporation.

The results are recorded in Factory Mutual Report Serial No. 26543 dated October 28, 1975. The tests were performed following the procedures for evaluating floor-ceiling assemblies as defined under the Standard for Fire Testing of Building Construction and Materials ASTM E-119 (NFPA 251).

C. The following safety-related fire cells have been identified from the fire hazards analysis as having a fire loading greater than 120,000 Btu/ft².

- (1) Auxiliary Instrument Rooms (unit 1, 685.0-C1; and unit 2, 685.0-C4).
- (2) Cable Spreading Room (706.0-C2).
- (3) Diesel Generator Rooms (1A-A, 2A-A, 1B-B, 2B-B).
- (4) Diesel Generator Lube Oil Storage Room.
- (5) 480V Electrical Board Rooms (1A-A, 2A-A, 1B-B, 2B-B)
- (6) Intake Pump Station (El. 705.0 Upper Deck-ERCW Pump Trains)
- (7) Additional Equipment Buildings

TVA will provide equivalent three-hour fire rated compartmentation for these fire cells with the exception of the Diesel Generator Rooms and the Auxiliary Instrument Rooms.

The Diesel Generator Rooms and their associated board rooms are not separated by fire barriers. However, the Diesel Generator Room and board room for each diesel generator are separated by three-hour fire rated barriers from the same rooms of other diesel generators.

The unit 1 and unit 2 auxiliary instrument rooms (685.0-C1 and C4) are separated from the Turbine Building and Auxiliary Building by minimum three-hour fire resistant barriers. The Auxiliary Instrument Rooms are separated from each other by two 1-1/2-hour fire resistant barriers, the nonsafety-related computer room, and a corridor. (Refer to compartmentation drawing SK-1006.)

Although the fire loading of each Auxiliary Instrument Room exceeds a 1-1/2-hour duration, the fire loading consists mainly of exposed cable insulation in trays and all exposed cabling within the rooms is coated with a fire retardant material similar to Flamemastic 77.

In addition, each Auxiliary Instrument Room is provided with an automatic total flooding CO₂ system actuated by cross-zoned ionization smoke detectors and rate compensated heat detectors. This is supplemented by a fire hose station located in each stairwell.

As indicated in the response to question 21, loss of either Auxiliary Instrument Room does not prevent the ability to achieve and maintain a safe shutdown condition.

Due to the above considerations, TVA takes the position that the two as-built 1-1/2-hour fire barriers that separate the safety-related Auxiliary Instrument Rooms are adequate.

- D. The fire doors listed in Table 3.D-1 are alarmed through the security system's primary alarm station in the gatehouse and secondary alarm station in the control building. Refer to the SK-1000 series of compartmentation drawings for details showing door numbers and column lines. TVA does not propose to supervise the operation of other fire doors.

Doors separating the control building from the turbine building are normally closed, heavy equipment doors which are locked and operated by card readers. Operation of these doors (except for flood-pressure door C27) is alarmed in the main control room.

All of the heavy equipment doors separating the control and turbine buildings are augmented by 3-hour rated sliding fire doors which are held open by fusible links. There is no alarm capability associated with the sliding fire doors.

TABLE 3.B.(i)-1

<u>Door No.</u>	<u>Door Type</u>	<u>Elevation</u>	<u>Column</u>
A55	Flood door	690.0	s-t,A1
A57	Flood-pressure door	690.0	r-q,A1
A60	Pressure door	690.0	r-s,A1-A2
A64	Pressure door	690.0	u-v,A15-C13
A65	Flood door	690.0	v-w,A1-S1
A77	Pressure door	690.0	u-v,A1-S1
A78	Flood door	690.0	v-w,A15-C13
A101	Pressure door	706.0	u-v,A2-A3
A105	Pressure door	706.0	u-v,A13-A14
A112	Flood door	706.0	x-y,A5
A115	Pressure door	706.0	w-x,A6-A8
A123	Pressure door	714.0	t-u,A3
A132	Pressure door	714.0	t-u,A13
A152	Pressure door	734.0	t-u,A5
A153	Pressure door	734.0	t-u,A8
A154	Pressure door	734.0	u-w,A8-A10
A159	Pressure door	734.0	t-u,A11
A173	Pressure door	734.0	u-x,A5-A6
A184	Pressure door	749.0	r-s,A3-A4
A191	Pressure door	749.0	r-s,A12-A13
A214	Pressure door	714.0	w-x,A12-A13
A215	Pressure door	714.0	w-x,A3-A4

TABLE 3.B.(i)-2

<u>Door No.</u>	<u>Door Type</u>	<u>Elevation</u>	<u>Column</u>
C49	Security door	732.0	q,C4-C5
C50	Security door	732.0	q,C9-C10
C55	Security door	732.0	n,C9-C10
C56	Security door	732.0	n,C4

TABLE 3.B.(i)-3

<u>Door No.</u>	<u>Elevation</u>	<u>Column</u>	<u>Remarks</u> (See note)
A19	669.0	s-t,A6-A8	(1)
A20	669.0	s-t,A5-A6	(1)
A37	669.0	w,A8-A10	(1)
A38	669.0	w,A10-A11	(1)
A82	690.C	q,A4-A5	(1)
A83	690.0	r-s,A3-A4	(1)
A127	714.0	u-v,A6-A8	(1)
A128	714.0	u-v,A8-A10	(1)
A183	714.0	w-x,A3-A4	(2)
A192	714.0	w-x,A11-A12	(2)

Notes:

- (1) Fire door modifications identified in Nonconformance Report SWP-78-S-2.
- (2) Modifications resulting from commitments made in response to question 3.B.(i).

TABLE 3.B.(ii)-1

<u>TVA Damper No.</u>	<u>TVA Drawing No.</u>
0-31A-12	47W866-4 ↓ 47W866-3 ↓ 47W866-2 47W866-11 47W866-3 ↓ 47W866-2 47W866-11
0-31A-20	
0-31A-25	
0-31A-26	
0-31A-8	
0-31A-39	
0-31A-159	
PCO-39-17A	
0-31A-13	
0-31A-21	
1-31C-792	
2-31C-818	
1-31C-793	
2-31C-819	
1-31C-796	
2-31C-822	
1-31C-794	
2-31C-820	
1-31C-802	
2-31C-828	
1-31C-829	
2-31C-830	
1-31C-800	
2-31C-826	
1-31C-795	
2-31C-821	
1-31C-781	
2-31C-807	
1-31C-1199	
2-31C-1333	
1-31C-955	
2-31C-955	
1-31C-777	
2-31C-803	
1-31C-957	
2-31C-957	
1-31C-1200	
2-31C-1335	

TABLE 3.B.(ii)-2

<u>TVA Damper No.</u>	<u>TVA Drawing No.</u>
1-31C-914	47W866-3
2-31C-914	
1-31C-908	
2-31C-908	
1-31C-926	
2-31C-926	
1-31C-913	
2-31C-913	
1-31C-906	
2-31C-906	
1-31C-941	
2-31C-941	
1-31C-949	
2-31C-949	
1-31C-935	
2-31C-935	
1-31C-1204	47W866-2
2-31C-1338	47W866-11
1-31C-1206	47W866-2
2-31C-1337	47W866-11
1-31C-918	47W866-3
2-31C-918	
1-31C-919	
2-31C-919	
1-31C-916	
2-31C-916	
1-31C-921	
2-31C-921	
0-31A-148	47W866-4

TABLE 3.B.(ii)-3

<u>TVA Damper No.</u>	<u>TVA Drawing No.</u>	<u>Remarks</u> (See note)
0-31A-243	47W866-4	(2)
0-31A-231	↓	↓
0-31A-233	↓	↓
0-31A-241	↓	↓
0-31A-242	↓	↓
0-31A-236	↓	↓
0-31A-257	↓	(1)
1-31C-1219	47W866-2	↓
1-31C-1220	↓	↓
1-31C-1217	↓	↓
1-31C-1218	↓	↓
2-31C-1221	47W866-3	↓
2-31C-1222	↓	↓
2-31C-1223	47W866-11	↓
1-31C-611	47W866-8	(2)
2-31C-662	↓	↓
0-30-613	47W866-9	(1)
0-30-594	↓	(2)

Notes:

- (1) Fire damper modifications identified in Nonconformance Report SWP-78-S-2.
- (2) Modifications resulting from commitments made in response to question 3.B.(ii).

TABLE 3.B.(ii)-4

<u>Feature</u>	<u>Dowco Corporation and American Foundry and Furnance Co., Model FNM-2003-16 (Non-Labeled)</u>	<u>Ruskin Manufacturing Company Model FD, FD/SS (Certified)</u>
Frame Design	2" x 1/2" x 1/8" HR steel channel - Braced with 1/8" x 1" steel corner brace	3-1/2" x 7/8" x 16 ga. (1/16") galvanized with internally braced corners
Blade Dimensions	7" wide maximum, 16 ga. galvanized steel	6" wide, 16 ga. galvanized steel
Blade Shaft and Bearings	7/16" cadium steel shaft oil impregnated bearings	1/2" zinc plated shaft oilite bronze bearings
Linkage	1/4" diameter cadium plated CR steel	3/16" x 3/4" steel tiebars
Fusible Link	Yes - 160 ⁰	Yes - 160 ⁰
Finish	Zincilate-frame mill galvanized	Mill galvanized


TABLE 3.D-1

<u>Door No.</u>	<u>Building</u>	<u>Elevation</u>	<u>Column</u>
A3	Auxiliary	653.0	t-u,A6-A7
A4	Auxiliary	653.0	t-u,A6-A7
A5	Auxiliary	653.0	u-v,A6-A7
A6	Auxiliary	653.0	v-w,A50A7
A8	Auxiliary	653.0	v-w,A9-A10
A9	Auxiliary	653.0	u-v,A9-A10
A10	Auxiliary	653.0	t-u,A9-A10
A11	Auxiliary	653.0	t-u,A9-A10
A25	Auxiliary	669.0	t-u,A2
A46	Auxiliary	669.0	t-u,A14
A117	Auxiliary	706.0	w-x,A3-A4
A118	Auxiliary	706.0	x-y,A12-A13
A125	Auxiliary	714.0	u-v,A2-A3
A130	Auxiliary	714.0	u-v,A13-A14
A169	Auxiliary	734.0	q-r,A11-A12
A170	Auxiliary	734.0	q-r,A11-A12
A172	Auxiliary	734.0	q-r,A8-A10
A181	Auxiliary	749.0	q-r,A6
A182	Auxiliary	749.0	q-r,A4
A194	Auxiliary	749.0	q-r,A12
A195	Auxiliary	749.0	q-r,A10
A203	Auxiliary	759.0	w-x,A4-A5
A204	Auxiliary	759.0	w-x,A11-A12
A207	Auxiliary	763.0	s-t,A6-A8
C1	Control	669.0	n-p,C3-C4
C10	Control	669.0	n-p,C9-C10
C12	Control	669.0	n-p,C10-C11
C21	Control	685.0	n-p,C3-C4
C22	Control	685.0	n-p,C6-C7
C23	Control	685.0	n-p,C6-C7
C24	Control	685.0	n-p,C7-C8
C25	Control	685.0	n-p,C10-C11
C30	Control	706.0	n-p,C3-C4
C33	Control	706.0	n-p,C10-C11
C49	Control	732.0	q,C4-C5
C50	Control	732.0	q,C9-C10
C51	Control	732.0	n-p,C12-C13
C52	Control	732.0	n-p,C10
C55	Control	732.0	n-p,C9-C10
C56	Control	732.0	n-p,C4-C5

HIGHER
PRESSURES
SIDE


1" Inorganic Fire
Barrier Board, Cut to
Fit Around Tray and
Cable Configurations
(both sides of wall).

After wall board is
in place, coat
exposed surfaces for
a minimum distance
of 5' from inorganic
board or to nearest
electrical panel or
enclosure with a
3/16 to 1/16" (wet
depth) of ablative
material (both sides
of wall).



CABLE TRAY PENETRATION


Typical of Wall Opening with Metal Barrier




CONDUIT PENETRATION

Figure 3.E.(iii)-1

Typical Horizontal Electrical Penetration
Fire Stops through Wall



TOP PLAN VIEW



ELEVATION

Figure 3.B.(111)-2

Typical Vertical Electrical Penetration Fire Stop through Floor with Embedded Cable Sleeve

SILICONE FOAM, ALL AIR SPACES
BETWEEN SLEEVE AND WALL

CONCRETE WALL




Figure 3.B.(iii)-3
TYPICAL FIRE DAMPER
PENETRATION FIRE STOP




FIGURE 3.B.(iii)-4
 TYPICAL PIPE PENETRATION FIRE STOP
 (WITHOUT PIPE MOVEMENTS)






FIGURE 3.B.(iii)-5
 TYPICAL PIPE PENETRATION FIRE STOP
 (WITH PIPE MOVEMENTS)



UNIT ONE GENERAL VENTILATION



NOTES:


- SYSTEM IDENTIFICATION NUMBERS 30 & 31C.
- FOR GENERAL NOTES, REFERENCE DRAWINGS, AND DAMPER LEGEND SEE 47866-1.
- FOR CHILLED WATER SUPPLY TO AIR HANDLING UNITS, AIR INTAKE COILS, AND HOT WATER SUPPLY TO AIR INTAKE COILS SEE 47866 SERIES.
- ALL AIR CONDITIONING DUCTWORK AND DUCTWORK BELOW EL 690.0 SHALL BE TVA CLASS U.
- ALL DUCTWORK ABOVE EL 690.0 SHALL BE TVA CLASS S (RECTANGULAR DUCTS) EXCEPT WHERE MARKED TVA CLASS Q (ROUND DUCTS).
- DESIGN CRITERIA REFERENCE SQN-DC-7.9.
- FULL FLOW VENTILATION WILL OCCUR ONLY WHEN PUMP ROOM DOORS ARE OPEN.
- THIS GRILLE AND BACKDRAFT DAMPER TO BE USED ONLY DURING CONSTRUCTION OF UNIT 2.
- THIS DUCT TO BE BLANKED OFF DURING UNIT 2 CONSTRUCTION.
- DESIGN PRESSURE ABOVE ELEVATION 690.0 IS 6 IN-WG IN ACCORDANCE WITH SMACNA HIGH VELOCITY DUCT CONSTRUCTION STANDARDS FOR MEDIUM PRESSURE. DESIGN PRESSURE FOR DUCTWORK BELOW ELEVATION 690.0 IS 2 IN-WG IN ACCORDANCE WITH SMACNA LOW VELOCITY DUCT CONSTRUCTION STANDARDS. DUCTWORK SHALL BE TESTED IN ACCORDANCE WITH TVA GENERAL CONSTRUCTION SPECIFICATION NO. G-37.

16	2/21/51	1-7-79	HR	HR	SHK	DCR	284	-	124	1/2
15	2006									
14	1934									
13	1647									
12	1647, 1634, 1623, 1610									
11	1647, 1634									
10	1647, 1634									
9	1647, 1634									
8	1647, 1634									
7	1647, 1634									
6	1647, 1634									
5	1647, 1634									
4	1647, 1634									
3	1647, 1634									
2	1647, 1634									
1	1647, 1634									

POWERHOUSE
 AUXILIARY BUILDING
 FLOW DIAGRAM
 HEATING & VENTILATING
 AIR FLOW

SEQUOYAH NUCLEAR PLANT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF ENGINEERING DESIGN

SUBMITTED: *Charles H. Bailey*
 RECOMMENDED: *[Signature]*
 APPROVED: *[Signature]*



AIR FLOW
AUXILIARY BLDG
SHUTDOWN ROOM

- Reference Drawings
- 47B364-3K Series, Instrument Tabulations
 - 47B401-30 Series, Instrument Tabulations
 - 47A366-3K Series, Valve Marker Tag Tabulations
 - 47W862-B, Chilled Water Flow Diagram
 - 47W862-G, Refrigerant Flow Diagram
 - 47W867-5, 6 and 7, EL 749 Control Diagram
 - 47W867-8, 3, EL 734 Control Diagram

- NOTES:
1. For notes, abbreviations, dimensions, and damper legend, see 47W864-1.
 2. Design pressure is 8 in.-wg in accordance with SMACNA high velocity duct construction standards for medium pressure. Ductwork shall be tested in accordance with TVA General Construction Specification No. G-37.
 3. Design Criteria Reference SQN-DC-7.9.
 4. The duct containing these fire dampers passes through the 480V Board Rm 2A, 480V Trans Rms 2A&2B AND 480V Bd Rm 2B to Battery Rm IX. There is a fire damper in each wall.

SEE REV. NO. X AT RIGHT

NO.	DATE	BY	CHKD.	DESCRIPTION








DIAGRAM
RD ROOMS E1749.0
RD ROOMS E1734.0

11	2121	1-7-74	HRL	HRL	SRK	DR	WAM	1000	24/10/74
	ADDED FIRE DAMPERS AND NOTE 4								
10	1647	1-23-77	EBS	EBS	DRS	DRS	DRS	DRS	10/10/77
	DELETED DAMPERS & CHGD DAMPER NOS								
9	SI	6-20-77	DRS	EBS	DRS	DRS	DRS	DRS	10/10/77
	CHANGED DAMPER NUMBERS & FAN DESIGNATION								
8	1647	4-8-77	DRS	DRS	DRS	DRS	DRS	DRS	10/10/77
	ADDED FIRE DAMPERS								
7	SI	10-4-76	DRS	DRS	DRS	DRS	DRS	DRS	10/10/76
	ADDED DAMPER SYM, CHG D FAN NO								
6	SI	7-1-76	DRS	DRS	DRS	DRS	DRS	DRS	10/10/76
	ADDED REF DWGS IN NOTE 3, VARIOUS REV								
5	SI	3-2-76	DRS	DRS	DRS	DRS	DRS	DRS	10/10/76
	Added note 2								
4	SI	1-7-76	DRS	DRS	DRS	DRS	DRS	DRS	10/10/76
	Added note 1								
3	ECN	1405	1-25-75	UNREV	UNREV	UNREV	UNREV	UNREV	10/10/75
	Installed 20 KW Heaters in Pressurizing Air Supply Ducts								
	Changed AHU air flow rates, press fan air supply source, added dampers								
	Detailed fan instrument shop & control room program; minor revisions								
	Change E1749.0 air conditioning & air conditioning system and minor revisions								
REV									
NO	ECN NO	DATE	ISSUED	APPROVED	BY	CHKD	REVISION	APPV	

POWERHOUSE
AUXILIARY BUILDING
FLOW DIAGRAM
HEATING VENTILATING & AIR COND
AIR FLOW

SEQUOYAH NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

SUBMITTED: *[Signature]*
RECOMMENDED: *[Signature]*
APPROVED: *[Signature]*




NOTES

1. THE AIR QUANTITIES SUPPLIED AND EXHAUSTED TO AND FROM EACH FLOOR ARE DESIGNED TO PRESSURIZE ALL FLOORS EXCEPT THE SPREADING ROOM.
2. ONE BATTERY ROOM EXHAUST FAN SHALL BE IN OPERATION WITH THE OTHER TWO ON STANDBY.
3. AIR QUANTITIES INDICATED THIS (200) ARE FLOW QUANTITIES FOR EMERGENCY OPERATION.
4. EQUIPMENT IDENTIFICATION NUMBER, AND THE SECOND LETTER DESIGNATES THE POWER TRAIN ASSIGNMENT.
5. ALL VALVE TAG NUMBERS ARE PREFIXED BY -D- UNLESS OTHERWISE NOTED.
6. DESIGN PRESSURE FOR CONTROL BUILDING DUCTWORK IS IN ACCORDANCE WITH TABLE A. DUCTWORK SHALL BE TESTED IN ACCORDANCE WITH TVA GENERAL CONSTRUCTION SPECIFICATION NO. G-37.

15	REV	FCD'S PER FLOOR	11-27-77	JPL/AM	
16	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
17	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
18	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
19	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
20	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
21	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
22	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
23	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
24	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
25	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
26	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
27	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
28	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
29	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
30	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
31	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
32	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
33	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
34	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	
35	REV	SECURITY ALARM STATION ROOM	11-27-77	JPL/AM	

13	51	6-30-77	DTG	EBS	JAM	MVB	JLP	-	JLP	JLK	MP
12	1647, 1649	4-8-77	DTG	HRL	JAM	MVB	JLP	-	JLP	JLK	MP
11	51	12-20-76	BCJ	BCJ	DTG	MVB	JLP	-	JLP	JLK	MP
10	51	9-9-76	DTG	WJA	SLA	MVB	BCJ	-	BCJ	JLK	MP



DESIGN PRESSURE
DUCTWORK WITH CONDITIONED
PRESSURIZED AIR

POINT TO POINT	PRESSURE IN * G
A - B	1.75
B - C	0.20
C - D	0.25
D - E	0.25
E - F	0.50
F - G	1.80
G - H	0.50
H - K	1.00

TABLE 4

9	57	8-12-76	DTG	JLG	GLA	HVB	BOC	-	BOC	JLK	IMP	
		ADDED DOORS, REF. CHG. DUCT										
8	51	6-1-76	DTG	HRL	JHM	HVB	BOC	-	BOC	JLK	IMP	
		REVISED NOTE 6, ADDED TABLE 4 AND S.P. REF. NOS.										
7	51	3-29-76	PER	PER	1	HVB	BOC	-	BOC	JLK	IMP	
		ADDED NOTE 6										
6	1567, 1572	12-30-75	DTG	JHM	HVB	BOC	-	BOC	JLK	IMP		
		ADDED EMERG. PRESSURE CROSSOVER, RELOCATED P.S.O. ENGINE, SHOP										
5	1439, 1450	6-19-75	GLA	DTG	HVB	CLB	-	CLB	JLK	IMP		
		CHG. FLOW RATES B RM DES. RELOCATED BATTERY RM EXH. FAN, RELOCATED DUCT										
4	51	1-13-75	DTG	ADH	BOC	HVB	CLB	-	CLB	JLK	IMP	
		CHGD. VALVE MARKER TAGS, CHGD. INST. NOS.										
3	51	10-24-74	DTG	DTG	HVB	CLB	-	CLB	JLK	IMP		
		CHANGED INST. NO'S										
2	1224, 1217, 1308	9-30-74	DTG	DTG	HVB	CLB	-	CLB	JLK	IMP		
		CHG. AIR FLOW QUANTITIES, CHG. PRESS. AIR INTAKE, ADDED DMPS										
1	116, 117	1-22-74	DTG	DTG	BOC	CLB	-	CLB	JLK	IMP		
		REDRAWN										

REV. NO.	ECN NO.	DATE	ORGN.	BY	CHKD.	SUPV.	ENGR.	NSP.	SUBMITTER	APPD.

SCALE: NONE EXCEPT AS NOTED

POWERHOUSE CONTROL BUILDING UNITS 1 & 2

FLOW DIAGRAM HEATING VENTILATING AND AIR CONDITIONING AIR FLOW

SEQUOYAH NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN



SUBMITTED: [Signature] RECOMMENDED: [Signature] APPROVED: [Signature]

REFERENCE DRAWINGS



- 47865-3-7 - - - REFRIGERANT FLOW DIAGRAM
- 47867-1, 2, 3 - - - CONTROL DIAGRAMS
- 47A366-314-1 THRU 6 - VALVE MARKER TAG TABULATION
- 47866-314-1 THRU 16 - INSTRUMENT TABULATIONS
- 50N-DC-V-78 - DESIGN CRITERIA FOR CONTROL BUILDING AIR-CONDITIONING SYSTEM

DAMPER LEGEND

- NORMALLY OPEN
- NORMALLY CLOSED
- X— FAILS CLOSED
- FAILS OPEN
- B— BALANCE
- D— BACKDRAFT
- F— FIRE
- FA— FAILS AS IS



12	2001	10-11-78	REVISIONS	ADD 1-31C-641	ADD 1-31C-642	ADD 1-31C-643	ADD 1-31C-644	ADD 1-31C-645	ADD 1-31C-646	ADD 1-31C-647	ADD 1-31C-648	ADD 1-31C-649	ADD 1-31C-650	ADD 1-31C-651	ADD 1-31C-652	ADD 1-31C-653	ADD 1-31C-654	ADD 1-31C-655	ADD 1-31C-656	ADD 1-31C-657	ADD 1-31C-658	ADD 1-31C-659	ADD 1-31C-660
11	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
10	1730	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
9	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
8	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
7	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
6	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
5	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
4	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
3	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
2	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660
1	1654	10-11-78	REVISIONS	ADD 2-31C-641	ADD 2-31C-642	ADD 2-31C-643	ADD 2-31C-644	ADD 2-31C-645	ADD 2-31C-646	ADD 2-31C-647	ADD 2-31C-648	ADD 2-31C-649	ADD 2-31C-650	ADD 2-31C-651	ADD 2-31C-652	ADD 2-31C-653	ADD 2-31C-654	ADD 2-31C-655	ADD 2-31C-656	ADD 2-31C-657	ADD 2-31C-658	ADD 2-31C-659	ADD 2-31C-660




SPACE HEATER
 TYPICAL FOR HS-31C-544 & TS-31C-544
 THROUGH
 HS-31C-558 AND TS-31C-558
 SEE CHART

EL 734.0
 EL 714.0
 EL 690.0
 EL 669.0
 EL 653.0

- NOTES
1. SYSTEM IDENTIFICATION NUMBERS 30-31C
 2. FOR IDENTIFICATION OF SYMBOLS
 30B617 MECH INSTRUMENTATION SYMBOLS
 30B617 MECH FLOW & CONTROL DIAGRAM
 3. FOR VALVE-MARKER-TAG TABULATION SEE 47W856-31C-1, 2
 4. NUMBERS SHOWN THUS 1-31C-414 ARE VALVE MARKER TAG NUMBERS FOR UNIT 1. UNIT 2 NUMBERS ARE PREFIXED BY 2
 5. NUMBERS SHOWN THUS 3,500 INDICATE FLOW IN CFM
 6. TYPICAL INSTRUMENT NUMBERS SHOWN THUS $\text{HS } \begin{matrix} \text{554} \\ \text{554} \end{matrix}$ AND $\text{TS } \begin{matrix} \text{554} \\ \text{554} \end{matrix}$ ARE ABBREVIATED FORMS OF HS-31C-554 & TS-31C-554
 7. DESIGN PRESSURE IN THE ADDITIONAL EQUIPMENT BUILDING IS 2 IN-WG IN ACCORDANCE WITH SMACNA LOW VELOCITY DUCT CONSTRUCTION STANDARDS. DESIGN PRESSURE FOR AUXILIARY BUILDING ESF COOLER DUCTWORK IS 6 IN-WG IN ACCORDANCE WITH SMACNA HIGH VELOCITY DUCT CONSTRUCTION STANDARDS. DUCTWORK SHALL BE TESTED IN ACCORDANCE WITH TVA GENERAL CONSTRUCTION SPECIFICATION G-87. BERGW FOR AUXILIARY BUILDING ESF COOLER IS SHOWN ON 47W845-4.

AUXILIARY BLDG

HEATERS & A/C UNITS		INSTRUMENTS			
SIGNATURE	ELEVATION	COL	UNIT	HS	TS
UNIT HEATER	706.0	A4B-WD		544	544
	740.5	A4-WD		545	545
	706.0	A11B-14	2	546	546
	717.5	A11B-14		547	547
	740.5	A11B-14		548	548
	752.25	A11B-14		549	549
	763.5	A11B-14		550	550
		A11B-14		551	551
		A11B-14		552	552
		A11B-14		553	553
		A11B-14		554	554
		A11B-14		555	555
		A11B-14		556	556
A/C UNIT	740.5	A5-WB	1	540	540
	706.0	A11B-A	2	541	541
	740.5	A11B-A		542	542
	763.5	A11B-A		543	543



REFERENCE DRAWINGS:
 47W610-30-586
 47W611-65-1
 47W93C
 47W321-1, 2
 47W485-4

5	SI	9-12-76	REVISION	ADD	1-1	ADD PUMP COOLER NAMES & MINOR REVISION
4	SI	5-27-76	REVISION	ADD	1-1	ADD PUMP COOLER NAMES & MINOR REVISION
3	SI	2-25-76	REVISION	ADD	1-1	ADD PUMP COOLER NAMES & MINOR REVISION
2	ECN	4-6-65	REVISION	ADD	1-1	ADD INSTRUMENT NO. 2 (NOT CIR-CLED) & REVISED NOTE
1	SI	7-12-75	REVISION	ADD	1-1	ADD INSTRUMENT NO. 2 (NOT CIR-CLED) & REVISED NOTE

ADDED ADD EQPT BLDG EXH
 1-1
 1-1
 ADDED RAW COOLING WATER REFERENCES, TYPICAL DETAIL FOR SPACE HTRS, LOCATION CHART FOR HTRS, A/C UNITS, AND INSTR. NOTE 7.

REV	NO	DATE	DESCRIPTION	BY	CHKD	APPD




POWERHOUSE
 AUX BLDG & ADDITIONAL EQUIP. BLDG

FLOW DIAGRAM
 HEATING AND VENTILATING
 AIR FLOW

SEQUOYAH NUCLEAR PLANT
 TENNESSEE VALLEY AUTHORITY
 DIVISION OF ENGINEERING DESIGN




SUBMITTED	RECOMMENDED	APPROVED
J. A. Hudson	D. K. Patterson	H. E. Van Camp


KNOXVILLE 7-10-73 45 M 4 47W866-8 R12




DIESEL ROOM VENTILATION SYSTEM
TYPICAL ALL DIESEL GENERATOR UNITS
1A-A, 2A-A, 1B-B, 2B-B, EXCEPT AS NOTED

- DAMPER LEGEND**
- AUTOMATIC OPERATION FOR NORMAL SERVICE
 - REMOTE-MANUAL OPERATION
 - AUTOMATIC OPERATING FOR ISOLATION
 - NORMALLY OPEN
 - NORMALLY CLOSED
 - FIRE DAMPER
 - BACKDRAFT DAMPER
 - BALANCING DAMPER
 - MANUAL DAMPER






- NOTES:
- FOR GENERAL NOTES SEE 47W866-1
 - DIESEL GENERATOR ROOM EXHAUST FANS 1 & 2, BATTERY HOOD EXHAUST FANS AND ELECTRIC BOARD ROOMS EXHAUST FANS SHALL EACH BE CONNECTED TO POWER TRAIL WHICH SUPPLIES THE RESPECTIVE DIESEL GENERATOR UNIT
 - A TYPICAL INSTRUMENT NUMBER SHOWN THUS $\text{FCO } 468$ IS ABBREVIATED FORM OF FCO-30-468
 - INSTRUMENT NUMBERS ARE LISTED FOR DIESEL GENERATOR UNITS 1A-A, 2A-A, 1B-B, 2B-B, AS FOLLOWS
-
- DESIGN PRESSURE FOR BATTERY HOOD EXHAUST DUCTWORK IS 6 IN-WG IN ACCORDANCE WITH SMACNA HIGH VELOCITY DUCT CONSTRUCTION STANDARD. DESIGN PRESSURE FOR ALL OTHER DUCTWORK IS 2 IN-WG IN ACCORDANCE WITH SMACNA LOW VELOCITY DUCT CONSTRUCTION STANDARDS. DUCTWORK SHALL BE TESTED IN ACCORDANCE WITH TVA GENERAL CONSTRUCTION SPECIFICATION NO G-37.
 - FOR DESIGN CRITERIA FOR DIESEL GENERATOR SYSTEM REFER TO SON-DC-V-11.1.




STORAGE ROOM AND RADIATION SHELTER VENTILATION SYSTEM

REFERENCE DRAWINGS:
 17W910-1-B-2 - - EQUIPMENT DRAWINGS
 47W866-30 SERIES - INSTRUMENT TABULATION
 47A366-30 SERIES - VALVE MARKER TAG TABULATION
 47W611-30-7 - - VENTILATION SYSTEM LOGIC DIAG

9	3/71	1-4-79 JNC	PH/CS	DES	100	-	100	1/1/79	
8	1647	4-23-77 JAC	JAC/OTS	PH/PL	-	200	1/1/77		
7	51	4-20-77 JAC	HR/OTS	PH/PL	-	200	1/1/77		
6	1647	4-8-77 JAC	HR/AM	PH/PL	-	200	1/1/77		
5	51	4-8-77 JAC	HR/AM	PH/PL	-	200	1/1/77		
4	5-1	5-26-76 JAC	HR/AM	PH/PL	-	200	1/1/76		
3	51	3-29-76 JAC	HR/AM	PH/PL	-	200	1/1/76		
2	1647	3-15-76 JAC	HR/AM	PH/PL	-	200	1/1/76		
1	5-1	3-5-76 JAC	HR/AM	PH/PL	-	200	1/1/76		
REV	NO	DATE	BY	CHKD	SUPV	ENGR	INSP	APPV	
DESIGN	JAC							INSP	PH/PL
CHKD	JAC							INSP	PH/PL
SUPV	JAC							INSP	PH/PL
DIESEL GENERATOR BUILDING									
FLOW DIAGRAM HEATING VENTILATING AIR FLOW									
SEQUOYAH NUCLEAR PLANT TENNESSEE VALLEY AUTHORITY DIVISION OF ENGINEERING DESIGN									
SUBMITTED			RECOMMENDED			APPROVED			
JAC			JAC			PH/PL			
KNOXVILLE 4-1-74			45 M			47W866-9 P9			



UNIT TWO GENERAL VENTILATION



COMPANION DRAWINGS
47W866-2, -10

REV NO.	ECH NO.	DATE	BY	CHKD	SUPV	ENGR	INSP	SUBMITTED	APPV
1	1	12-15-76	T.E. COLLINS	R.D. TOLLEY					
2	2	1-15-77	C.W. PARKER						
3	3	4-27-76	T.E. COLLINS						
4	4	8-16-76	B.D. GINGLAW						
5	5	12-15-76	T.E. COLLINS						
6	6	1-15-77	C.W. PARKER						
7	7	9-23-77	T.E. COLLINS						
8	8	12-22-76	T.E. COLLINS						
9	9	12-15-76	T.E. COLLINS						

1. DELETED FCO-30-47, FCO-30-28'S. ADDED PRESS DIFF INDICATORS 67 AND 285, WASTE GAS ANALYZER RM & REVISED AIR FLOW RATES.
 2. ADDED NOTE 2 ADDED ISOLATION DAMPER TO GROSS FAILED DET RM.
 3. ADDED NOTE 3.
 4. REVISED FLOW RATES.
 5. ADDED BALANCING DAMPER TO SAMPLE ROOM EXHAUST.
 6. ADDED FIRE DAMPERS AND REVISED FLOW RATES.
 7. ADDED FIRE DMPR V NO'S, FIRE DMPRS, DELETED DUCT & FIRE DMPR.
 8. DELETED HEPA FILTERS PER ECN.
 9. ADDED DAMPERS.

AUXILIARY BUILDING
FLOW DIAGRAM
HEATING & VENTILATING
AIR FLOW

SEQUOYAH NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN

SUBMITTED: Charles L. Bailey
RECOMMENDED: J. C. King
APPROVED: R. M. Carson

4. Item 3.e. - It is our position that fire stops be installed every 20 ft. along horizontal uncoated cable routings in areas not protected by automatic water systems. Between levels or in vertical uncoated cable chases, fire stops should be installed at the mid-height if the vertical run is 20 ft. or more, at less than 30 ft. or at 15-foot intervals in vertical runs of 30 ft. or more unless such vertical cable routings are protected by automatic water systems directed on the cable trays. Individual fire stop designs should prevent the propagation of a fire for a minimum period of 30 minutes when tested for the largest number of cable routings and maximum cable density. Confirm that your design will meet this position.

TVA Response

In areas outside primary containment containing one or both safety-related divisions, all exposed surfaces of cables in horizontal or vertical routings will be coated with a flame-retardant material such as Flamemastic 77. Thus, the design meets the stated NRC position and no fire stops will be installed at intervals in horizontal or vertical routings.

5. Item D.4, Ventilation - Describe the procedure employed for heat and smoke removal using fixed or portable equipment in areas that house systems or components necessary for cold shutdown of the plant. Describe how these areas can be ventilated for manual firefighting purposes. Include a discussion regarding control accesses to ventilation equipment (including fire dampers) as well as the ability to handle high temperature gases and particulates.

TVA Response

In general, heat and smoke removal capability is provided in areas that house systems or components necessary for cold plant shutdown by the normal ventilation systems discussed in FSAR Section 9.4. A developing fire will cause the isolation of these ventilation systems in the immediate vicinity of the fire through the closing of fusible link or fire detector actuated dampers. Smoke venting at this point will be accomplished by the use of portable smoke ejectors. Two ejectors are provided for the use of the fire brigade and each is rated at 7200 cfm. Smoke will be vented from a fire area to adjacent areas, where it will be removed by the normal ventilation systems.

Those areas of the plant utilizing recirculating ventilation systems will rely upon portable smoke ejectors exclusively.

Due to containment requirements, smoke removal in the reactor building will be provided by the containment purge air system. Should the smoke and fire gas temperatures exceed the capability of the containment purge air system, it will be isolated and smoke removal will be accomplished by the redundant trains of the standby gas treatment systems.

6. Item D.5, Lighting and Communication

- A. Item (a). You state that adequate emergency lighting system is provided in safety-related areas of the plant. Power supply for the system is from the plant emergency diesel generator. Your proposed emergency lighting system is unacceptable. It is our position that fixed self-contained lighting consisting of fluorescent or sealed beam units with an individual 8 hr. minimum battery power supply be provided in areas that must be manned for safe cold shutdown and for access and egress routes to and from all fire areas.
- B. Item (d). You indicate that fixed repeaters are being installed in the Sequoyah plant to facilitate the use of portable radio equipment. It is our position, however, that the fixed repeaters should be protected against exposure fire damage using 1/2 hour fire rated barriers such as 1" mineral wool. In addition, verify that the portable radio communication system will be tested to demonstrate that its frequencies will not interfere with the actuation of protective relays.

TVA Response

- A. Item (a). Fixed self-contained lighting consisting of fluorescent or sealed beam units with an individual 8 hour minimum battery power supply will be provided in areas that must be manned for safe cold shutdown and for access and egress routes to and from all fire areas.
- B. Item (d). The protection of fixed radio repeaters by 1/2 hour fire rated barriers such as mineral wool is not feasible since the repeater would be damaged by overheating. It is TVA's position that such protection is not necessary due to the redundancy and physical separation of the repeaters.

There are three independent intraplant radio repeater systems at Sequoyah. Two of these systems known as the inplant repeaters, operate with 26 two-channel portable radios (this group includes the six fire brigade portables). One of these repeaters is located in the turbine building and one is located in the auxiliary building, providing multiple fire barriers between systems. The associated portables can address either of these repeaters.

The third intraplant repeater system (the public safety service repeater system) consists of one repeater located in the turbine building and 18 portable radios. These portable radios have three channels capable of addressing all three intraplant repeater systems. The public safety service repeater is located on a different turbine building elevation from one inplant repeater and in a different building from the other.

The portable radio communication system will be tested during the preoperational test program to demonstrate that its frequencies will not interfere with other plant systems.

7. Item E.1, Fire Detection - Your description of the fire detection system is incomplete. Describe the type of detector provided for each room or area containing safety related equipment or systems. Also, provide a detailed description of the fire detection system, supported where necessary, by diagrams or appropriate prints (include a single line drawing from the detection circuits, waterflow alarms, through the subpanels and into the control room).

It is our position that primary and secondary power be supplied as follows:

- A. Using normal offsite power as the primary supply with a 4 hr. battery supply as secondary supply; and
- B. Having capability for manual connection to the Class 1E emergency power, but within 4 hrs. of loss of offsite power. Such connection should follow the applicable guidelines in Regulatory Guides 1.6, 1.32, and 1.75. Confirm that your design will meet this position.

TVA Response

The fire detection system complies with the requirements of BTP 9.5-1, Appendix A, and is designed in accordance with NFPA 72D and 72E. The system consists of initiating devices, local control panels, remote transmitter-receivers providing remote multiplex (MUX) functions, and computerized multiplex central control equipment. Refer to Figure 7-1 for a block diagram of the system.

The system's initiating devices consist of fire detectors which are identified as to type and location in Table 1-1 and flow alarm pressure switches which are provided for each fixed suppression system.

A central processor unit (CPU) communicates with the local control panels via the remote MUX units over looped circuits. The MUX equipment allows the processor to interrogate each local control panel in turn and to receive data from the panels. When an initiating device changes from normal to a trouble or alarm status, it is detected at the remote MUX transmitter-receiver and when next interrogated by the central processor will transmit this status change. The change is evaluated by the processor and visual and audible indications provided.

An alarm condition results in the following system responses:

- (1) Sounding of audible devices locally and in the main control room.
- (2) Illumination of indicating lamps on the local control panel indicating the location of the alarming device.
- (3) Actuation of local control panel circuits for the control of automatic suppression systems, fire pumps, fire dampers, fire doors, and ventilation equipment.

- (4) Identification of the location and time of receipt of the alarm condition on a cathode ray tube (CRT) display in the main control room and on a line printer in the unit 2 auxiliary instrument room.

The fire detection system is electrically supervised as required in NFPA 72D Article 240, for ground and open wiring faults in the detection, power supply, alarm, and data transmission circuits. Electrical supervision of the supplementary output circuitry that actuates fire suppression systems, fire dampers, fire door holders, and ventilation equipment is not provided. However, TVA will check these supplemental circuits every 18 months for operability. Supervision is Class A in the detection and data transmission circuits and Class B in the local audible alarm circuits. A wiring fault in the supervised circuits results in an audible and visual trouble indication at both the local and control locations. The system is capable of processing and displaying multiple alarm and trouble conditions.

A second CPU is provided in the main control room as an installed spare. Upon failure of the primary processor, the spare can be connected to the system by jumper cables in less than 30 minutes.

The fire detection system is powered from a single 120V ac distribution panel as shown in Figure 7-2. The panel is provided with a manual transfer switch to allow normal or alternate power feed from 480V ac control and auxiliary building ventilation boards 1A1-A and 2A1-A, respectively. Both ventilation boards are automatically connected after 10 seconds to the emergency diesel generators on loss of offsite power. The system's power supply complies with the applicable guidelines in Regulatory Guides 1.6 and 1.32 and partially complies with Regulatory Guide 1.75 as discussed in FSAR section 8.3. The fire protection power distribution panel will be electrically supervised to provide an alarm in the main control room upon loss of power.

The momentary loss of power to the CPU resulting from the transfer to the diesel generators will cause a loss of the CRT display in the main control room. However, when power is restored, all persisting alarm and trouble conditions will be redisplayed.

Fire detection system components are located as identified in Table 7.1. Refer to compartmentation drawing SK-1004 for definition of the column lines.

The Sequoyah Nuclear Plant Technical Specifications will reflect the requirement for six month surveillance testing of detection circuits from the local panel to the actuated devices, i.e., fire dampers, fire door holders, ventilation equipment or preaction valves as agreed in the resolution of open item 7.a during the meeting of February 12, 1979.




FIGURE 7-1




FIGURE 7-2

TABLE 7.1

<u>Component</u>	<u>Building</u>	<u>Elevation</u>	<u>Column</u>	<u>Room Name</u>
Central processor unit and CRT display	Control	732.0	p,C7	Main control room
Line printer	Control	685.0	p,C10	U2 aux. inst. room
Local control panels	----- Located throughout plant -----			
Power distribution panel	Auxiliary	734.0	t,A8	6.9 kV shutdown board room B
480V cont. and aux. bldg. vent board 1A1-A	Auxiliary	734.0	t,A3	480V shutdown board room 1A2-A
Transformer 1	Auxiliary	734.0	u,A2	480V shutdown board room 1A1-A
480V cont. and aux. bldg. vent board 2A1-A	Auxiliary	734.0	r,A13	480V shutdown board room 2A2-A
Transformer 2	Auxiliary	734.0	r,A15	480V shutdown board room 2A1-A

8. Item E.2.c., Fire Protection Water Supply System - In Section E.2.c you state that the fire pumps at the Sequoyah Nuclear Plant are electric motor driven and are connectable to the emergency diesel generators. Confirm that these pump motors will be connected automatically to the 1E bus, upon loss of offsite power. The required alarms and status are annunciated in the main control room. It is not clear that the pump monitoring system meets the guidelines of BTP 9.5-1, Appendix A. Therefore, verify that the fire pumps are individually monitored and the monitoring circuits are electrically supervised. Alarms indicating pump running, driver availability, or failure to start, should be provided in the control room.

TVA Response

The electric motor-driven fire pump motors are powered by the 480V shutdown boards. Upon loss of offsite power, these boards are automatically loaded on the diesels. Two minutes after the power loss, the fire pumps are in turn loaded on the 480V shutdown boards.

Supervised alarm circuits will be provided for loss of line power and motor running condition for the fire pumps and will alarm and annunciate in the MCR.

The fire pumps are not designed or installed in accordance with NFPA 20. The pumps are vertical, submersible, turbine-type, electric motor-driven units that meet ASME Section III and Siesmic Category I requirements.

9. Item E.3, Water Sprinklers and Hose Standpipe Systems

- A. Item (a). You state that the fire protection system or plant equipment will be so designed such that a pipe break or a single inadvertent actuation of the fire protection will not prevent the functioning of both trains of the safety-related system. This design arrangement is unacceptable. It is our position that the safety related systems or equipment should be protected against moderate energy line cracks in accordance with BTP APCSB 3-1, by water shields or baffles.
- B. Item (d). Verify that the hose station will be able to reach any locations that contain or present a fire hazard to safety related equipment with at least one hose not over 100' long.
- C. Your submittal does not indicate the hourly fire rating of the protected openings in the stairwell. Indicate their hourly fire ratings.
- D. Throughout your fire hazards analysis, you state that sprinkler systems will be installed in various areas of the plant. We observed during our site visit that the sprinkler systems were installed at the ceiling level. However, no provisions were made to locate sprinkler heads clear of overhead obstructions, especially in areas housing the auxiliary feed-water pumps and the component cooling water pumps. It is our position that where such systems are to be installed that additional sprinkler heads be provided below any obstructions to obtain minimum interference to discharge patterns of the sprinkler heads on the floor below.

TVA Response

- A. The Sequoyah fire protection systems in safety-related areas are seismically qualified, preaction sprinkler systems. They are charged with water only when cross-zoned detectors (smoke and smoke; smoke and thermal) are actuated. Areas provided with cross-zoned smoke and thermal detection that actuate preaction sprinkler systems are identified in Table 9.1. Due to the inherent tendency of smoke detectors to drift toward their alarm setpoint with time, cross-zoning provides an additional margin of safety against spurious application of water to safety-related equipment. In addition, low pressure air supervision of the sprinkler system is provided in areas containing sensitive electrical equipment. If system integrity is not maintained, the supervision air pressure is lost and annunciation is provided in the MCR. Water shields are also provided in areas where actuation of the suppression systems could unacceptably impair safety-related equipment. This design philosophy complies fully with BTP APCSB 3-1, Sections B.1 and B.3a which require protection of essential systems and components against postulated piping failures in high or moderate energy fluid systems that operate during normal plant conditions.

In general, the cross-zoning technique utilizes two detectors in the same area that a single detector would normally occupy if located in accordance with UL spacing guidelines. Based on this

detection zone overlap, TVA is satisfied that preaction valve actuation will be accomplished prior to the fusing of any sprinkler heads.

- B. All areas of safety-related structures are within reach of fire hose stations equipped with 100' of hose.
- C. The protected stairwells in the control building have equivalent 1-1/2 hour rated reinforced concrete and concrete block construction. The plaster partition assemblies above the fire doors have a fire resistive rating at least equivalent to that assigned the wall construction.

Fire barrier seals around pipe penetrations in the stairwells are in accordance with the designs discussed in 3.B. There are no cable tray or ducts penetrating the stairwells.

- D. Additional sprinkler heads shall be provided or existing heads relocated in order to clear overhead obstructions and obtain minimum interference patterns where possible.

TABLE 9.1

CROSS-ZONED SMOKE AND THERMAL DETECTORS

The following areas are provided with cross-zoned smoke and thermal detection that actuates the preaction sprinkler systems. The thermal detector's setpoint temperature is 135° F. Refer to the compartmentation drawings SK-1000 series for room locations.

<u>Protected Area</u>	<u>Building</u>	<u>Elevation</u>	<u>Room No</u>
Auxiliary Feedwater Pump 1A-A Rm	Auxiliary	669.0	A6
Charging Pump 1A-A Rm	Auxiliary	669.0	A9
Charging Pump 1B-B Rm	Auxiliary	669.0	A10
Charging Pump 1C Rm	Auxiliary	669.0	A11
Safety Injection Pump 1B-B Rm	Auxiliary	669.0	A12
Safety Injection Pump 1A-A Rm	Auxiliary	669.0	A13
Safety Injection Pump 2A-A Rm	Auxiliary	669.0	A19
Safety Injection Pump 2B-B Rm	Auxiliary	669.0	A20
Charging Pump 2C Rm	Auxiliary	669.0	A21
Charging Pump 2B-B Rm	Auxiliary	669.0	A22
Charging Pump 2A-A Rm	Auxiliary	669.0	A23
Auxiliary Feedwater Pump 2A-A Rm	Auxiliary	669.0	A26
PSO Engineers' Shop	Control	732.0	C16
Record Storage Rm	Control	732.0	C14
Shift Engineers' Office	Control	732.0	C11
Chart Storage	Control	732.0	C10
Instrument Calibration Rm	Control	732.0	C9
Locker Rm	Control	732.0	C6
Toilet	Control	732.0	C5
Kitchen Area	Control	732.0	C4
Mechanical Equipment Rm	Control	669.0	C10
250V Battery Rm No. 2	Control	669.0	C6
250V Battery Rm No. 1	Control	669.0	C3
Mechanical Equipment Room	Control	669.0	C1

10. Safety related pumps of both trains for both Unit 1 and Unit 2 are contained in the Auxiliary Building elevation 653' and 660' area. Each train is in its own room; however, no fire rated door separates the room from the corridor and adjacent pump rooms. It is our position that each room be provided with a 3-hr. fire rated door, mounted in an approved fire rated frame to properly protect the room. In lieu of fire rated doors, provide a wet pipe sprinkler system to completely cover the corridor separating Unit No. 1 from Unit No. 2. The sprinkler system should alarm and annunciate in the control room.

TVA Response

Three-hour fire doors are provided for each of the eight openings from safety-related pump rooms. At the time of the NRC site visit, these doors had not been installed.

11. On elevation 690' of the auxiliary building at Al an.' U, all four power cables (both trains of both units) of the ERCW pump from the yard pump house come into a metal enclosure mounted on the concrete wall approximately 10 ft. above the floor. Each cable within the junction box is separated by a metal baffle. From the enclosure, the cables are run in conduits and go up the wall and through the ceiling. We were informed that at the ceiling, all the conduits are supposed to be buried in concrete back to the switchgear room of the various trains and units.

It is our position that:

- A. Verify that these conduits are actually buried back to their switchgear rooms from the ceiling level above the junction box.
- B. A 3-hr. fire rated barrier be installed around the metal enclosure as well as around the conduits located on the wall above the enclosure and terminating at the ceiling to protect against potential exposure fires. In addition, we are concerned that the metal enclosure and metal baffles are inadequate to prevent an electrically initiated fire that may damage all power cabling in the enclosure. Revise your design of the metal enclosure and metal baffles to protect the cables such that an electrically initiated fire will cause damage to no more than one power train.

TVA Response

- A. The conduits are not buried back to their switchgear rooms from the ceiling level above the junction box. The conduits ascend from the junction box to elevation 734.0 embedded only as they penetrate floor slabs. On elevation 734.0 the conduits terminate in cable trays that extend to the switchgear.
- B. In lieu of the 3-hour fire rated barriers, TVA will provide a 1" mineral wool barrier between the redundant power cables in the junction box as protection against an electrically initiated fire. The outside of the junction box and the four redundant power conduits routed between elevation 690' and 734' will be protected by 1-1/2-hour fire rated barriers utilizing a UL-approved configuration.

As indicated in the response to position 13.C, TVA will provide sprinkler coverage for the area around the component cooling water pumps and the ERCW pump cable junction box.

12. During our site visit we noticed numerous places where redundant safety related cable trays as well as conduits were in close proximity to each other. This was noticed on almost all elevations. Some of these locations are to have flamemastic and preaction sprinkler systems installed at the interaction. At the time of the site visit the function of these various cables-conduit could not be determined at these interactions.

It is our position that:

- A. Identify all such interactions in the areas of both Units 1 and 2 where the redundant safety related trains are within 20 ft. of each other. Also, the consequence of electrically initiated or exposure fires should be evaluated with regard to plant shutdown capability (see item 1).
- B. For those areas indicated in item (A) above, where a fire can affect the plant shutdown capability, an area automatic sprinkler system should be provided to afford protection against exposure fires. Also, a 1/2-hr. fire rated barrier such as 1" of mineral wool should be provided to separate one safety related train from the other or from a common exposure fire source. The sprinkler system should alarm and annunciate in the control room.

TVA Response

- A. The criteria for the separation of Class 1E equipment and circuits basically meet RG 1.75, revision 0, although it was issued after the Sequoyah design was complete. The criteria used in the design for the separation of redundant cable trays at Sequoyah in general plant areas are as follows. Redundant cable trays are separated a minimum of 3 feet horizontally, and a minimum of 5 feet vertically, except where trays containing cables of different divisions of separation cross. Where redundant cable trays cross, there is a minimum vertical separation of 12 inches (tray top of lower tray to tray bottom of upper tray) with the bottom tray covered with a solid steel cover and the top tray provided with a solid steel bottom for minimum distance of 3 feet on each side of the tray crossing.

In the auxiliary building, each cable tray tier may contain a combination of nondivisional trays together with trays of only one division. As a result of the reevaluation of the Sequoyah fire protection program, it was determined that in most fire cells, containing redundant division of systems, the installed combustibles consisted of cable insulation and jacket materials. New criteria were developed to identify and protect redundant circuits, whether installed in conduits and/or cable trays within a 5-foot radius of the point of interaction. This distance was established as the most credible zone of influence for an electrically initiated fire.

Following this 5-foot criterion, approximately 50 percent of the cable trays in the auxiliary building were identified as needing protection. The areas of divisional interactions are shown as hatched cable trays in figures 12-1 through 12-5. The hatched trays represent both tray-to-tray and tray-to-conduit divisional interactions. In each reactor building annulus there are 15 divisional interactions, in the cable spreading room there are 44 divisional interactions, and in each auxiliary instrument room there are 4 divisional interactions.

Following a 20-foot criterion, between 75 and 80 percent of the trays will be involved in divisional interactions within the reactor building annulus, the auxiliary building, the cable spreading room, and the auxiliary instrument room. For example, in units 1 and 2 areas of the auxiliary building, the divisional interactions of redundant safety-related trains that are within 20 feet of each other are shown shaded in figures 12-6 through 12-10.




The present design requires that the exposed surfaces of cables in the identified trays (both divisional and nondivisional) be coated with a flame-retardant material such as Flamemastic 77 for a 5-foot radius from the point of interaction (or to the nearest wall, floor, or ceiling). In addition, fixed suppression systems are provided for these interactions.

TVA has evaluated the consequences of fires with regard to plant shutdown capability. Electrically initiated fires are judged to be acceptable based on the results of tests conducted at Sandia Laboratories and the commitment to add a fire-retardant coating to cables as discussed in the response to question 4. The tests demonstrate that a fire initiated in a shorted cable will not propagate to cables in adjacent trays and that cable coatings are effective in restricting fire propagation. The consequences of exposure fires are discussed in the response to question 1.


- B. TVA has provided automatic sprinkler systems for the protection of redundant circuits at interaction points based on the 5-foot criterion. Automatic sprinkler coverage is also provided for areas containing fixed combustibles which could impose an exposure fire threat to equipment, components, or circuits necessary to achieve safe plant shutdown. As indicated in the response to question 9.D, additional sprinkler heads shall be provided or existing heads relocated in order to clear overhead obstructions and obtain minimum interference patterns where possible, and additional suppression systems will be provided as described in the responses to questions 1 and 13.

TVA's present design philosophy provides for the alarm and annunciation in the main control room of the operation of all fixed suppression systems.

See the response to question 1 for a discussion of the measures proposed for protection of redundant safety-related circuits required for safe shutdown.






SECTION B-B




FIELD TO FABRICATE A 6" WIDE BY 4" DEEP GUTTER FROM 16 GAUGE GALV. STL AND INSTALL BETWEEN TRAYS PL-A AND PH-A BETWEEN REAC. MOV. BD. 2A-1 AND U-LINE WALL. ALSO, PAINT TRAY DESIGNATION ON BOTH SIDES OF GUTTER REDUCING LETTER SIZE TO 2" IF NECESSARY.

DETAIL A13
(45N880-13)





SECTION A-A



DETAIL B13 NOT TO SCALE

PLAN EL 749.0

FIGURE 12-1











FIGURE 12-2



ECN
1940

REACTOR BUILDING UNIT 2

Cont'd on 45N82-1
MK 24
(45N880-23)



REACTOR BUILDING UNIT 2

PIPE TUNNEL
E1 694 0






FIGURE 12-4



REACTOR BUILDING UNIT 2





FIGURE 12-5



ASSUMED NORTH

480V SHUTDOWN BLDG TRANSFORMERS

480V SHUTDOWN BLDG EMERGENCY TRANSFORMERS


480V AUXILIARY BLDG COMMON BLDG TRANSFORMER

480V SHUTDOWN BLDG TRANSFORMER

BATTERY ROOM II
480V REACTOR

BATTERY ROOM III

SECTION B-B




*FIELD TO FABRICATE A 6" WIDE BY 4" DEEP GUTTER FROM 1/8 GAUGE GALV. STEEL AND INSTALL BETWEEN TRAYS PL-A AND PH-A BETWEEN REAC. MOV. BD 2A1-A AND U-LINE WALL. ALSO, PRINT TRAY DESIGNATION ON BOTH SIDES OF GUTTER REDUCING LETTER SIZE TO 2" IF NECESSARY.


DETAIL A13
(45N880-13)

CONTD. ON 45N879-1

REACTOR BUILDING UNIT 2



MK 18 (45N880-24)
D25
MK 18, 14 (45N880-24)
1A, B
1V
1W
1X
1Y
1Z



Z60(4)
EL 771'-8"; HV
EL 770'-8"; HW
EL 769'-8"; HX
EL 768'-8"; HY
Z60(5)
EL 775'-0"
EL 774'-0"
EL 773'-0"

EL 774'-0"; HN-B
EL 773'-0"; HO-B
END TRAYS

EL 771'-8"; HV
EL 770'-8"; HW
EL 769'-8"; HX
EL 768'-8"; HY
END TRAYS

EL 774'-0"
EL 773'-0"
END TRAYS

EL 775'-0"; AR-B
EL 774'-0"; AH-B
EL 773'-0"; AO-B
EL 772'-8"
EL 771'-8"; AV
EL 770'-8"; AW
EL 769'-8"; AX
EL 768'-8"; AY
EL 775'-0"; AS-B
EL 774'-0"; AP-B
EL 773'-0"; AR-B

EL 774'-2"
EL 773'-5"
EL 772'-8"

EL 774'-2"
EL 773'-5"
EL 772'-8"
EL 771'-8"
EL 770'-8"
EL 769'-8"
EL 768'-8"

EL 775'-0"; AR-B
EL 774'-0"; AH-B
EL 773'-0"; AO-B
EL 772'-8"
EL 771'-8"; AV
EL 770'-8"; AW
EL 769'-8"; AX
EL 768'-8"; AY
EL 775'-0"; AS-B
EL 774'-0"; AP-B
EL 773'-0"; AR-B

EL 774'-2"
EL 773'-5"
EL 772'-8"

EL 774'-2"
EL 773'-5"
EL 772'-8"
EL 771'-8"
EL 770'-8"
EL 769'-8"
EL 768'-8"

EL 775'-0"; AR-B
EL 774'-0"; AH-B
EL 773'-0"; AO-B
EL 772'-8"
EL 771'-8"; AV
EL 770'-8"; AW
EL 769'-8"; AX
EL 768'-8"; AY
EL 775'-0"; AS-B
EL 774'-0"; AP-B
EL 773'-0"; AR-B

EL 774'-2"
EL 773'-5"
EL 772'-8"

EL 774'-2"
EL 773'-5"
EL 772'-8"
EL 771'-8"
EL 770'-8"
EL 769'-8"
EL 768'-8"

EL 775'-0"; AR-B
EL 774'-0"; AH-B
EL 773'-0"; AO-B
EL 772'-8"
EL 771'-8"; AV
EL 770'-8"; AW
EL 769'-8"; AX
EL 768'-8"; AY
EL 775'-0"; AS-B
EL 774'-0"; AP-B
EL 773'-0"; AR-B

EL 774'-2"
EL 773'-5"
EL 772'-8"

EL 774'-2"
EL 773'-5"
EL 772'-8"
EL 771'-8"
EL 770'-8"
EL 769'-8"
EL 768'-8"

EL 775'-0"; AR-B
EL 774'-0"; AH-B
EL 773'-0"; AO-B
EL 772'-8"
EL 771'-8"; AV
EL 770'-8"; AW
EL 769'-8"; AX
EL 768'-8"; AY
EL 775'-0"; AS-B
EL 774'-0"; AP-B
EL 773'-0"; AR-B






FIGURE 12-6










FIGURE 12-7








FIGURE 12-8



REACTOR BUILDING UNIT 2

PIPE TUNNEL
E1 694 0

PLAN-EL 690.0







FIGURE 12-9



PLAN-EL 669.0




FIGURE 12-10

13. On elevation 690' of the auxiliary building at coordinate A-3 and T, all five (two from each unit and one swing) component cooling water pumps are located together. Adjacent to these safety related pumps are the two motor driven auxiliary feedwater pumps (both trains), of Unit 1, which are also safety related. Both Unit No. 2 auxiliary feedwater pumps are located approximately 125' away down the corridor at coordinates A-12 and S. Power operated control valves for the component cooling water (CCW) pumps are located immediately above the CCW pumps on an open grating mezzanine. Various safety related cable trays are also located in the area. A preaction sprinkler system is proposed for the ceiling level only and would offer very little protection against an exposure fire due to the many obstructions between the ceiling level sprinkler and the floor below.

It is our position that:

- A. A half hour fire rated barrier be provided between the redundant auxiliary feedwater pumps and extend up to the mezzanine above these pumps. At present, a metal decking barrier is used to partially separate each auxiliary feedwater pumps. This applies to both Unit 1 and 2 pumps.
- B. Provide automatic sprinkler protection under the partition above the auxiliary feedwater pumps of both Unit 1 and 2. Activation of the system should alarm and annunciate in the control room.
- C. Provide automatic sprinklers over all five component cooling water pumps under the mezzanine above them.
- D. Provide a 1/2-hr. fire rated barrier separating each component cooling water pump from each other. The barrier should extend to the underside of the mezzanine above. Also provide a 1/2-hr fire rated barrier for the mezzanine floor above these pumps. The 1/2-hr. fire rating should protect against a fire from either side of the barrier.
- E. Provide a 1/2-hr. fire rated barrier protection (1" mineral wool or equivalent) for the control and power supplies to the various valves on the mezzanine level above the component cooling water pumps.
- F. Provide additional smoke detection throughout the area for early detection. Detection should be tied into the existing fire alarm system and alarm and annunciate in the control room.
- G. Verify that the existing hose station location will be sufficient with the above fire rated barriers in place for protection of all pumps and valves.

TVA Response

- A. The auxiliary feedwater system contains two motor-driven pumps (those described in the above question) and a steam turbine-driven pump (located on elevation 669). Since any one of these pumps has sufficient capacity to establish and maintain a safe shutdown, the loss of both motor-driven pumps to a fire is an acceptable event. Hence, fire rated barriers between pumps are not required. See discussion of steam generator inventory control in response to question 1.
- B. Automatic sprinkler protection will be provided under the pipe break barrier for the units 1 and 2 motor-driven auxiliary feedwater pumps.
- C. Automatic sprinkler coverage will be provided under the mezzanine for all five component cooling water pumps. Sprinkler heads will be a fast-response type and tested according to UL 199. Heat collectors will be provided for each sprinkler head. Sufficient heads will be provided to cover the entire general area at the mezzanine level with the maximum distance between heads of eight feet.
- D. A single fire barrier will be provided between train A and train B component cooling water pumps. The fire barrier will extend approximately three feet above the highest point on the pumps and have a minimum 1/2-hour fire resistance rating.
- E. Control and power supply cables that are required for safe shutdown and that are located on the mezzanine level above the component cooling water pumps will be protected as discussed in the response to question 1.
- F. Additional smoke detection will be provided to actuate the proposed sprinkler systems and to ensure early warning of a fire. Detection circuits will be Class A supervised in accordance with NFPA 72D.
- G. Existing fire hose capability is sufficient to reach all equipment within the area of the component cooling water pumps and motor-driven auxiliary feedwater pumps with no more than 100 feet of hose.

14. The emergency raw cooling water pump house is separated into three compartments with train A of both units located on either end and train B of both units located together in the middle compartment. It is our position that the following be provided for the ERCW pump house.
 - A. Provide a 3 hr. fire rated door to separate the center compartment from the south compartment. The door should be alarmed and annunciated in the control room.
 - B. Provide a 1/2-hr. fire rated partial barrier to separate the two B trains in the center compartment. Barriers should be at least 6" high.

TVA Response

- A. A 3-hour rated fire door is provided between the center and south compartments of the intake pumping station containing the ERCW pumps. At the time of the NRC site visit, the door had not been installed.

The door shall be locked in its normally closed position with the keys administratively controlled. Therefore, alarm and annunciation of the door is not necessary.

- B. It is TVA's position that the present compartmentation in the CCW intake pumping station is adequate based on the following discussion.

The NRC's understanding of the ERCW system appears to be incomplete. Sequoyah's ERCW system is a two-train, nonunitized system. Each of the two trains contains four 50-percent capacity pumps in the CCW intake pumping station and four 50-percent capacity pumps in the ERCW pumping station. Figure 14.1 is a single-line drawing of the two supply headers and the pumping stations. Note that in each pumping station, all pumps of a given train feed a common header. For distribution purposes, two headers do branch off of each common header, both of these are required for operation of either unit (with single failure capability) as each serves not only unit loads but also essential common plant loads.

For unit one operation, all ERCW loads will be supplied by four pumps located at the CCW intake pumping station. The other four pumps at this station will never be used. When construction of the new ERCW pumping station is completed, some time before unit two operation, all ERCW pumps at the CCW intake pumping station will be abandoned. See Figures 14.1 and 14.2 to identify which pumps will be in service and to which diesel they may be loaded. Figure 14.3 depicts the pump and header arrangement for the new ERCW pumping station.

Sequoyah's two-train, nonunitized system is more fully described in Section 9.2.2 of the FSAR (see Figures 9.2-11, 9.2-15a, 9.2-20, and 9.2-20a). It has been reviewed and found to be acceptable by the NRC's APCS Branch.

Additionally, the two required B train pumps in the central compartment of the CCW intake pumping station are located approximately 30 feet apart. This special separation precludes the need for any barrier.

Thermal spot detectors and heat collectors will be provided immediately above each ERCW pump in both the CCW intake pumping station and the ERCW pumping station to provide early warning fire detection capability.





FIGURE 14.1
 ERCW SUPPLY
 HEADER ARRANGEMENT
 SEQUOYAH NUCLEAR PLANT




X These pumps are not and will not ever be wired up.

○ These pumps will be disconnected prior to startup of unit 2. Number in circle is diesel pump assigned to.

Figure 14.2

Condenser Circulating Water Intake Pumping Station
Sequoyah Nuclear Plant



○ NUMBER IS PUMPS
DIESEL ASSIGNMENT

Figure 14.3

WATER SUPPLY UNITS 1&2
EMCV PUMPING STATION
SECOYAH NUCLEAR PLANT
TENNESSEE VALLEY AUTHORITY

15. All four wood and PVC cooling towers for the Auxiliary Essential Raw Cooling Water System are located within 50 ft. of the emergency diesel generator building and approximately within 50 ft. from the two large diesel fuel oil storage tanks (also located approximately within 50 ft. from the emergency diesel generator building and approximately 50 ft. from the AERCW pumps). These cooling towers are not protected by a deluge system. We are concerned that a fire in the cooling towers can threaten the diesel generator building, the diesel storage tanks, and the auxiliary essential raw cooling water pumps. It is our position that the cooling towers be protected in accordance with Section D.18 of Appendix A, i.e., providing deluge system, hydrants, and hose stations.

TVA Response

TVA is not providing a deluge system or hose stations for the four auxiliary essential raw cooling water (AERCW) cooling towers for the following reasons:

- A. The AERCW system will also serve as interim backup to the ERCW system until the permanent modifications discussed the response to questions 1 (table 1.4) for protection of circuits within the ERCW junction box on auxiliary building floor El. 690.0 and conduits exiting the junction box to El. 734.0 are completed and until completion of the new ERCW pumping station discussed in the response to question 14. The AERCW system (pumps and cooling towers) is required to shutdown the plant only upon loss of Chicamauga Dam (the downstream dam). The safety feature will be transferred to the new ERCW station when it is completed (prior to unit 2 operation).
- B. The diesel generator building is about 50 feet from the closest tower (the distances of the other towers are 120, 200, and 280 feet). This distance is great enough so that an AERCW cooling tower fire would not constitute a hazard to this structure. The diesel generator building is a seismic 1A structure, designed to be tornado and missile resistant and its exterior walls are equivalent to at least a 3-hour rated fire barrier.
- C. The yard storage fuel oil tanks are 70 feet away from the closest cooling tower (distances to remaining towers are 75, 120, and 180 feet). This separation distance is sufficient such that an AERCW cooling tower fire would not constitute an exposure hazard to these tanks (see table 4-4, NFPA 30). The fuel oil tanks are diked and yard hydrant and hose/equipment capabilities are provided for the entire area. Further, the yard fuel oil tanks serve no safety function. The safety-related diesel seven-day tanks are embedded in concrete under the diesel generator building.
- D. Salient features of the cooling tower design are as follows:
- a. The use of fire retardant, corrugated fiberglass casing and louvers.
 - b. Fire retardant glass reinforced polyester fan cylinder.
 - c. PVC fill and eliminators with a flame spread rating of 25 or less.

16. It is our position that when the CO₂ total flooding system is locked out locally in any emergency diesel generator room that the operator in the control room receives an alarm and annunciator indicating that the system is inoperative.

TVA Response

A common MCR alarm and annunciation will be provided for the train A Emergency Diesel Generator Room and 480V Board Room CO₂ systems to indicate when any system is locked out locally. Identical alarm and annunciation capability will be provided for the train B Emergency Diesel Generator Room and 480V Board Room CO₂ systems.

17. A. The corridor outside each diesel generator room of the emergency diesel generator building has a preaction sprinkler system. Power conduits from each diesel run up the west wall of the corridor. A concrete barrier extending out approximately 3 ft. from the west wall separates the redundant power trains. Unit No. 1 power conduit is located at one end of the corridor and Unit No. 2 at the opposite end. It is our position that a 1-1/2 hr. fire rated barrier separate each redundant train of each unit from each other in the corridor for protection against an exposure fire in the event of failure of the sprinkler system.

It is also our position that the doors leading to each emergency diesel generator from the corridor be kept in the closed position (at all times) and alarmed and annunciated in the control room.

- B. Also verify that a fire in any one of the four switchgear rooms above the corridor of the diesel generator building, elevation 740 ft., will not involve cables and/or conduit for any other safety related train or unit.

TVA Response

- A. The NRC understanding of the conduit assignment is in error. Unit 1 and unit 2 train A power conduits are located on the north end of the corridor, and unit 1 and unit 2 train B conduits are located on the south end of the corridor. There is approximately 50 feet separation between train A and train B conduits. TVA considers the spacial separation to be adequate for fixed and transient fire hazards located in the area.

Lubricating oil with a flash point of 465⁰ F will be transported between the lube oil storage room and the diesel generator rooms in 55-gallon drums. If the contents of one or more drums were spilled in the corridor, the oil would run to the center of the corridor and out of the building through a 24-inch drain line. In the unlikely event that this oil were to ignite, the fire could affect the conduits of one train only, approaching the conduits of the second train by no closer than 25 feet.

A flammable liquid fire in the lube oil storage room, fuel oil transfer pump room, or any diesel generator room would present minimum danger to the conduits since each room is provided with a carbon dioxide suppression system, 3-hour fire rated compartmentation, floor drains, and curbs across the door's opening into the corridor. The hazard from the fuel oil transfer pump room is further minimized by the transfer pump's local control station which must be manned continuously when the pump is in service.

Normally closed, 3-hour rated fire doors will be provided for the opening leading to each emergency diesel generator room from the corridor. The sliding fire doors presently installed will be removed.

It is TVA's position that the fire doors require no supervision.

- B. There are no cable trays and/or conduit that penetrate switchgear rooms of opposite divisions.

18. We were informed at the time of the site visit that an alternative means of achieving cold shutdown if both redundant trains of conduit-cable trays (of both units) are lost due to a fire in the control room, or cable spreading room or remote shutdown panel room. In order to evaluate this alternative, we require a description of how the alternate shutdown method for each area will be carried out, system modifications associated with the shutdown method, and confirmation that written procedures have been established for immediate use by responsible individuals. The staff position with respect to providing alternate or dedicated shutdown methods for fire protection is stated in Enclosure 1. Provide information that demonstrates that the requirements of Enclosure 1 will be satisfied.

TVA Response

Emergency Operating Instruction EOI-7, Control Room Inaccessibility, provides for safe plant shutdown from the auxiliary control room should the main control room become inaccessible due to a fire (or for other reasons such as toxic gas, etc.) in either it, the spreading room, or Auxiliary Instrument Room. This instruction provides a discussion of symptoms, automatic actions, immediate operator action, subsequent operator action, and recovery for: (a) control room inaccessibility at power or hot standby; (b) control room inaccessibility at hot shutdown, cold shutdown, or refueling shutdown; (c) hot standby to cold shutdown in the auxiliary control mode; and (d) return to main control room operation from test of EOI-7. EOI-7 and all EOI's have been submitted to NRC Region 2 Office of Inspection and Enforcement for review.

The auxiliary control room has been divided into five independent compartments (a central control area and four transfer switch rooms) which are separated from each other by 1-1/2 hour fire rated barriers. The central control area is the only room where a fire could affect both safety trains. Panels and cables in the central area are normally inactive and their loss would have no effect upon plant control. A fire in one of the other four rooms could affect only a single train and would not prevent safe shutdown from the main control room.

TVA will comply fully with all Staff positions in enclosure 1. Compliance with Sections 1.1 through 1.7 will be provided by dedicated shutdown methods or repair procedure: for fires located in any area of the plant except the Main Control Room, the Cable Spreading Room, or the Auxiliary Instrument Rooms. Compliance for these areas is provided by alternate shutdown methods and EOI-7. Fire protection equipment and features will be provided that will meet the requirements of Sections 2.1 and 2.2.

Standard Operating Instruction SOI 67.2 has been written to incorporate procedures for placing the AERCW system into operation in the event of loss of normal ERCW system function. These procedures satisfy the requirements for interim protective measures specified in section 2.3.

19. It is our position that the ventilation system of each safety-related battery room be alarmed and annunciated in the control room upon failure of such systems. Confirm that you will meet this position.

TVA Response

Redundant ventilation systems are provided for each safety-related battery room. Failure of one system results in an alarm and annunciation in the main control room and the automatic starting of the second system.

20. Control Room Complex

- A. Provide the flamespread, smoke developed, and fuel contributed test results as per E-84 of the dropped plastic ceiling in the control room. We were informed at the time of the site visit that this ceiling was a UL-approved dropout ceiling. Verify that the ceiling material meets the guidelines of Section C.4.a(4) of Revision 1 to BTP 9.5-1 or replace it with a ceiling material that does.
- B. It is our position that you provide a 3-hour fire rated barrier at T5 and T12 on the ends of the control room. Present doors are not labeled as well as openings are above the suspended ceiling into the corridor. Verify that the doors are of 3-hour fire rated construction and that 3-hour fire doors/dampers are used in all ventilation duct penetrations where they penetrate the 3-hour barrier.
- C. The main safety-related consoles actually extend through the floor three to four feet into the cable spreading room. These are completely enclosed with metal walls and floor. A 3-hour fire rated coating is to be applied to the sides and bottom of these consoles from the cable spreading room side only. There is no fire rating from the control room side. The consoles are congested with cables (all non-IEEE-383 rated) and would make manual firefighting difficult.

It is our position that taking the above factors into consideration and providing a defense-in-depth protection that an automatic or local manual operated gas suppression system (either high or low pressure CO₂ or halon) be provided for protection of these consoles.

- D. Verify that the sprinkler system for protection in the records storage area conforms to NFPA 13. It was noted that the riser nipples appear to be 1/2-inch pipe, which is not permitted by NFPA 13. Also, verify that the wall separating the records storage room from the relay room is of 3-hour fire rated construction, including protection of all duct penetrations.

TVA Response

- A. The dropped plastic ceiling in the main control room is constructed of molded prismatic acrylic plastic (plexiglas G) panels. These panels have not been tested under ASTM E84 test and are not listed by UL in the Building Materials Directory.

The following test results are based on tests conducted on plexiglas G according to the designated standards:

1. Flammability rate of 1.9 inches per minute in accordance with ASTM D 635.
2. Minimum self-ignition temperature of 450 C in accordance with ASTM D 1929-68.

3. Maximum smoke density of 10 in accordance with ASTM D 2843-70.
4. Deflection temperature of 75 C in accordance with ASTM D 648-56.
5. Plexiglas G is listed as a slow burning plastic material by UL as designated on UL cards MH4833A and 3, and Guide QLZQ2 dated March 18, 1971.

There are no safety-related equipment or cabling located above the dropped ceiling.

- B. The control room complex is separated from the other plant areas by minimum 3-hour fire rated construction. Within the complex, the peripheral rooms are generally separated from the main control room by 1-1/2-hour fire rated construction. One-and-one-half hour fire separation between the main control room and the remainder of the control room complex satisfies the requirements of section C.6.b of Regulatory Guide 1.120, Revision 1.

Refer to control building elevation 732.0 on compartmentation drawing SK-1007 for the layout of the control room complex.

The Sequoyah Nuclear Plant Fire Protection Program Reevaluation indicates that the fire load in the kitchen area exceeds the fire rating of its enclosure. This documentation is in error since it is based on the use of wooden cabinets which have been replaced by metal cabinets.

The mechanical equipment room on elevation 732.0 contains ventilation equipment that is essential for continued operation of the main control room. Therefore, the equipment room is considered an extension of the main control room fire cell. The two rooms are connected by ventilation ducts located above the suspended ceiling for the housekeeping area between columns C2 and C4. These ducts do not penetrate a fire barrier and are not provided with fire dampers. The housekeeping area is separated from the main control room, the mechanical equipment room, and the essential ventilation ducts for the main control room by 1-1/2-hour rated suspended ceilings and fire walls. The ventilation supply ducts penetrating the ceiling of the housekeeping area consisting of the shift engineer's office, instrument calibration shop, toilet and locker area, and the kitchen area are not provided with fire dampers at the ceiling penetration. Smoke dampers actuated by ionization smoke detectors are provided in the main supply trunk above the 1-1/2-hour fire rated ceiling for each of these areas. These dampers are UL listed and have a 1-1/2-hour fire rating. Upon detection of smoke in any of the housekeeping area rooms, the dampers in the main supply trunk to the affected room or rooms will be isolated thereby closing off supply air to the room or rooms without interrupting essential ventilation supply to the main control room.

Return air ducts from the chart storage room and instrument calibration room are also provided with a rated smoke detector actuated damper in the main return trunk above the suspended ceiling. Isolation of this damper will prevent smoke in these rooms from returning to the control room complex air-handling units thereby preventing contamination of the main control room.

Return ventilation from the shift engineer's office is through a louver in the wall to the corridor and back to the mechanical equipment room. The louver in the wall between the shift engineer's office and the corridor is provided with a 1-1/2-hour fire rated damper. A glass window between the shift engineer's office and the corridor is provided with a 1-1/2-hour rated roll-up fire shutter which is released by a fusible link.

Exhaust ventilation for the kitchen area and the toilet and locker rooms is through an exhaust fan located in the mechanical equipment room exhausting to the outside through the control building roof. No fire dampers are provided for these ducts.

Additional detector-actuated rated fire dampers are provided between the corridor and the mechanical equipment room to prevent smoke present in the corridor from entering the mechanical equipment room, and in the return air duct within the mechanical equipment room supplying 5200 cfm makeup air to the main control room air-handling units to prevent smoke present in the mechanical equipment room from entering the main control room.

The relay room is separated from the main control room by 1-1/2-hour rated fire wall that extends through the suspended ceilings. Refer to part D. of this response for a discussion of the separation between the relay room and the record storage room.

All fire barrier openings are provided with appropriately rated, UL-labeled assemblies except the previously mentioned housekeeping area ventilation supply ducts and door openings C55 and C56 (refer to drawing SK-1007) which contain special purpose security doors. These doors are made of bullet-resistant, heavy gauge steel and have not been tested by UL. However, the manufacturer has certified that the two doors are equivalent to UL-tested fire doors rated for three hours.

The above-described fire rated separation and smoke control provide adequate protection of the main control room from a fire originating in the peripheral areas of the control room complex. As described in the response to question 20.C, loss of the main control room is an acceptable event since reactor shutdown can be accomplished from the backup control room located in the auxiliary building.

- C. Automatic smoke detection is provided within the control room consoles to provide the earliest possible indication of a fire. Portable halon and pressurized water fire extinguishers are provided within the main control room and manual fire hose backup capability is provided immediately outside the room in accordance with the requirements of BTP 9.5-1, Appendix A.

The control room consoles contain only low-voltage cable, which minimizes the possibility of internally generated fires. The consoles are provided with full access doors on the rear of the panels which afford access to the lower recessed portions of the consoles with an extinguisher or fire hose nozzle.

With early detection capability in the control room consoles, a fire can be detected and extinguished in the incipient stage with minimal effect on equipment and electrical circuits.

Should a fire occur that develops beyond the capability of the extinguishing equipment, the main control room can be abandoned and reactor shutdown accomplished from the backup control room located in the auxiliary building.

It is TVA's position that a gaseous suppression system is not necessary for the main control room consoles. Access inside the consoles for manual firefighting would be no better for a gaseous hose system than for a water system. In addition, a gaseous system would not be particularly effective against a deep-seated fire which is the most likely fire condition to occur in the consoles. In order to make a gaseous system effective, excessive amounts of the gas would be required and could result in the unnecessary evacuation of the Main Control Room.

- D. The 1/2-inch riser nipples will be replaced with 1-inch nipples to conform to NFPA 13 in the records storage area. The wall separating the records storage room from the relay room is of 1-1/2-hour fire rated construction including 1-1/2-hour rated fire dampers in duct penetrations.

21. In the control building on elevation 685 ft. in both Units 1 and 2, auxiliary instrument rooms, both safety related divisions of one unit are located in each room. The consequence of electrically initiated or exposure fires should be evaluated with regard to plant shutdown capability. In the event that the plant shutdown capability cannot be maintained, an alternate shutdown method should be provided.

TVA Response

The auxiliary instrument room(s) located on elevation 685.0 of the control building are considered an extension of the main control room for the sake of the design of the backup control system. Hence, Sequoyah can establish and maintain a safe shutdown with a total loss of an auxiliary instrument room. See response to question 18.

22. In the cable spreading room of the control building, a preaction sprinkler system is used for protection with one layer of sprinklers located at the ceiling and an intermediate level located approximately half way between the floor and the ceiling. Provide heat collectors for the lower sprinkler heads to prevent ceiling level sprinklers from cold soldering the lower layer of sprinklers.

TVA Response

Heat collectors are provided for lower level sprinkler heads in the spreading room. At the time of the NRC site visit the heat collectors had not been installed.

23. Verify that the controllers of the four fire pumps are separated such that an exposure fire will not jeopardize more than one controller. List the location of each such controller.

TVA Response

The four fire pumps are controlled by switchgear located in separate 480V shutdown board rooms. Refer to compartmentation drawing SK-1004 and Table 23-1 for the switchgear locations.

Table 23-1

<u>Fire Pump</u>	<u>480V Shutdown Board</u>	<u>Room Number</u>
1A-A	1A2-A	734.0-A8
1B-B	1B2-B	734.0-A5
2A-A	2A2-B	734.0-A21
2B-B	2B2-B	734.0-A18

24. Verify that the main control valve of the CO₂ system used for protection of safety related equipment in various rooms is supervised and alarmed and annunciated in the control room.

TVA Response

The CO₂ system provides three valves between the storage tanks and the protected areas--a storage tank shutoff valve, a master selector valve, and a hazard selector valve. The tank shutoff valve is normally locked open and is administratively controlled. The master selector valve is a normally closed, pressure-operated piston valve controlled by a normally energized solenoid pilot valve. The hazard selector valve is identical to the master valve except it is controlled by a normally de-energized solenoid pilot valve. Upon system actuation, the master and hazard selector valves open releasing CO₂ to the hazard area. On loss of power the master selector valve fails open but the hazard selector valve remains closed.

Neither the master nor hazard selector valves can be supervised directly. However, TVA has provided an electrically supervised pressure switch downstream of the hazard selector valves to provide Main Control Room alarm and annunciation when CO₂ is being released in a hazard area.

All fire detection circuits associated with the CO₂ protected areas which transmit alarm signals to the Main Control Room are electrically supervised. However, the automatic actuation logic for the CO₂ systems is not supervised.

The CO₂ system meets the requirements of NFPA 12 and 72D for equipment supervision. It is TVA's position that the present design is adequate.

25. The information obtained as the result of the site visit was that the cable used at the Sequoyah Nuclear Plant will not pass the flame test in the current IEEE Standard 383. We were informed that some testing had been performed on this cable. Provide the information on the test used as well as the necessary data and criteria.

TVA Response

Table 25.1 contains the requested data for the purchased electrical cable. A description of the various flame tests is given in table 25.2.

TABLE 25.1

<u>TVA Cable Type</u> ¹	<u>Flame Tests</u>	<u>Cable Description</u>
WB, WC ²	IPCEA S-19-81	Single conductor, stranded, nylon jacket, polyethylene insulation
WV, WW	IEEE 383-1974 IPCEA S-19-81 IPCEA S-61-402 MILW-22759/16 UL-44	Multi-conductor, twisted, stranded, shielded, chlorosulfonated polyethylene jacket, crosslinked, polyethylene insulation
WX, WD ²	IPCEA S-19-81 IEEE 383-1974	Single conductor, PVC jacket, crosslinked polyethylene insulation
WT	IPCEA S-61-402	Telephone and coaxial cable
WE, WM	IPCEA S-19-81	Multi-conductor, singles - crosslinked polyethylene PVC jacket, PVC overall jacket
WP	IPCEA S-19-81 VTFT ³	Single conductor, asbestos braid jacket, silicone rubber insulation
WF, WG, WH	IPCEA S-19-81 IPCEA S-61-402	Multi-conductor, singles - polyethylene PVC jacket, overall PVC jacket
WR	VTFT	Multi-conductor, singles silicone rubber with glass braid, overall jacket asbestos braid
WU	IPCEA S-19-81 MILW 22759/16	Thermocouple cable

POOR ORIGINAL

1 The TVA cable type is actually a three letter designation. The third letter was dropped for table brevity as the cable description remains unchanged.

2 Single conductors smaller than No. 8 AWG are installed in conduits

3 TVA Vertical Tray Flame Test

TABLE 25.2

IEEE 383-1974

1. An eight foot cable tray was erected vertically and loaded with multiple length of cables arranged in a single layer.
2. The flame source was a ribbon gas burner placed very near the bottom of the vertical tray.
3. The criteria for failure was a propagating fire in the tray above the flame source for the total length of the tray.

UL-44

1. A three sided metal enclosure was erected vertically and loaded with a single conductor.
2. The flame source was a Turrill gas burner placed approximately near the center of the cable specimen.
3. The following is the criteria for failure:
 - A. A single conductor wire that flamed longer than 1 minute following any of the five 15-second applications of the flame.
 - B. The wire igniting any combustible material in its vicinity during, between, or after the various applications of the flame.
 - C. A damage of more than 25 percent of the indicator material during, between, or after the various applications of the flame.

TVA Vertical Tray Flame Test

1. An eight foot ladder type metal cable tray was erected vertically and loaded with several conductors from end to end on a single level.
2. A 120/240-volt ac test circuit was used to monitor circuit integrity during the test.
3. The flame source was crumpled burlap soaked with transformer insulating oil and placed several inches above the lower cable end.
4. The following was the criteria for failure:
 - A. Propagating fire results.
 - B. Circuit integrity loss in less than 15 seconds after ignition.
 - C. Excessive smoke appearing from cable.
 - D. Hot drippings from cable that may ignite fire in lower areas.

POOR ORIGINAL

TABLE 25.2 (Continued)

ICEA S-19-81/ICEA S-61-402 (Flame Resisting Test)

1. The flame resisting tests of the above are exactly the same as the previously described test of UL-44(1976) except part B of the failure criteria which is not adhered to.

MIIM-22759/16

1. A three-sided metal enclosure was erected vertically and loaded with a single wire.
2. The flame source was a Bunsen burner applied approximately near the center of the cable specimen.
3. The following is the criteria for failure:
 - A. A single conductor that flamed longer than five seconds after the flame is withdrawn.
 - B. A flame travel of more than 0.25 inch from flame mark on cable after the flame is removed.

26. Verify that hose houses equipped with hose and combination nozzle and other auxiliary equipment recommended in NFPA 24, "Outside Protection," is spaced not more than 1000 ft. apart.

TVA Response

Hose houses are spaced less than 1000 feet apart. However, they are not completely furnished with the equipment listed in NFPA 24. The following will be provided:

- 250 ft - 2-1/2" hose (on wheeled cart)
- 150 ft - 1-1/2" hose
- 2 - 2-1/2" variable fog nozzles
- 2 - 1-1/2" variable fog nozzles
- 1 - Fire axe
- 1 - Crow bar
- 2 - Hydrant wrenches
- 4 - Coupling spanners
- 2 - Hose and ladder straps
- 1 - 2-1/2" by 2-1/2" by 2-1/2" gated wye
- 1 - 2-1/2" by 1-1/2" by 1-1/2" gated wye
- 2 - 2-1/2" by 1-1/2" reducers
- 2 - 2-1/2" adapters (female to male)
- 2 - 1-1/2" adapters (female to male)
- 2 - 2-1/2" adapters (double male)
- 2 - 1-1/2" adapters (double male)
- 2 - 2-1/2" adapters (double female)
- 2 - 1-1/2" adapters (double female)
- 1 - Wheeled fire extinguisher (rated 320 B:C)
- 1 - Tee handle wrench
- 1 - Portable hand lantern (battery operated)

27. Provide a description on the operation and sequencing of the station fire pumps including isolation of the RWST valves, pushbutton stations located next to fire hose stations including supervision of the circuits and how they are connected to the fire alarm control panel as well as the fire pump controllers. Consideration should be given to failure of any of the above circuits and its affect on the fire protection system.

TVA Response

The four station fire pumps are capable of three modes of operation-- automatic, manual, and standby. In normal operation, two pumps are placed in automatic mode and two in standby. Upon receipt of an automatic start signal, one automatic pump starts immediately and the second starts three seconds later. If the fire protection system pressure cannot be maintained above 130 psig because of high system demand, the two standby pumps start ten seconds after the receipt of the initial signal. Manual operation of the pumps is also provided from the main control room and the individual pump switchgear.

The automatic start signals are originated in the circuits shown in block diagram form in Figure 27-1. Local control panels are provided for each fixed suppression system to actuate the system and to transmit a signal to start the fire pumps. These panels receive initiation inputs from the fire detection system and/or from handswitches located in the protected areas. Additional fire pump start signals are generated by pushbuttons near fire hose stations located throughout the plant. All the start signals are processed through the centralized automatic start logic located in three panels in the unit 1 and 2 auxiliary instrument rooms. From this logic, the start signals are transmitted simultaneously through separation relays to the individual pump switchgear. The pump sequencing is controlled by the switchgear as determined by the position of the handswitches located in the main control room. Refer to Table 27-1 for the location of the major system components and the SK-1000 series compartmentation drawings for definition of the column lines.

Upon starting a fire pump in any mode, its switchgear provides an output to close the raw service water head tank isolation valves.

The pushbutton stations located next to the fire hose stations are provided to start the fire pumps only. They are not connected to the fire detection system and they are not supervised.

No single failure in the circuits shown in Figure 27-1 or their power supplies will result in an unacceptable loss of firefighting capability. A failure in a local control panel could prevent the automatic initiation of the associated suppression system and the fire pumps during a fire. However, the failure would not affect the detection system's annunciation capability so the unit operator can manually start one or more fire pumps and can dispatch the fire brigade to manually initiate the suppression system. Automatic start logic failures can prevent the automatic actuation of all fire

pumps. This would not affect the suppression system operation, but would require manual starting of pumps from the main control room upon receipt of a detection system annunciation. A failure in the separation relays, 480V switchgear, or fire pumps would affect one pump only. The remaining three pumps would be operable in any mode. Failures in the handswitches, pilot valves, pushbuttons, and the system's connecting circuits are no more restrictive than those failures discussed above.

The consequences of an exposure fire are no more restrictive than the failures addressed above except in the case of the separation relays. This relay logic will be separated by 20 feet to ensure that the MCR control functions for no more than one fire pump can be affected by an exposure fire.

The fire pumps are assigned trained designations with two pumps in train A and two in train B. The manual control circuits (main control room switch, 480V switchgear, power supply, and connecting circuits) for the pumps are separated per the requirements for Class 1E electrical components.




FIGURE 27-1

TABLE 27.1

<u>Component</u>	<u>Building</u>	<u>Elevation</u>	<u>Column</u>	<u>Room Name</u>
Local control panels	-----Located Throughout the Plant-----			
Automatic fire pump start logic	Control	685.0	p,C5 p,C9	Units 1&2 Aux. Instr.
Fire pump 1A-A	Intake Pumping Station	705.0	-	-
1A-A separation relays*	Control	685.0		Unit 1 Aux. Instr.
1A-A 480V switch-gear	Auxiliary	734.0	t,A2	480V Shutdown Bd. Rm. 1A2
Fire Pump 1B-B	Intake Pumping Station	705.0	-	-
1B-B separation relays	Control	685.0		Unit 1 Aux. Instr.
1B-B 480V switch-gear	Auxiliary	734.0	r,A3	480V Shutdown Bd. Rm. 1B2
Fire pump 2A-A	Intake Pumping Station	705.0	-	-
2A-A separation relays	Control	685.0		Unit 1 Aux. Instr.
2A-A 480V switch-gear	Auxiliary	734.0	r,A13	480V Shutdown Bd. Rm. 2A2
Fire Pump 2B-B	Intake Pumping Station	705.0	-	-
2B-B separation relays	Control	685.0		Unit 1 Aux. Instr.
2B-B 480V switch-gear	Auxiliary	734.0	t,A14	480V Shutdown Bd. Rm. 2B2

Quality Assurance Branch
Request for Additional Information

Your description in Sections A.1 and B.5 of your submittals relative to your compliance with the "Guidelines in Appendix A of BTP 9.5-1" does not provide adequate information on your fire protection organization for us to complete our review. Therefore, please provide the following information:

1. Describe the upper level management position that has the overall responsibility for the formulation, implementation, and assessment of the effectiveness of the fire protection program.
2. Describe the offsite position(s) that has direct responsibility for formulating, implementing, and periodically assessing the effectiveness of the fire protection program for the nuclear plant, including fire drills and fire protection training.
3. While the Plant Superintendent is generally responsible for all activities at the facility, describe any further delegation of these responsibilities for the fire protection program such as training, maintenance of fire protection systems, testing of fire protection equipment, fire safety inspections, fire fighting procedures, and fire drills.
4. Describe the authority of your fire brigade leader relative to that of your Shift Engineer.

TVA Response

1. In the TVA organization structure, the General Manager has overall responsibility for the formulation, implementation, and assessment of the effectiveness of the fire protection program. In accordance with the TVA policy of management accountability, the General Manager has delegated these fire protection program responsibilities through the respective managers of offices to the Director of Engineering Design, the Director of Construction, and the Director of Power Production within their respective areas. To fulfill these responsibilities, these directors maintain qualified staffs to ensure that all aspects of the fire protection program are, at a minimum, consistent with applicable regulatory requirements. To ensure that an integrated program is maintained, TVA has established a fire protection panel composed of key management representatives from each of these three divisions for review and coordination of program policies and application in interface areas.

2. The offsite position(s) that has direct responsibility for formulating implementing, and periodically assessing the effectiveness of the fire protection program for the nuclear plant, including fire drills and fire protection training is the Fire Protection Section of Safety Engineering Services. The program is formulated and implemented through Division Procedures Manual N7852. Section F8 of this manual establishes the requirement for an annual fire audit of each nuclear facility.
3. Delegation of responsibilities for the fire protection program such as training, maintenance of fire protection systems, testing of fire protection equipment, fire inspections, firefighting procedures, and fire drills is contained in Division Procedures Manual N7852.
4. The authority of the fire brigade leader relative to that of the shift engineer is contained in Sequoyah Nuclear Plant Physical Security Instruction Physi-13, Section 1.0.

This instruction states in part that the duty assistant shift engineer, unit 1, shall be the fire brigade leader. He shall remain the leader unless relieved by his inline supervisor (the shift engineer). It further states that he shall keep the control room informed as to the fire conditions.

REQUEST FOR ADDITIONAL INFORMATION

QA FOR FIRE PROTECTION FOR SEQUOYAH (AND WATTS BAR) NUCLEAR PLANTS

F421.1 TVA's letter of January 24, 1977, to NRC regarding fire protection for Sequoyah (and Watts Bar) does not indicate whether the QA program for fire protection during design and construction is under the management control of the QA organization. This control consists of (1) formulating and/or verifying that the fire protection QA program incorporates suitable requirements and is acceptable to the management responsible for fire protection and (2) verifying the effectiveness of the QA program for fire protection through review, surveillance, and audits. Performance of other QA program functions for meeting the fire protection program requirements may be performed by personnel outside of the QA organization. The QA program for fire protection should be part of the overall plant QA program. These QA criteria apply to those items within the scope of the fire protection program, such as fire protection systems, emergency lighting, communication, and emergency breathing apparatus as well as the fire protection requirements of applicable safety-related equipment.

We find that the letter does not describe sufficient detail to address the ten specific quality assurance criteria in Branch Technical Position APCS 9.5-1 during design and construction. In order for the QAB to fully evaluate your plan to meet these criteria, additional detailed description is necessary. Examples of the detail we would expect TVA to provide are given in Attachment 6 to Mr. D. B. Vassallo's letter of August 29, 1977. If, however, you choose not to provide this detail, you may apply the same controls to each criterion that are commensurate with the controls described in your QA program description, Section 17.1A. These controls would apply to the remaining design and construction activities of Unit Nos. 1 and 2. If you select this method, a statement to this effect would be adequate for our review of the QA program for fire protection.

TVA Response

The QA program fire protection has been reviewed by appropriate TVA management including the QA organization to verify that the program incorporates suitable requirements and is acceptable. The appropriate QA personnel are responsible for verifying the effectiveness of the program through periodic audits.

The QA criteria apply to all fire protection related systems equipment and components within the scope of the fire protection program including fire protection systems, emergency lighting, communication, and emergency breathing apparatus, to the extent that they may affect the fire

protection for nuclear safety-related plant features. Our submittal of January 24, 1977, to the NRC will be revised as follows to reflect a more detailed discussion of the existing procedures and programs within the Office of Engineering Design and Construction (OEDC) that are required for fire protection related systems:

C. Quality Assurance

TVA Compliance

As indicated in the response to item A.1 Personnel, and as amplified in our response to Quality Assurance Branch question 1, TVA has delegated the responsibilities associated with the various aspects of fire prevention and protection to organizations which have personnel qualified to handle those functions.

The responsibility for the operational aspects of fire protection has been delegated to the Division of Power Production in TVA's Office of Power. The Office of Power utilizes TVA's established QA program designed to meet the requirements of Appendix B to 10CFR Part 50. This program applies, for the operational phase of TVA's nuclear power plants, to the activities affecting the quality of those critical structures, systems, and components (CSSC) whose satisfactory performance is required for safe plant operations; to prevent accidents that could cause undue risk to the health and safety of the public; and to mitigate the consequences of such accidents in the unlikely event that they should occur. Those fire protection features protecting critical structures or areas will be included in the CSSC list and as such will fall under TVA's operational QA program. The operational QA program is described in the Sequoyah Nuclear Plant Final Safety Analysis Report (FSAR), Chapter 17. Responsibility for the design and construction aspects of fire protection has been delegated to the Office of Engineering Design and Construction (OEDC). OEDC has documented procedures and specifications which govern its activities and which apply to all systems for which OEDC has responsibility. These procedures are aimed at ensuring that the design and construction of TVA facilities result in a reliable and quality product. As applied to fire protection, these documents will require, in part, that the actions required in C.1 through C.10 below be accomplished.

C.1 Design Control and Procurement Document Control

TVA Compliance

All fire protection related design criteria and procurement documents be reviewed by appropriate qualified individuals to ensure that applicable regulatory and design requirements are properly and adequately specified and, as appropriate, quality standards such as fire

protection codes and independent laboratory testing are included. All changes to these documents and deviations therefrom, including requests for field changes, are reviewed in a similar manner. The above includes appropriate design reviews to verify separation and isolation requirements as they relate to fire protection.

C.2 Instructions, Procedures, and Drawings

TVA Compliance

The design, installation, and tests associated with fire protection related systems be accomplished in accordance with written and approved instructions, procedures, and drawings. These documents must be reviewed by qualified personnel to ensure that applicable regulatory and design requirements are properly and adequately specified. This documentation includes any specialized training requirements for installation.

C.3 Control of Purchased Material and Equipment

TVA Compliance

The procurement of fire protection related material and equipment require either an inspection at the manufacturer's facility or a receiving inspection to verify conformance to procurement requirements.

C.4 Inspection



TVA Compliance

The installation of fire protection related systems be verified by independent inspection to ensure that it meets the specified requirements and conforms to installation drawings and procedures. The inspection must be conducted in accordance with documented procedures. The procedures controlling inspection activity require that the inspection procedures or instructions shall be available with necessary drawings and specifications to use prior to performing inspection operations. Further, the procedures, instructions, and/or drawings, including revisions, supporting the inspection activities shall be documented. The results of these inspections shall be recorded.



C.5 Test and Test Control

TVA Compliance



Fire protection systems be tested under TVA's preoperational test program. This program requires that tests be conducted in accordance with written test instructions which are reviewed to ensure that applicable regulatory and design requirements are properly and adequately specified. The acceptance criteria shall be evaluated and documented and all exceptions documented and controlled.



**IMAGE EVALUATION
TEST TARGET (MT-3)**



MICROCOPY RESOLUTION TEST CHART



C.6 Inspection, Test, and Operating Status

TVA Compliance

Items that have satisfactorily completed tests or inspections be identified by appropriate means.

C.7 Nonconforming Items

TVA Compliance

Nonconforming items be identified and controlled to prevent inadvertent use or installation. This includes documentation of the disposition of the nonconformance. The Thermal Power Engineering (TPE) Design Project shall review all nonconformance reports and may request review by other branches within EN DES as appropriate. The TPE Design Project Manager shall approve the disposition of the nonconformance.

C.8 Corrective Action

TVA Compliance

Significant and repetitive conditions adverse to fire protection such as nonconformances with installation drawings and deviations from specifications be controlled and appropriate corrective action taken and documented. Conditions involving fire incidents and the corrective actions taken shall be promptly reported to a cognizant level of management for review and assessment.

C.9 Records

TVA Compliance

Records be maintained for fire protection systems to document conformance to the prescribed criteria. These records must include review of criteria, procurement documents and drawings, inspections, test results, nonconformances, and modification records.

C.10 Audits

TVA Compliance

Independent audits by QA personnel be conducted annually in accordance with written procedures to ensure conformance to procedural requirements applicable to fire protection related systems. The audits must be documented along with the corrective action taken and reviewed by the appropriate level of management to ensure that the program is effective.

Additional Discussion Items

The following items have been discussed informally with the NRC Staff and are included as additional information.


1. No air-cooled transformers are located such that fires resulting from their failure would affect equipment or circuits identified in the response to question 1 that are required to achieve hot shutdown.
2. There is no fixed equipment containing flammable liquids in the vicinity of the entrance to the central room of the auxiliary control area. However, TVA will provide curbs at the doors between the auxiliary control area's central room and transfer switch rooms as protection against transient flammable liquid hazards. The curbs will ensure that a flammable liquid fire in any one of the five rooms will not jeopardize safe shutdown capability from the MCR.
3. Spray shields are provided for the reactor coolant pumps and all associated external lubricating oil piping and lift pumps such that the rupture of any oil-containing component will be contained. An oil collection basin is provided at the access platform elevation of each pump to collect and drain away any combustible liquid and/or suppression system discharge. Each reactor coolant pump is provided with a separate heat collection hood structure located approximately six feet above the pump designed to reduce the response time of the thermal detectors and thermal actuated water spray nozzles below the hood.

Neither the heat collector hood above, nor the collection system below the reactor coolant pump motor will jeopardize the ventilation air flow to the pump motor.

The above modifies TVA's description provided in Item F1 of the Sequoyah Nuclear Plant Fire Protection Program reevaluation forwarded to the NRC by letter from J. E. Gilleland to R. S. Boyd dated January 24, 1977.

4. During the NRC site visit, September 4 and 5, 1979, some concern was expressed by the NRC reviewers about the butt joint installation of the 1-inch Kaowool blanket conduit wrap noted in Table 1.3.

Discussions in subsequent telecons resulted in TVA's commitment to modify the butt joints of the wrap as shown in the following figure. This modification will be complete on conduits associated with unit 1 by January 1, 1980. The 1-inch Kaowool installation for conduits associated with unit 2 will be in accordance with the following figure and will be complete prior to initial fuel loading for unit 2.



MODIFICATION TO 1-INCH KAOLWOOL BLANKET
WRAP BUTT JOINT INSTALLATION

SCHEDULE FOR COMMITMENTS

All modifications resulting from commitments made in our submittal of January 24, 1977, shall be implemented prior to the initial fuel loading of the associated unit.

TVA proposes to implement modifications resulting from Nonconformance Report SWP-78-S-2 and from commitments made in this document per the following schedule:

<u>ASB Question No.</u>	<u>Action or Modification Required</u>	<u>Design Completion Date</u>	<u>Construction Completion Date</u>
1	Reroute conduit and cable identified in Table 1.2.	7/9/79 (unit 1) 7/9/79 (unit 2)	10/5/79 See note 1
	Wrap instrumentation conduit identified in Table 1.3 with 1-inch-thick Kaowool Blanket.	5/9/79 (unit 1) 7/9/79 (unit 2)	10/5/79 See note 1
	Enclose exposed conduit identified in Table 1.4 with a 1-1/2-hour fire barrier.	12/1/79	4/1/80
	Reroute units 1 and 2 pressurizer htr 6900V power cables to achieve 20 feet spatial separation.	5/7/79	10/5/79
3B(i)	Install additional fire doors identified in Nonconformance Report SWP-78-S-2.	3/6/79	See note 1
	Install remaining fire doors identified in Table 3B(i)-3.	3/6/79	See note 1
3B(ii)	Install additional fire dampers identified in Nonconformance Report SWP-78-S-2.	3/6/79	See note 1
	Install remaining fire dampers identified in Table 3B(ii)-3.	6/26/79	10/5/79
	Add pyrocrete to fire dampers PCO-39-17A and O-31A-148.	3/7/79	10/5/79
	Install additional fire dampers required as result of NRC concerns of February 12, 1979, meeting.	12/31/79	See note 2

<u>ASB Question No.</u>	<u>Action or Modification Required</u>	<u>Design Completion Date</u>	<u>Construction Completion Date</u>
3B(iii)	Coat the metal barrier plate in cable tray penetrations with pyrocrete.	12/1/79	4/1/79
4	Coat exposed surfaces of cables with flame retardant material in areas outside primary containment containing one or both safety-related divisions.	12/1/79	See note 2,3
6	Install fixed self-contained lighting in areas that must be manned for safe cold shutdown and for access and egress routes to and from all fire areas.	7/10/79	10/5/79
7	Electrically supervise the fire protection power distribution panel for loss of power.	7/9/79	11/7/79
8	Electrically supervise the fire pumps for loss of line power and motor running condition.	7/9/79	11/7/79
9D	Provide additional sprinkler heads or relocate existing heads to clear overhead obstructions.	3/31/80	See note 2
11B	Enclose ERCW junction box with 1-1/2-hour fire barrier.	12/1/79	2/1/80
	Provide a 1/2-hour fire barrier of 1-inch Kaowool Blanket between redundant power cables in the ERCW junction box.	6/29/79	10/5/79
13B	Provide automatic sprinkler protection under the pipe break barrier for the auxiliary feedwater pumps.	7/9/79	10/5/79
13C	Provide automatic sprinkler protection under the mezzanine for all component cooling water pumps.	7/17/79	10/5/79
13D	Provide a 1/2-hour fire barrier between train A and B component cooling water pumps.	7/9/79	10/5/79
13F	Provide additional smoke detectors to actuate the sprinkler systems in TVA responses to questions 13B and 13C.	7/9/79	10/5/79

<u>ASB Question No.</u>	<u>Action or Modification Required</u>	<u>Design Completion Date</u>	<u>Construction Completion Date</u>
16	Provide M.R alarm and annunciation for lock-out of diesel generator room and board room CO ₂ systems.	7/9/79	10/5/79
17A	Remove sliding fire doors for diesel generator rooms and replace with normally closed fire doors.	12/1/79	2/1/80
20D	Replace the existing 1/2-inch riser nipples with 1-inch nipples in the records storage area.	6/21/79	9/21/79
26	Provide additional equipment for fire equipment houses.	8/10/79	10/16/79
27	Relocate fire pump separation relays to achieve 20-foot spatial separation.	7/9/79	11/7/79
-	Install curbs at doors to transfer switch rooms of the auxiliary control complex.	6/20/79	10/5/79

Notes:

1. Prior to initial fuel loading of the associated unit.
2. End of first refueling outage for unit 1.
3. Cable coating is progressing. Areas identified in submittal of January 4, 1977, will be completed prior to initial fuel loading of the associated unit.