

Letter to N. C. Moseley from Duke Power Company dated February 14, 1975.

DISTRIBUTION:

50-269

H. D. Thornburg, IE

IE:HQS (5)

Office of Standards Development

→ Central Files

Division of Reactor Licensing (13)

PDR

Local PDR

NSIC

TIC

STATE

A. J.

7912100 613

~
5

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

P. O. Box 2178

February 14, 1975

Mr. Norman C. Moseley, Director
U. S. Nuclear Regulatory Commission
Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Re: Oconee Unit 1
Docket No. 50-269

Dear Mr. Moseley:

Unusual Event Report UE-269/74-6 reported a deficiency in the seismic qualification of the control rod drive system AC breaker cabinets at Oconee Nuclear Station. The report stated that a modification was being prepared to increase the attachment strength of the cabinet to the floor. This modification was to be completed by February 1, 1975.

A design review of the modification proposed by B&W has indicated that the modification cannot be accomplished due to close interference of nearby equipment. Consequently, the modification is being re-evaluated and a proposed design change should be available by March 1, 1975.

Modification of the trip breaker cabinets must be performed during a unit outage. Therefore, modification of the cabinets will be performed during the first scheduled unit outage following review and approval of the design change.

Very truly yours,

AC Thies / JBC
A. C. Thies

ACT:vr