NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | S C N E E 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE | LICENSE NUMBER | LICENSE TYPE | CAT

CON'T 01 REPORT SOURCE L (6) | 0 5 0 0 0 2 6 9 (7) DOCKET NUMBER | 0 1 0 5 7 8 (8) EVENT DATE | 0 1 3 1 7 9 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operations Keowee Hydro Unit 2 was removed from service to
03 perform maintenance actions which took approximately 5 hours. Keowee Unit
04 1 was connected to the underground feeder cable but was not verified
05 operable until after Keowee Unit 2 repairs were complete. Although this
06 violated the T.S. limit of 1 hour to check unit operability, the unit was
07 operable when checked.
08

09 SYSTEM CODE: E B (11) | CAUSE CODE: A (12) | CAUSE SUBCODE: A (13) | COMPONENT CODE: Z Z Z Z Z Z (14) | COMP SUBCODE: Z (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 7 8 | — | SEQUENTIAL REPORT NO. 0 0 2 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN: H (18) | FUTURE ACTION: Z (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: Y (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: Z (25) | COMPONENT MANUFACTURER: Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The event was caused by personnel error involving failure to follow
11 established procedures which was corrected by additional review of
12 procedures and specifications by personnel involved.
13
14

15 FACILITY STATUS: E (28) | % POWER: 1 0 0 (29) | OTHER STATUS (30): NA | METHOD OF DISCOVERY: Z (31) | DISCOVERY DESCRIPTION (32): NA

16 ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36):

PERSONNEL EXPOSURES
17 NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

PERSONNEL INJURIES
18 NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

LOSS OF OR DAMAGE TO FACILITY (43)
19 TYPE: Z (42) | DESCRIPTION: NA

PUBLICITY
20 ISSUED: N (44) | DESCRIPTION (45): NA

NRC USE ONLY

NAME OF PREPARER: K.R. Wilson

PHONE: (704) 373-8197

7912110797