

Letter to N. C. Moseley from Duke Power Company dated January 13, 1975.
This is a supplemental response.

DISTRIBUTION:

H. D. Thornburg, RO

RO:HQS (5)

Regulatory Standards

→ DR Central Files

Directorate of Licensing (13)

J. Rizzo, OOE, RO

PDR

Local PDR

NSIC

TIC

Chief, Regulatory News Branch, OIS, HQs

50-269

50-270

50-287

Response to ROB - 74-13

7912120605⁴⁰ *Q*

DUKE POWER COMPANY
POWER BUILDING
422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28201

A. C. THIES
SENIOR VICE PRESIDENT
PRODUCTION AND TRANSMISSION

P. O. Box 2178

January 13, 1975


Mr. Norman C. Moseley, Director
Directorate of Regulatory Operations
U. S. Atomic Energy Commission
Region II - Suite 818
230 Peachtree Street, Northwest
Atlanta, Georgia 30303

Re: RO:II:NCM
50-269, 50-270, 50-287
50-369, 50-370

Dear Mr. Moseley:

The purpose of this letter is to clarify my response to R.O. Bulletin No. 74-13, which was submitted on December 20, 1974. The use of Vulkene '600' cables in Class IE breaker-starters at the Oconee and McGuire Nuclear Stations has been reviewed. This type of cable has not been utilized within the subject equipment.

Very truly yours,



A. C. Thies

ACT:gje