

Encket Nos. 50-269  
50-270  
and 50-237

00 1976

POOR ORIGINAL

Duke Power Company  
ATTN: Mr. William O. Parker, Jr.  
Vice President  
Steam Production  
Post Office Box 2174  
122 South Church Street  
Charlotte, North Carolina 28242

Gentlemen:

RE: JOHNSON STATION, UNITS NOS. 1, 2 & 3

Earlier this year we sent letters to licensees of operating nuclear power plants notifying them of a revision to 10 CFR Part 50, Section 50.55a which was published in the Federal Register on February 12, 1976 (41 FR 625b). The revised regulation changed the inservice inspection and testing requirements for nuclear power plant components contained in paragraph (a) of 50.55a. A letter regarding this subject was sent to you on April 26, 1976.

Since that time, the NRC has received a number of inquiries from licensees regarding acceptable methods for complying with the regulation. In general, the inquiries have been directed toward three major areas relative to compliance with the regulation:

1. The determination of which ASME Boiler and Pressure Vessel Code Edition and Addenda are applicable for any updated inservice inspection or testing program,
2. The requirement to conform the Technical Specifications to a revised program, and
3. The process of obtaining relief from ASME Code requirements found to be impractical.

Consequently, we are transmitting for your use, Enclosure 1: "NRC Staff Guidance For Complying with Certain Provisions of 10 CFR 50.55a(f), Inservice Inspection Requirements". This enclosure describes the major provisions of the revised regulation, addresses the areas of licensee concern listed above, and provides guidance and information which the NRC staff will need to review inservice inspection and testing programs and to evaluate requests for relief from ASME Code requirements that are determined to be impractical. We believe this

enclosure will serve to clarify the proper method(s) for implementing the regulation in several important areas.

OFFICE  
SURNAME  
DATE

MAH

POOR ORIGINAL

NOV 30 1976

Duke Power Company

- 2 -

DISTRIBUTION

Dockets

ORB#1 Reading

NRC PDRs

VStello

LOCAL PDR

TJCarter

For Units 2 and 3, we reiterate our previous request that you submit proposed Technical Specification changes to incorporate standard language referencing §50.55a(d), at least 6 months before the start of the next 40-month inspection period for your facility. Also, as discussed in Enclosure 1, you should submit a description of your planned inservice inspection and testing programs, as well as any request for relief from ASME Code requirements determined to be impractical for your facility, as far in advance as possible of, but at least 90 days before, the start of any 40-month inservice inspection period, or 20-month pump and valve testing period. We are currently reviewing your unit 1 submittal dated October 1, 1976.

In addition, we would like to emphasize an important point regarding the ASME Code Section XI requirements to test selected pumps and valves, that are now incorporated in §50.55a(g): The ASME Code Section XI requirements apply only to selected valves and pumps that can be tested without placing the plant in an unsafe condition. You should exercise care in planning your testing programs to ensure that no test will be conducted while the plant is in an operating mode that would make it vulnerable to a test error or a test failure. Particular attention should be directed toward the valve exercising (cycling) tests. In this regard, some basic guidelines for excluding exercising (cycling) tests of certain valves during plant operation are contained in Enclosure 2. Valve leakage tests and other valve and pump tests required by the ASME Code, should be reviewed for each component, relative to each plant operating mode, to ensure that no test will have an adverse impact on plant safety.

If you have any further questions regarding implementation of 10 CFR 50.55a(d) at your facility, please contact us.

Sincerely,

Original signed by

A. Schwencer, Chief  
Operating Reactors Branch #1  
Division of Operating Reactors

Enclosures:

1. NRC Staff Guidance for Complying with Certain Provisions of 10 CFR 50.55a(d)
2. Guidelines for Excluding Exercising (Cycling) Tests of Certain Valves During Plant Operation

ASchwencer	TBAbernathy
SMSheppard	JRBuchanan
DNeighbors	ACRS (16)
JWetmore	
OELD	
OI&E (3)	
DEisenhut	

OFFICE →				DOR:ORB#1	DOR:ORB#3	DOR:ORB#1
cc	/enclosures:	see next page				
SURNAME →				DNeighbors:1	JWetmore	ASchwencer
DATE →				11/24/76	11/ /76	11/ /76

Duke Power Company

- 3 -

November 30, 1976

cc: Mr. William L. Porter  
Duke Power Company  
P. O. Box 2178  
422 South Church Street  
Charlotte, North Carolina 28242

POOR ORIGINAL

Mr. Troy B. Conner  
Conner & Knotts  
1747 Pennsylvania Avenue, N. W.  
Washington, D. C. 20006

Oconee Public Library  
201 South Spring Street  
Walhalla, South Carolina 29691