

THE BABCOCK & WILCOX COMPANY  
POWER GENERATION GROUP

95

B. A. Karrasch, Manager, Plant Integration

From *L.R. Cartin*

L. R. Cartin, Plant Integration (2835)

805 663.5

Cust.

File No.  
or Ref.

Subj.

Date

TECo - B&W Meeting Minutes

November 29, 1978

This letter is cover one customer and one subject only.

Re: 1) E. W. Swanson to W. H. Spangler, "Auxiliary Feedwater Setpoints,"  
NSS-14, November 15, 1978.

2) L. R. Cartin to W. H. Spangler, "TECo Operating Instructions,"  
T3.3.1, November 28, 1978.

On November 27, 1978 a meeting was held between TECo and B&W personnel (listing of attendees is given in Attachment 1) to discuss the design and requirements for DB-1 AFW System operation. This meeting was required to identify and resolve present problems associated with establishing steam generator level control setpoints which:

1. Maintain indicated pressurizer level during normal reactor trip events.
2. Maintain pressurizer level during moderate frequency events.
3. Provide secondary system performance consistent with LOCA and other DBA event analysis assumptions.

The above problems have arisen from TECo's need to reduce the steam generator level setpoints (to 35") for natural circulation and maintenance of indicated pressurizer level and B&W's need to maintain a high steam generator level (at least 10 feet) because of small LOCA requirements. Reference 1 provides a summary of activities that preceded the 11/27/78 meeting.

Attachment 2 provides the meeting agenda. To provide an orderly and concise summary of the discussions which took place, a synopsis of each major agenda section is provided below:

Section I: Definition of the Problem

Table 1 provides a listing of the principal (primarily technical) problems identified. In the short term, effort to resolve Items 7 and 8 to NRC's satisfaction is of primary importance so as to achieve continued operation of DB-1. Followon work will be required to implement permanent design changes and to finalize ECCS concerns.

8001170 746

P

Further discussion of short and long term activities to resolve identified problems is presented below.

## Section II: Auxiliary Feedwater (AFW) System Description

Fred Miller (TECo) provided a description of the major components of AFW System, the SFRCS which actuates and controls AFW, and possible AFW/SFRCS operating modes.

1. AFW System: Figure 1 is a simplified sketch of the AFW System assuming AFW addition to both steam generators. Two steam driven AFW pumps are supplied. Steam to drive the pump turbines is extracted from the main steam lines upstream of the MSIV's. Cross-connection for the steam supplies to the pump turbines and for AFW injection lines downstream of the AFW pumps are also provided to achieve FOGG capabilities during steam and feedwater line breaks. Each AFW pump is designed to deliver 800 gpm at 1050 psig (actual delivery is approximately 1200 gpm at 900 psig).
2. Steam and Feedwater Line Rupture Control System (SFRCS): The design goals of the SFRCS are:
  - a. Prevent release of high energy steam.
  - b. To automatically start AFW in the event of a steam or feedwater line, loss of both main feed pumps, or the loss of all four RC pumps.
  - c. To ensure adequate AFW to remove decay heat during periods when the normal feedwater supply and/or electric power supply to essential auxiliaries has been lost.
  - d. To provide essential steam generator level control when AFW is required.

Station variables which require actuation of AFW are:

- a. Low steam line pressure (< 591.6 psig).
- b. Low steam generator level ( $\leq$  17 inches).
- c. Steam generator pressure greater than main feedwater line pressure by 197.6 psi.
- d. Loss of all RC pumps as indicated by the RC pump monitors.

For all actuation signals except the loss of all RC pumps, the SFRCS will close both main steam isolation valves, close both main feedwater control and stop valves, initiate AFW and control AFW addition to maintain a 120" level in the steam generators. Furthermore, if one steam generator remains depressurized (< 591.6 psig) the SFRCS will also align both the AFW pump turbines and AFW injection lines to the pressurized steam generator (SLB and FWLB). If a loss of all RC pumps (only signal) signal occurs, the SFRCS only initiates AFW; steam and feedwater isolation is not actuated.

3. AFW/SFRCS Operational Aspects: Following SFRCS actuation and AFW system alignment (FOGC), steam generator level control is achieved by controlling the AFW pump turbine speed. No changes in valve position are instigated by SFRCS to achieve level control. TECo indicated that level control within  $\pm 6$ " of the setpoint is typically encountered. TECo further indicated that reductions seen in steam generator pressure following AFW actuation are due to the large quantity of cold AFW introduced into the steam generators and are not due to steam usage by the AFW pump turbines.

### Section III: Criteria for Pressurizer Sizing

The need to maintain pressurizer level during normal accident conditions was discussed at length. Table 2 presents, for condition I-IV events, criteria for pressurizer level and the required steam generator level control setpoints. Both B&W and TECo agreed that these conditions would allow safe operation of the plant without violation of Safety Analyses assumptions. This position is to serve as a basis to counteract NRC's inquiry (GDC-13) about TECo's ability to maintain indicated pressurizer level during normal and upset conditions. Also noted on Table 2 are action items to provide analysis support to the AFW/pressurizer level position.

TECo indicated that the position reflected in Table 2 would probably satisfy the regional reviewer; however, they were not so optimistic about DOR acceptance. If DOR insists that indicated pressurizer level be maintained for both condition I and II events, additional design changes such as reducing the rate of AFW addition may have to be pursued.

### Section IV: Interim Actions

In the interim, site instructions will be prepared to direct the operator to assume manual control of the AFW when actuated by SFRCS and maintain 35 inches (indicated) on the startup range instrumentation when no ESFAS actuation of HPI occurs. For SFRCS actuations followed by ESFAS actuation of the HPI system, the operator shall ensure automatic control of AFW by SFRCS to 120 inches (96 inches indicated) on the startup range instrumentation. No operator actions are required if main feedwater remains available following a reactor trip event, even with ESFAS actuation of the HPI. The revised site instructions are provided in Reference 2 and are consistent with the AFW/pressurizer level position given in Table 2.

An alternative to the above was discussed. This was simply to change the present SFRCS setpoint (10 feet) to 35 inches and to rely on operator action to manually control AFW at 10 feet if post LOCA conditions are present (HPI actuation). This alternative was not adopted because: 1) NRC acceptance of a timely and continuous manual control function to mitigate a LOCA may be difficult to obtain, and 2) the preferred interim measures are more similar to present operating procedures.

Action items for B&W to supply analysis and/or test data to support the interim site operating instructions from a safety standpoint are given in Table 2.

#### Section V: Criteria for Design of AFW Systems

The present problem on TECo is a clear indication that the AFW system now performs many more functions than its original design purpose of decay heat removal. An internal review (generic) of B&W requirements on the AFW system may be desirable to eliminate similar problems in the future. Of particular interest would be to limit dependence on steam generator performance for LOCA mitigation.

#### Section VI: Permanent Design Change (Long Term)

The dual setpoint concept for SFRCS control of AFW (automation of interim site instructions) was deemed the most desirable permanent fix. Several modifications were noted, however, to provide greater protection from loss of pressurizer level. These included the possible use of a 10 foot level only if: 1) SFRCS-ESFAS-RC pumps off only or, 2) SFRCS-ESFAS (4 psig and 1600 psig) where both ESFAS signals are required to indicate the existence of a small break. These considerations will be reviewed in the long term.

TECo indicated that their next planned outage is March, 1980 and any permanent design changes would be made at that time because the incorporation of a dual setpoint will require plant shutdown. This long lead time is advantageous for design of a permanent solution, however, the NRC may not accept this schedule which would rely on operator action for over one year to meet GDC-13.

If the NRC inquires about plans for a permanent fix in the short term, it was decided to indicate an automatic control scheme similar to the present site instructions would be implemented. This approach will allow review and possible use of the modifications noted above.

To summarize discussions in previous sections, Table 3 has been developed to illustrate TECo's present AFW control schemes and the proposed modifications during several accident situations.

Note: If the NRC does not accept the proposed position on GDC-13 (Pressurizer Level Indication) in Table 2, additional design changes may be required. One possible change would be to limit AFW flow rates.

#### Section VII: Licensing Concerns

Although not specifically addressed, the small LOCA concern (32 foot steam generator level in Topical compared to present SFRCS design which will allow only 10 feet) is not considered to be a PSC. B&W will supply technical arguments to support the adequacy of the 10 foot level if required.

For the past year, TECo site operators have been instructed to manually control AFW at the 35 inch level following all SFRCS actuations. Since B&W site instructions will require the achievement of a 10 foot level for SFRCS-HPI events, the present site instructions are considered to be inconsistent with Safety Analysis assumptions, but not considered to be a safety problem. This inconsistency is interpreted to be an unreviewed safety issue. At

the time TECo revises their site procedures, they will also inform the NRC of the unreviewed safety issue. It is hoped that NRC will accept this report as a mere formality to document measures to assure future plant operation consistent with past safety analysis assumptions.

Section VIII: Schedule/Plan for Problem Resolution

TECo is to contact the NRC on 11/28/78 and present the revised site instructions and position on GDC-13 given in Table 2. Action items noted in Table 2 are to proceed on an "as soon as possible" schedule to provide TECo support to anticipated NRC questions. Plant Integration will coordinate these short term activities.

NRC's reaction to TECo proposals will ultimately control any short or long term activities schedules. For the long term, work activities and schedules will be developed following receipt of feedback from TECo.

LRC:dh

Attach

cc: B. M. Dunn  
R. C. Luken  
W. H. Spangler  
E. W. Swanson  
R. O. Vosburgh/D.W. Labelle  
R. W. Winks  
E. A. Womack  
J. D. Carlton



TABLE 1: PRINCIPLE PROBLEMS ASSOCIATED WITH  
STEAM GENERATOR LEVEL CONTROL SETPOINT

1. Pressurizer level indication will be lost for normal and upset conditions with SFRCS actuation and control of AFW to 10 foot level. (NRC GDC-13 concern.)
2. Pressurizer drains with addition of 4 feet (steam generator level) of AFW at low power levels ( $<15\%$ ) with the RC pumps on.
3. ECCS requires at least 10 feet (steam generator level of AFW for small breaks when LOOP assumed (RC pump off)). Limited analysis is available assuming a 10 foot level.
4. Small LOCA's have not been analyzed assuming main feedwater, controlled at 2 foot level by the ICS, and RC pumps operative (no LOOP).
5. If a loss of pressurizer level occurs due to addition of AFW to a 10 foot steam generator level, the effect of displacing the pressurizer steam bubble into the loops is unanalyzed. Outstanding concerns include: a) the ability to regain pressurizer level with the low head HPI system, and b) the ability to maintain natural circulation for LOOP events.
6. Transients that constitute the design basis for pressurizer sizing and level indication requirements need to be defined so that present or future steam generator level setpoints can be justified.
7. Present TECo operating procedures instruct the operator to limit (manually) AFW addition to 35 inches on the startup range, level instrumentation. Revised instructions to acquire a 10 foot steam generator level for ESFAS events (small LOCA mitigation) may represent an unreviewed safety problem.
8. TECo must contact the NRC on 11/28/78 and provide a compliance position on GDC-13 and assurance that no safety analyses are violated.

2002

POOR ORIGINAL

Handwritten notes at the bottom of the page:

Handwritten notes at the bottom of the page:

# TABLE 3 Recommended Control Actions for Abnormal Remote Trip Events And Accident Conditions

NO	DESCRIPTION	EXISTING Control Sequence	Revised SC Control Seq.	ANALYSIS RECOMM.	Comments
1.	<p>Is Trip From Any Pump Level</p> <p>SC Pumps OPERATIVE</p> <p>INSTR OPERATIVE</p> <p>NO SPDES Action</p> <p>NO EFAS</p> <p>(Also FOGG)</p>	<p>ICS Control of main/SC</p> <p>Recowater Flow To Maintain Low Level (426" on SC Range) T-1 OTSC</p>	<p>No change</p>	<p>Buy To Provide Analogue and/or Trip Backup That Png level indication is maintained at low power levels</p>	<p>Normal Trip.</p>
2.	<p>Is Trip From Any Power Level</p> <p>SC Pump OPERATIVE</p> <p>INSTR NOT OPERATIVE</p> <p>NO EFAS</p> <p>(NO FOGG)</p> <p>SPDES Action of AFES on Low SC level or M/SC AP</p>	<p>SPDES isolation of steam and MF lines, safety action and control of AFES to 120" on SC Range T-1 OTSC.</p>	<p>Same as existing design except control setpt. should be 35" on the SC Range.</p>	<p>Buy to provide analogue to demonstrate that the Png data not down and that EFAS as not calculated for a loss of 15% power.</p>	<p>Inform station regarding the significance of action immediately on loss of AFES and to manually control SC level to the 35" level.</p> <p>(100% of FOGG On 12.00 C.O.V.)</p>
3.	<p>Is Trip From Any Power Level</p> <p>SC Pumps Not OPERATIVE</p> <p>INSTR Not OPERATIVE</p> <p>NO EFAS</p> <p>(NO FOGG)</p> <p>SPDES Action of AFES on Low SC level or M/SC AP</p>	<p>Same as Case #2.</p>	<p>Same as Case #2</p>	<p>Buy to provide analogue that demonstrate maintenance of Png level and no EFAS indication for a 100% at low power (15%)</p>	<p>Same as Case #2 (100P)</p>

POOR ORIGINAL



NO.	DESCRIPTION	EXISTING CONTROL SEA	PROPOSED CONTROL SEA	ANALYSIS REAR	COMMENTS
4.	<p>For Pump from Dry Basin</p> <p>Isol.</p> <p>PC Pump Operation</p> <p>NEW Operation</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p>	<p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p>	<p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p>	<p>Reasoning of Small Break May Be Read.</p> <p>This is a generic 177FA Plant Concern</p>	<p>No Transition Required. Actions Required. 100% within these conditions is below to be safe.</p> <p>(Source: 177FA)</p>
5.	<p>For Pump from Dry Basin</p> <p>Isol.</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p>	<p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p>	<p>Same As Existing Plant</p> <p>EXCEPT EX. RECS INPUT TO</p> <p>EX. RECS MAY BE READ</p>	<p>Reasoning of Small Break May Be Read. RECS To Demonstrate Adequacy of 10-11 Level.</p>	<p>Full scale test has been done at 10-11 level &amp; 10-12 level.</p>
6.	<p>For Pump from Dry Basin</p> <p>Isol.</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p> <p>EX. RECS Act on</p>	<p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p> <p>EX. RECS Act of RECS, EX. RECS</p> <p>Isol. of RECS &amp; RECS</p>	<p>Same As Existing Plant</p> <p>EXCEPT EX. RECS INPUT TO</p> <p>EX. RECS MAY BE READ</p>	<p>Read To Dry Position and Here To Regain Pre Level To Maintain Hot Y/D For A SLB.</p>	<p>(SLB)</p>

POOR ORIGINAL

Case No.	References	Existing Control Schemes	Proposed Control Schemes	Analysis Summary	Comments
7.	<p>See Sup from Army Panel Panel</p> <p>See Army Operation 1940-1942 Operation EFFECTS DETENTION (4000)</p> <p>Effects not on low in land and low in water. (F066)</p>	<p>Effects Act of 1940 &amp; 1942 of 1940 &amp; 1942</p> <p>SECS Tool of Stream Fus Lines, SECS Act And Control of Army To 120' on the Range In 1940-1942</p>	<p>Same As Existing However, EFFECT THAT SECS INPUT TO SECS MAY BE REQUIRED</p>	N/A	<p>(THIS INDEX CONT. 0 26.)</p>
	<p>See Sup from Army Panel Panel</p> <p>See Army Operation 1940-1942 Operation EFFECTS DETENTION (4000)</p> <p>Effects not on low in land and low in water. (F066)</p>	<p>Same as Case #1</p>	<p>Same as Case #1</p>	<p>But To Develop Position on Effect of Loss of Fus Bubble on Natural Circulation And on The Need and Ability To Regain the Level.</p>	<p>(See with 100P)</p>

NOTE: IT IS ASSUMED HERE THAT A TOOL SETPOINT IS TO BE ADOPTED, THAT IS, EFFECTS WILL INITIATE AND CONTROL AFM TO 35" WATER AND EFFECTS INFORMATION IS PRESENT 4 TO 10-H WHEN AN EFFECT IS ACTUATED

POOR ORIGINAL



# ATTACHMENT 1

Babcock & Wilcox

11/27/78 Meeting on Control of Steam Generator

Level and Associated Pressurizer Level

AT Lynchburg

DAVIS-Besse Unit 1

NAME	Organization	Title
CHUCK DUNECK	TECO	DEI Nuclear Project Engineer
Fred R. Miller	"	Head S&S Dept.
Terry D. Murray	TECO	Station Supt.
Low CARTIN	B&W	PLANT INTEGRATION
Bob Winks	B&W	Control Analysis
Ron Davis	"	"
Bert Dunn	B&W	ECCS Analysis
RAY LUKEN	B&W	PROG MGR/SERVICE MGR
Ken Finnie	B&W	Licensing
E.A. NOMACK	B&W	Engineering Plant Design
E. L. L.	"	Plant Integration
ERIC SWANSON	B&W	PLANT DESIGN Integration

POOR ORIGINAL

## ATTACHMENT 2.

### PROPOSED AGENDA FOR TECO - B&W

MEETING ON NOVEMBER 27, 1978

- I. Definition of the Problem(s) (TECO)
  - A. TECO Perception of Problems
    - 1. Recent Operational Occurrences
    - 2. Testing Requirements
    - 3. NRC Involvement
      - a. NRC Positions on SG Level Control Setpoints
      - b. Summary of Recent NRC-TECO Discussions
      - c. Level of Problem Escalation Within the NRC
      - d. TECO Commitments, if any, to Supply the NRC Information
      - e. Time Restraints
  - B. B&W Perception of the Problem
    - 1. Loss of Pressurizer Level Indication (NRC concern)
    - 2. Loss of Level (pressurizer draining)
    - 3. Potential for Spurious Initiation of ESFAS on Loss of Level
    - 4. Needs for Steam Generator High Level for ECCS
    - 5. Need to Maintain Natural Circulation
- II. Auxiliary Feedwater (AFW) System Description (TECO)
  - A. Physical Layout - Major Components
  - B. Present System Modes of Operation
    - 1. Initiating Signals (SFRCS, ICS, etc.)
    - 2. SG Level Control Setpoints
    - 3. Expected Flow Rates



## PROPOSED AGENDA (CONTINUED)

### C. System Operation

1. AFW System Operation to Achieve and Control SG Level  
(Interaction of Pump Speed Controls and AFW Injection Valve Operation; with SG Level Control and FW Demand Signals; System Response Times; Sequence of Control Events; etc.)
2. AFW - Secondary Side Interaction
  - a. Impact of AFW System Operation on SG Pressure
  - b. Level Control Stability with Off-On AFW Operation

### III. Criteria for Pressurizer Sizing

(B&W)

#### A. Need to Maintain Indicated Level for:

1. Normal Reactor Trip Events
2. Upset Condition (LOMF, Secondary Side Steam-Feedwater Malfunction, etc)
3. Design Basis Events (SLB, LOCA, etc.)

#### B. Past and Present NRC Positions on Criterion 13.

Following this discussion, a position will be developed by TECO/B&W for future use in NRC discussions.

### IV. Interim Actions to Achieve Pressurizer Level Control and to Maintain Validity of Safety Analysis (Short Term)

#### A. Discussion of Recent Site Instructions

1. Situations Requiring Op. Action to Control SG Level
2. Basis for Operator Intervention -
  - Maintenance of Pressurizer Level
  - LOCA Mitigation
  - Etc.

#### B. Probability of Success Based on Operation Exp.

#### C. Anticipated NRC Reaction to Proposed Administrative Procedures

## PROPOSED AGENDA (CONTINUED)

### V. Criteria for Design of AFW System

#### A. At the Time of TECO Design

1. Decay Heat Removal (LOFW)
2. Establish Natural Circulation

#### B. Present (in addition to A)

1. Maintain Hot Shutdown Decay Heat Removal After Abnormal Transients
2. Small Break LOCA Mitigation

#### C. Future (Possibles in addition to A and B)

1. Loss of All AC Power
2. Safety Grade Cooldown

### VI. Permanent Design Change Alternatives (Long Term)

#### A. Dual Setpoints - Control of SG Level at 120" for ESFAS Transients Only

#### B. AFW Flow Rate Reduction

1. Injection Valve Throttling
2. Pump Speed Reduction
3. Increased Bypassed Flow

#### C. Other Alternatives

### VII. Licensing Concerns

#### A. Present NRC Commitments - FSAR, Verbal, etc.

#### B. Is Problem A Preliminary Safety Concern?

#### C. Licensing Action to Implement Permanent Design Change

### VIII. Development of Schedule and Program Plan for Problem Resolution

#### A. Short Term TECO & B&W Actions

#### B. Long Term TECO & B&W Actions