

Jersey Central Power & Light Company  
Madison Avenue at Punch Bowl Road  
Morristown, New Jersey 07960  
(201) 455-8200

February 14, 1980

Mr. Boyce H. Grier, Director  
Office of Inspection and Enforcement  
Region I  
United States Nuclear Regulatory Commission  
631 Park Avenue  
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

SUBJECT: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Licensee Event Report  
Reportable Occurrence No. 50-219/80-2/3L

This letter forwards three copies of a Licensee Event Report to report Reportable Occurrence No. 50-219/80-2/3L in compliance with paragraph 6.6.1.a of the Technical Specifications.

Very truly yours,

Ivan R. Finrock, Jr.  
Vice President-Generation

ck

Enclosures

cc: Director (40 copies)  
Office of Inspection and Enforcement  
United States Nuclear Regulatory Commission  
Washington, DC 20555


Director (3 copies)  
Office of Management and Program Analysis  
United States Nuclear Regulatory Commission  
Washington, DC 20555

S 8 002 220 390

10.0 Transportation Security

10.1 The licensee shall not import, export, transport in a single shipment or take delivery of a single shipment free on board at the point where it is delivered to an agent or carrier, quantities of special nuclear material as specified in 10 CFR Part 73.1(b)(2) until a detailed plan as described in § 70.22(g) of 10 CFR Part 70 has been submitted, and approved by the Nuclear Regulatory Commission.

Sincerely,



George W. McCorkle, Chief  
Physical Security Licensing Branch  
Division of Safeguards

Mr. James G. Kepley, Director  
U. S. Nuclear Regulatory Commission  
Region III  
January 11, 1980 - QA-1247  
Page 2

Date When Full Compliance will be Achieved

Full compliance will be achieved when the verification of the drywell steel is complete. This verification is scheduled to be completed March 15, 1980.

In order that records are correct, the following information is provided.


Reinforcing plates identified by Heat Number 801E04680 (3/8" thick) and AN-74292 (3/4" thick) are both A-36 materials and were installed in compliance with drawing requirements.

We trust that this letter is an adequate response to your IE Investigation Report #79-32.

Very truly yours,

THE CINCINNATI GAS & ELECTRIC COMPANY

By



E. A. BORGMANN  
SENIOR VICE PRESIDENT

DCK:pa