

LICENSEE EVENT REPORT

CONTROL BLOCK: 01171167

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME				LICENSE NUMBER												LICENSE TYPE				EVENT TYPE				
01	F	L	C	R	P	3	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	1
7	8	9	14	15	25	26	30	31	32															
CATEGORY		REPORT TYPE	REPORT SOURCE	COCKET NUMBER				EVENT DATE				REPORT DATE												
01	CONT	0	P	0	5	0	-	0	3	0	2	0	1	2	6	7	7	0	2	0	9	7	7	
7	8	57	58	59	60	61	68	69	74	75	80													

EVENT DESCRIPTION **(77-3)**

02	L While in Mode 3 (Hot Standby) during start-up, Boron concentration was found																							80
03	to be approximately 50 ppm diluted causing a 0.57% reactivity insertion.																							80
04	Recovering from trip of 4160V unit bus the "A" Makeup and Purification demineralizer																							80
05	had inadvertently been placed in service. Shutdown margin remained 4.34% AK/K.																							80
06	Demineralizer was immediately by-passed. (77-8)																							80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER			VIOLATION			
07	C	G	A	D	E	M	I	N	X	N	B	0	1	5	N	
7	8	9	10	11	12	13	14	15	16	17	43	44	45	46	47	48

CAUSE DESCRIPTION

08	Operator erred in placing unborated mixed bed Demin. on line. Tagging now																							80
09	employed to alert operators which unit is to be out of service.																							80

FACILITY STATUS		% POWER			OTHER STATUS				METHOD OF DISCOVERY		DISCOVERY DESCRIPTION						
11	B	0	0	0	Mode 3				B	Routine Chemistry Surveillance							
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE									
12				N/A													
7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION			
13				N/A			
7	8	9	10	11	12	13	14

PERSONNEL INJURIES

NUMBER		DESCRIPTION			
14		N/A			
7	8	9	10	11	12

OFFSITE CONSEQUENCES

15	N/A																							80
----	-----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION			
16		N/A			
7	8	9	10	11	12

PUBLICITY

17	N/A																							80
----	-----	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	--	----

8002270585

ADDITIONAL FACTORS

18	Plant was in Mode 3 (Hot Standby), shutdown margin remained greater than 4% AK/K,																							80
19	Safety Rod Groups were withdrawn and cocked.																							80

NAME: W. P. Stewart *WPS* PHONE: (813) 866-4159