



FILE COPY

**Florida Power**  
CORPORATION

24 January 1977  
CS-77-12  
3-0-3-a-1



Mr. Norman C. Moseley, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
230 Peachtree St., N.W., Suite 818  
Atlanta, Georgia 30303

Docket No. 50-302  
License #DPR-72  
Licensee Event Report 77-5

Dear Mr. Moseley:

Please find enclosed Licensee Event Report 77-5, which is submitted pursuant to Technical Specification 6.9.1, and Section 2.b.(1) of Regulatory Guide 1.16, Revision 4.

During surveillance inspection of Boric Acid Storage Tank "A" Level Indicator, it was found to be plugged reading 100% when, in fact, the tank was empty. Redundant sources of boron were available.

A modification to the indicator has been submitted to provide blowdown, and periodic mechanical clearance of lines is being performed to prevent recurrence.

Very truly yours,

FLORIDA POWER CORPORATION

*W. P. Stewart*

W. P. Stewart  
Director, Power Production

DWP/feh

Enclosure

*[Signature]*

Nuclear Plant Manager

*No COPY SENT REGION* ~~N/A~~

1040

8002 270 596 5