

LICENSEE EVENT REPORT

CONTROL BLOCK						LICENSEE NAME						LICENSE NUMBER						LICENSE TYPE						EVENT TYPE																							
[01]						FILCRP3						00-000000-00						41111						03																							
REPORT CATEGORY												DOCKET NUMBER												EVENT DATE												REPORT DATE											
[01] CONT												050-0302												020177												022877											

EVENT DESCRIPTION

[02] During performance of SP-300 (Operating Daily Surveillance Log), Remote Temperature Indicator RC-4A-TI-2 ("A" loop T.H.) was found to be in error (9 degrees low). Redundant readout in the Control Center was available. This was the first occurrence of this type. Faulty meter movement was replaced in kind.

SYSTEM CAUSE				COMPONENT CODE				PRIME COMPONENT SUPPLIER				COMPONENT MANUFACTURER				VIOLATION			
[07] ID E				INSITRU				N				B045				N			

CAUSE DESCRIPTION

[08] Meter movement had failed. It was replaced and the indicator calibrated. Bailey Meter Temperature Indicator Model ES-170. Daily comparison check enforced by Surveillance Procedures.

FACILITY STATUS			% POWER			OTHER STATUS			METHOD OF DISCOVERY			DISCOVERY DESCRIPTION		
[11] B			015			Mode 1			B			N/A		

FORM OF ACTIVITY RELEASED			CONTENT OF RELEASE			AMOUNT OF ACTIVITY			LOCATION OF RELEASE		
[12] 2			2			N/A			N/A		

PERSONNEL EXPOSURES			PERSONNEL INJURIES		
[13] 0100			[14] 000		
TYPE 2			DESCRIPTION N/A		

PROBABLE CONSEQUENCES		
[15] N/A		

LOSS OR DAMAGE TO FACILITY		
[16] N/A		

PUBLICITY		
[17] N/A		

ADDITIONAL FACTORS		
[18] N/A		

[19]		
------	--	--

NAME: W. I. Stewart PHONE: (813) 866-4159

8002270-614