



LE FILE COPY

**Florida Power**  
CORPORATION

18 February 1977  
3-0-3-a-1  
CS-77-31



Mr. Norman C. Moseley, Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
230 Peachtree St., N.W., Suite 818  
Atlanta, Georgia 30303

Docket No. 50-302  
License #DPR-72  
Licensee Event Report 77-14

Dear Mr. Moseley:

This report is submitted in accordance with Technical Specification 6.9.1 and Regulatory Guide 1.16, Revision 4, Section 2.b. (3) as a written Thirty (30) Day Report.

Review of surveillance test procedure results determined that the Crystal River Unit 1 station battery did not meet acceptance criteria in that specific gravity was below 1.20. Redundant sources of emergency power were available and demonstrated operability. Upon discovery, the battery was charged and tested satisfactorily.

Corrective action was implemented in accordance with the attached Licensee Event Report. No safety implications resulted.

Very truly yours,

FLORIDA POWER CORPORATION

*W. P. Stewart*

W. P. Stewart  
Director, Power Production

DWP/feh

Enclosure

*[Signature]*  
Nuclear Plant Manager

2081

8002 270679