

LICENSEE EVENT REPO

CONTROL BLOCK:

[PLEASE PRINT ALL REQUIRED INFORMATION]

LICENSEE NAME						LICENSE NUMBER										LICENSE TYPE					EVENT TYPE				
01	F	L	C	R	P	3	0	0	-	0	0	0	0	0	-	0	0	4	1	1	1	1	0	1	
7	8	9				14	15											26					30	31	32
CATEGORY		REPORT TYPE		REPORT SOURCE		DOCKET NUMBER						EVENT DATE				REPORT DATE									
01	CONT	0	*	L	L	0	5	0	-	0	3	0	2	0	1	0	3	7	7	0	1	2	4	7	7
7	8	57	58	59	60	61								68	69					74	75				80

EVENT DESCRIPTION

02	During surveillance inspection "A" Boric Acid Storage Tank Level Indicator was																							80
03	found to be plugged. It was reading 100% when tank was empty. Redundant sources																							80
04	of boron were available. Modification in progress. Periodic mechanical clearing																							80
05	being performed.																							80
06	(77-5)																							80

SYSTEM CODE		CAUSE CODE		COMPONENT CODE				PRIME COMPONENT SUPPLIER		COMPONENT MANUFACTURER			VIOLATION			
07	P	C	B	I	N	S	T	R	U	A	B	0	4	5	N	
7	8	9	10	11	12					17	43	44			47	48

CAUSE DESCRIPTION

08	The sensing line "dip tube" was blocked by crystallized boric acid. We now rod																							80
09	out on periodic basis and have requested modification for blowdown capability.																							80

FACILITY STATUS		% POWER			OTHER STATUS			METHOD OF DISCOVERY		DISCOVERY DESCRIPTION															
11	B	0	0	0	Mode 5			B	Heater externals very hot																
7	8	9	10	12	13				44	45	46														80

FORM OF ACTIVITY RELEASED		CONTENT OF RELEASE		AMOUNT OF ACTIVITY				LOCATION OF RELEASE																	
12				N/A																					
7	8	9	10	11																					80

PERSONNEL EXPOSURES

NUMBER		TYPE		DESCRIPTION																					
13				N/A																					
7	8	9	11	12	13																				80

PERSONNEL INJURIES

NUMBER		DESCRIPTION																							
14		N/A																							
7	8	9	11	12																					80

OFFSITE CONSEQUENCES

N/A																										
7	8	9																								80

LOSS OR DAMAGE TO FACILITY

TYPE		DESCRIPTION																								
16		N/A																								
7	8	9	10																							80

PUBLICITY

N/A																										
7	8	9																								80

ADDITIONAL FACTORS

N/A																										
7	8	9																								80

8002 270720

NAME: W. P. Stewart

WPS

PHONE: (813) 866-4159