

# LICENSEE EVENT REPORT

CONTROL BLOCK 1 

--	--	--	--	--	--

 6

PLEASE PRINT ALL REQUIRED INFORMATION

LICENSEE NAME F L C R P 3			LICENSE NUMBER 0 0 - 0 0 0 0 - 0 0				LICENSE TYPE 4 1   1 1   1			EVENT TYPE 0 1		
CATEGORY 0 1 CONT		REPORT TYPE P	REPORT SOURCE L	DOCKET NUMBER 0 5 0 - 0 3 0 2				EVENT DATE 0 1 3 0 7 7			REPORT DATE 0 2 0 7 7 7	

### EVENT DESCRIPTION

02	Discovery of a through wall crack in an eight inch Schedule 40 304 stainless steel building spray pipe inside the containment building. Crack is in heat affected zone of a pipe-to-pipe weld. The system may have contained stagnant water. This is the second occurrence of this nature.									80
03										80
04										80
05										80
06										80

(77-6)

SYSTEM CODE S A	CAUSE CODE E	COMPONENT CODE P I P E X X	PRIME COMPONENT SUPPLIER A	COMPONENT MANUFACTURER K O 5 5	VIOLATION N
--------------------	-----------------	-------------------------------	-------------------------------	-----------------------------------	----------------

### CAUSE DESCRIPTION

08	Suspected stress corrosion cracking due to presence of chlorides and oxygen.									80
09	Investigation is continuing in accordance with IE Circular 76-06.									80
10										80

FACILITY STATUS B	% POWER 0 0 0	OTHER STATUS Mode 5	METHOD OF DISCOVERY B	DISCOVERY DESCRIPTION Leakage noted by plant Operator
----------------------	------------------	------------------------	--------------------------	--

FORM OF ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY NA	LOCATION OF RELEASE
---------------------------	--------------------	--------------------------	---------------------

### PERSONNEL EXPOSURES

NUMBER	TYPE	DESCRIPTION NA
--------	------	-------------------

### PERSONNEL INJURIES

NUMBER	DESCRIPTION NA
--------	-------------------

### OFFSITE CONSEQUENCES

DESCRIPTION NA
-------------------

### LOSS OR DAMAGE TO FACILITY

TYPE	DESCRIPTION NA
------	-------------------

### PUBLICITY

DESCRIPTION NA
-------------------

### ADDITIONAL FACTORS

DESCRIPTION NA
-------------------

8002270727

18										80
----	--	--	--	--	--	--	--	--	--	----

NAME: W. P. Stewart *WPS* PHONE: (813) 866-4159