



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
230 PEACHTREE STREET, N.W. SUITE 818
ATLANTA, GEORGIA 30303

IE FILE COPY

NOV 9 1976

In Reply Refer To:
IE:II:FJ
50-302/76-17

Florida Power Corporation
Attn: Mr. J. T. Rodgers
Assistant Vice President
Quality and Environmental Departments
3201 34th Street, South
P. O. Box 14042
St. Petersburg, Florida 33733

Gentlemen:

This refers to the inspection conducted by Mr. G. L. Troup of this office on September 28 - October 1, 1976, of activities authorized by NRC Construction Permit No. CPPR-51 for the Crystal River 3 facility, and to the discussion of our findings held with Mr. J. Alberdi at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examination of procedures and representative records, interviews with personnel, and observations by the inspector.

Within the scope of this inspection, no items of noncompliance were disclosed.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you believe to be proprietary, it is necessary that you submit a written application to this office requesting that such information be withheld from public disclosure. If no proprietary information is identified, a written statement to that effect should be submitted. If an application is submitted, it must fully identify the bases for which information is claimed to be proprietary. The application should be prepared so that information sought to be withheld is incorporated in a separate paper and referenced in the application since the application will be placed in the Public Document Room. Your application, or written statement, should be submitted to us within 20 days. If we are not contacted as specified, the enclosed report and this letter may then be placed in the Public Document Room.

8002 270 734


NOV 9 1976

Florida Power Corporation

-2-

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Very truly yours,



F. J. Long, Chief
Reactor Operations and
Nuclear Support Branch

Enclosure:

IE Inspection Report No.

50-302/76-17

cc: Florida Power Corp.

G. P. Beatty, Jr.

P. O. Box 1228

Crystal River, Fla. 32629

SUMMARY OF FINDINGS

I. Enforcement Items

None

II. Licensee Action on Previously Identified Enforcement Matters

Not inspected.

III. New Unresolved Items

None

IV. Status of Previously Reported Unresolved Items

75-19/4 Testing of Radioactive Waste Sample Lines

A program for the testing of the sample lines has not been developed. This item remains open.

75-19/6 Evaluation of Sampling Media Collection Efficiencies

The licensee's evaluation of the collection efficiencies is incomplete. This item remains open.

V. Unusual Occurrences

None

VI. Other Significant Findings

None

VII. Management Interview

At the conclusion of the inspection a management interview was held on October 1, 1976, with J. Alberdi, Project Manager, and members of the corporate and plant staffs. Items discussed included the status of previously identified unresolved items, the status of preoperational testing, the status of plant procedures and the inspector's observations during the inspection.