



Supplementary Information

1. Report No.: 50-302/77-58
2. Facility: Crystal River Unit #3
3. Report Date: 13 July 1977
4. Occurrence Date: 20 June 1977

5. Identification of Occurrence:

Failure to demonstrate the operability of the nuclear services closed cycle cooling system within the time frame required by Technical Specification 4.7.3.1 and 4.3.3.5.

6. Conditions Prior to Occurrence:

Mode 1 power operation

7. Description of Occurrence:

At 1530 while reviewing completed surveillance procedures, it was discovered that the surveillance procedure for nuclear services cooling system operability (SP-344) had last been performed on 10 May 1977. A change to the surveillance schedule had been effected in order to comply with the ASME Section XI and SP-344 was scheduled and completed on 24 June 1977. The new surveillance schedule will insure Tech Specs frequency requirements are met.

8. Designation of Apparent Cause:

The schedule of surveillance procedures was changed to comply with the new ASME Section XI requirements causing a shift in scheduling dates.

9. Analysis of Occurrence:

There were no safety implications as the cooling system was in operation during this period except for plant outage period.

10. Corrective Action:

The new surveillance schedule will preclude recurrence of this event.

11. Failure Data:

There have been no previous occurrences of this event from this cause.