



UNITED STATES
ATOMIC ENERGY COMMISSION
DIVISION OF COMPLIANCE
REGION II - SUITE 818
230 PEACHTREE STREET, NORTHWEST
ATLANTA, GEORGIA 30303

TELEPHONE: (404) 526-4503

January 7, 1971

J. B. Henderson, Chief, Reactor Construction Branch
Division of Compliance, Headquarters

FLORIDA POWER CORPORATION (CRYSTAL RIVER 3), LICENSE NO. CPPR-51,
DOCKET NO. 50-302

The attached report of a special announced inspection at the subject site on December 20-21, 1971, is forwarded for information. The inspection was made in response to a memorandum dated December 7, 1971, from P. A. Morris to L. D. Low in which we were asked to confirm that the foundation grouting program was accomplished as described in the application. The findings of this inspection indicate that the grouting was satisfactorily completed as described.

C. Moseley for
N. C. Moseley
Senior Reactor Inspector

CO:II:NCM

Enclosure:
CO Rpt. No. 50-302/71-6
(Warnick, Beratan)

cc w/encl:
E. G. Case, DRS (3)
R. S. [unclear], DRL (2)
R. J. DeYoung, DRL (2)
D. S. Skovholt, DRL (3)
H. R. Denton, DRL (2)
A. Giambusso, CO
L. Kornblith, Jr., 70
R. H. Engelken, CO
J. P. O'Reilly, CO:I
B. H. Grier, CO:III
J. W. Flora, CO:IV
R. W. Smith, CO:V
CO Files
DR Central Files

8002280758

20037