

B0810/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)
DISTRIBUTION FOR INCOMING MATERIAL

50-302

REC: REID R W
NRC

ORG: STEWART W P
FL PWR

DOC DATE: 08/04/78
DATE RCVD: 08/08/78

DOCTYPE: LETTER NOTARIZED: YES
SUBJECT:

COPIES RECEIVED
LTR 3 ENCL 0

RESPONSE TO NRC LTR DTD 07/06/78... FURNISHING INFO CONCERNING TWO STAFF
POSITIONS RE CLEARING AND SHARED ANNUNCIATORS, AND LOCKOUT RELAYS OF SUBJECT
FACILITY'S DIESEL GENERATOR SYSTEM... NOTARIZED 08/04/78.

PLANT NAME: CRYSTAL RIVER #3

REVIEWER INITIAL: XJM
DISTRIBUTOR INITIAL: *m*

***** DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS *****

DIESEL ALARM CIRCUITRY FOR DIESEL GENERATORS.
(DISTRIBUTION CODE A005)

FOR ACTION: BR CHIEF ORB#4 BC**LTR ONLY(7)

INTERNAL:	REG FILE**LTR ONLY(1)	NRC PDR**LTR ONLY(1)
	I & E**LTR ONLY(2)	OELD**LTR ONLY(1)
	MIPC**LTR ONLY(1)	HANAUER**LTR ONLY(1)
	AUXILIARY SYS BR**LTR ONLY(1)	I & C SYSTEMS BR**LTR ONLY(1)
	AD EOP SYS & PROJ**LTR ONLY(1)	ENGINEERING BR**LTR ONLY(1)
	REACTOR SAFETY BR**LTR ONLY(1)	PLANT SYSTEMS BR**LTR ONLY(1)
	EEB**LTR ONLY(1)	POWER SYS BR**LTR ONLY(1)
	T. WAMBACH**LTR ONLY(1)	

EXTERNAL: LPDR'S
CRYSTAL RIVER, FL**LTR ONLY(1)
ACRS CAT B**LTR ONLY(16)


DISTRIBUTION: LTR 40 ENCL 0
SIZE: 2P

CONTROL NBR: ~~722007~~

MR 4 60

***** THE END *****

8008130752 P



**Florida
Power**
CORPORATION

W. P. STEWART, DIRECTOR
POWER PRODUCTION

August 4, 1978

Mr. Robert W. Reid
Branch Chief
Operating Reactors Branch #4
Division of Operating Reactors
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Subject: Crystal River Unit 3
Operating License No. DRP-72
Docket No. 50-302

Dear Mr. Reid:

In your letter of July 6, 1978, you requested Florida Power Corporation to provide, within 30 days, a statement that our diesel generator system at CR#3 meets the two staff positions attached to your letter.

Since receipt of your letter we have reviewed the diesel generator system design and wish to offer the following statements with regard to the two staff positions:

1. The CR#3 diesel generator system meets the requirements of the staff's position concerning clearing of shared annunciators. Before an alarm which is shared with a number of other alarms can be cleared, all abnormal conditions must be removed first.
2. The CR#3 diesel generator system meets the staff's second position statement as our system has no manual lockout relays.

Should you require additional information or discussion concerning our response, please feel free to contact this office.

Very truly yours,

FLORIDA POWER CORPORATION

W. P. Stewart

W. P. Stewart

RMB/lld/F01

File: 3-0-3-a-3


~~7822000/8~~

Aug 5
3/0

STATE OF FLORIDA

COUNTY OF PINELLAS

W.P. Stewart states that he is the Director, Power Production, of Florida Power Corporation; that he is authorized on the part of said company to sign and file with the Nuclear Regulatory Commission the information attached hereto; and that all such statements made and matters set forth therein are true and correct to the best of his knowledge, information and belief.



W.P. Stewart

Subscribed and sworn to before me, a Notary Public in and for the State and County above named, this 4th day of August, 1978.

Notary Public

Notary Public, State of Florida at Large,
My Commission Expires: July 25, 1980