

ticket file

JAN 31 1974

POOR ORIGINAL

V. A. Moore, Assistant Director for Light Water Reactors, Group 2, L

CRYSTAL RIVER UNIT 3 SE INPUT

PLANT NAME: Crystal River Unit 3
LICENSING STAGE: OL
DOCKET NUMBER: 50-302 ✓
RESPONSIBLE BRANCH: LWR 1; B. Buckley, LPM
REQUESTED COMPLETION DATE: January 15, 1974
APPLICANT'S RESPONSE DATE NECESSARY FOR NEXT ACTION PLANNED ON PROJECT: N/A
DESCRIPTION OF RESPONSE: N/A
REVIEW STATUS: Accident Analysis Branch Review Complete

Enclosed is our Safety Evaluation Input for Crystal River Unit 3. Also included is a bibliography for our Branch review. We have also used, but not listed, AEC Regulations and Safety Guides as part of our evaluation. A bibliography covering sprays and filters is now in CRSS and will be forwarded as soon as it is completed.

The ventilation system filter train for the spent fuel pool area is not designed as a seismically Class 1 system. However, the doses without filters are within the limits of 10 CFR Part 100, and we have concluded that for this plant, at the operating license stage, the computed doses are acceptable.

Original by
H. R. Denton

Harold R. Denton, Assistant Director
for Site Safety
Directorate of Licensing

Enclosure:
SE Input

DISTRIBUTION:

8003180754

cc: See next page

Docket Files (50-302) ✓
 AD/SS/L
 AAB/RDG
 L/RDG

E

OFFICE	AAB/L	AAB/L	AD/SS/L		
SURNAME	Gverrell/Lam	BKGrimes	HRDenton		Memo
DATE	1/23/74	1/3/74	1/3/74		

V. A. Moore

- 2 -

JAN 31 1974

cc w/o enclosure:

A. Giambusso
W. McDonald
A. Kennske
J. Panzarella
SS B/C's

cc w/enclosure:

S. Hanauer
J. Handric
B. Grimes
A. Schwencer
B. Buckley
E. Klacker
D. Eisenhut
S. Varga
J. Carter
C. Farrell

POOR ORIGINAL

OFFICE					
SURNAME					
DATE					