St. Petersburg, Florid	DATE OF DOCUMENT:	0ATE RECEIVED	9-1.7	NO.	ú	
J. T. Rodgers	LTR. MEMO: REPORT: OTHER:					
DRL	ORIG.: CC: OTHER 3 signed & 19 conf 'd					
	ACTION NECESSARY	CONCURRENCE		DATE ANSWERED	•	
CLASSIF: POST OFFICE U REG. NO:	FILE CODE: 50-302					
DESCRIP' Must Be Unclassified)	REFERRED TO	DATE	TE RECEIVED BY		DATE	
LEF TRAS THE FOLLOWING:	W/4 cys for ACTIO	9-1-70 (2 cys	adv F.	Karas)		
	DISTRIBUTION:		DON	IOT RELI	OVE	
AMDT # 10, notarized 8-28-70 consistin	Regulatory File AEC FDR		D.	Thompson		
3 of SUPPL # 5(Report of Tests on 1170	Compliance (2) OGC(Rm P 506A)		DTIE(Laughlin) MSIC(Buchanan)			
info re our ltr req of 3-13-70.	Dube/Wilson Boyd		AEC HQ LIB J 004 ASLB (Yore "H" St)			
(3 Orig signed & 97 conf'd cys es rec'	a) Defoung Howe		Ca	se(Reading	ile)	
REMARKS:	Maccary Dromerick (3)		ACKI	1940 n. Lat		
Holding (18) cys for ACRS	Minogue Moore Rosen			2103	fod	
U.S. AT	OMIC ENERGY COMMISION	MAIL	CONTRO	L FORM FORM	EC-3265	

8003240 897 B



August 28, 1970

The Director Division of Reactor Licensing United States Atomic Energy Commission Washington, D. C. 20545



Dear Sir:

In re: Florida Power Corporation Crystal River Nuclear Generating Plant Docket No. 50-302

Regulatory File Cy.

Enclosed are three (3) executed originals and nineteen (19) conformed copies of Amendment No. 10 consisting of Part III of Supplement No. 5, two insert pages to Supplement No. 5 to the Preliminary Safety Analysis Report, and the remaining information requested in your letter of March 13, 1970. Also enclosed are an additional eighty one (81) copies of each for updating the balance of the copies of the Preliminary Safety Analysis Report filed with the original application.

Amendment No. 10 supplements the Preliminary Safety Analysis Report so as to include the latest design information for your continuing review.

Amendment No. 10 material includes two amended pages (x and xi) and Part III of The Prescon Corporation's presentation on "Tests on 1170 Ton Prescon Tendons". This information completes The Prescon Corporation's report on the tendon system.

In accordance with a request noted in your letter of March 13, 1970, the prestressing system anchorage component "materials description and fabrication process summary" is as follows:



27539

The Director Division of Reactor Licensing

- 2 -

# Materiais Description

....

The acceptance criteria and the proposed materials for the anchorage components is as follows:

Component	fy (ksi) min.	fu (ksi) min.	NDTT (max)	Location	Material	
Bearing	50	90	-15°F	Mat only	ASTM A533 Grade B Class 2	
Plate				All others	Modified Armco VNT <sup>1</sup> (Covered by proposed ASTM A633-E single normalized)	
Dead End	50	90	-15°F	A11	Modified Armco VNT <sup>1</sup> (Covered by proposed ASTM A633-E double normalized)	
Shims	50	90	-15°F	All	Modified Armco VNT <sup>1</sup> (Covered by proposed ASTM A633-2) 3" plate single normalized, 4" plate double normalized	
Stressing Washer	60	100	-15°F	A11	Either Q & T Alloy steel forging, chemistry of ASTM A514 type E - double quenched and tempered or Luken's Q & T Alloy steel plate (Modified ASTM A517, Gr. F) <sup>2</sup>	
<sup>1</sup> Chemical c	ompositi	on for m	odified A	rmco VNT:		
Carbon Manganes Vanadium Silicon	0.25% e 1.30% 0.12% 0.15%	maximum to 1.65% to 0.17% to 0.30%	к к	Nitrogen Phosphorus Sulfur	0.01% to 0.02% 0.035% maximum 0.040% maximum	
<sup>2</sup> Modificati	ons to A	STM A517	, Grade F	1		
Chemistr Gage - 6 Physical	y - Max. inches Propert:	N - 1.5% thick ies - as	%, Max. M above	n - 1.3%		

The above criteria were developed in conjunction with the tendon test program reported in Supplement 5 to the Preliminary Safety Analysis Report.

The Director Division of Reactor Licensing

...

- 3 -

## Fabrication of Anchorage Components

## Fabrication Process Summary

- 1. Bearing Plates:
  - a. Plate is flame-cut to size.
  - b. Central hole is flame-cut.
  - c. Mounting holes are jig-drilled and tapped.
  - d. Trumpet is positioned concentric with central hole and welded using a seal weld.

## 2. Dead End Plates:

- a. Plate is flame-cut to size.
- b. Mounting holes are jig-drilled.
- c. Wire holes are drilled.
- 3. Shims:
  - a. Plate is flame-cut to size.

### 4. Stressing Washers:

- I. Forging
  - a. Billet is cut and forged.
  - b. Forging is double quenched and tempered.
  - c. The heat treated forging is threaded externally.
  - d. Wire holes are drilled.
  - e. Mounting holes are jig-drilled and tapped.
- II. Plate
  - a. The double quenched and tempered plate is preheated and the scressing washer cut from plate.
  - b. Stressing washer is stress relieved after flame cutting.

The Director Division of Reactor Licensing

- 4 -

August 28, 1970

- c. Stressing washer is threaded externally.
- d. Wire holes are drilled.
- e. Mounting holes are jig-drilled and tapped.

#### Effects of Fabrication

1. Flame Cutting:

Results of tests and studies by AWS and ASME show that flame cut surfaces of low carbon content (less than 0.25%) and low alloy steels are at least equal in mechanical properties to the uncut metal. (See AWS Handbook, Section 3A of the Sixth Edition).

2. Welding:

The welding procedures and operators were qualified under the AWS recommended practices. The effects of welding upon the mechanical properties are not detrimental due to the low carbon content.

3. Machining (drilling, tapping, threading):

Production type components were tested and reported in Supplement No. 5. No detrimental effects on the machined surfaces were noted.

4. Stress Relieving (Stressing washer cut from plate):

The stressing washer is heated in a furnace to approximately 1150°F and held for sufficient time to reduce the surface hardness for subsequent threading operations.

The prestressing system anchorage component materials listed above meet the criteria as outlined in our letter of March 4, 1970.

Very truly yours,

gers

J. T. Rodgers V Nuclear Project Manager

JTR/sd