

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A | R | A | N | 0 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | - | 0 | 0 | 4 | 1 | 1 | 1 | 1 | _____ (5)

7 8 9 14 15 25 26 30 37 CAT 38

LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T

0 1 | L | 0 | 5 | 0 | 0 | 0 | 3 | 6 | 8 | 7 | 0 | 1 | 2 | 9 | 8 | 0 | 0 | 1 | 2 | 8 | 8 | 0 | _____ (9)

7 8 80 81 60

REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | During Mode 3 operation following a Reactor Trip from 100% power, an

0 3 | Iodine-131 dose equivalent value of 1.67 microcuries per gram was

0 4 | observed, contrary to the Tech. Spec. limit per 3.4.8.a. There have been

0 5 | no similar occurrences.

0 6 | Reportable per Tech. Spec. 6.9.1.9.b.

0 7 | _____

0 8 | _____

0 9 | C | G | X | Z | Z | Z | Z | Z | Z | Z | Z | Z | Z | Z | _____ (16)

7 8 9 10 11 12 13 14 15 16 17 18 19 20

SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SURCODE

17 | LER/RO REPORT NUMBER | 8 | 0 | _____ (21) | _____ (22) | 0 | 0 | 9 | _____ (24) | _____ (26) | 0 | 3 | _____ (28) | L | _____ (30) | _____ (31) | 0 | _____ (32)

21 22 23 24 26 27 28 29 30 31 32

EVENT YEAR SEQUENTIAL REPORT NO OCCURRENCE CODE REPORT TYPE REVISION NO

18 | Z | 19 | Z | 20 | Z | 21 | Z | 22 | 0 | 0 | 0 | 27 | 28 | N | 23 | 24 | N | 25 | A | 26 | Z | 9 | 9 | 9 | _____ (26)

33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was caused by an expected spike following a reactor trip. No

1 1 | corrective action was necessary as the Chemical and Volume Control System,

1 2 | returned the DEI-131 to within acceptable limits.

1 3 | _____

1 4 | _____

1 5 | B | 28 | 0 | 0 | 0 | 0 | 29 | Pwr. Esc. Testing | B | 31 | Chem/Rad Analysis | _____ (32)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

FACILITY STATUS % POWER OTHER STATUS (30) METHOD OF DISCOVERY DISCOVERY DESCRIPTION (32)

1 6 | Z | 33 | Z | 34 | NA | _____ (35) | NA | _____ (36)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

RELEASED OF RELEASE AMOUNT OF ACTIVITY (35) LOCATION OF RELEASE (36)

1 7 | 0 | 0 | 0 | 0 | 37 | Z | 38 | NA | _____ (39)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION (39)

1 8 | 0 | 0 | 0 | 40 | NA | _____ (41)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

PERSONNEL INJURIES NUMBER DESCRIPTION (41)

1 9 | Z | 42 | NA | _____ (43)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION (43)

2 0 | N | 44 | NA | _____ (45)

7 8 9 10 11 12 13 14 15 16 17 18 19 20 21 22 23 24 25 26 27 28 29 30 31 32

ISSUED DESCRIPTION (45) PUBLICITY

NAME OF PREPARER: Rex Pendergraft PHONE: 501/968-2519

8008810 390