



MATERIAL TRANSMITTED HERewith
CONTAINS 2.760 INFORMATION

UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

JAN 18 1980

Report No. 50-348/79-41

Docket No. 50-348

License No. NPF-2

Licensee: Alabama Power Company
Attn: F. L. Clayton, Jr.
Senior Vice President
Post Office Box 2641
Birmingham, Alabama 35291

Facility Name: Farley 1

Inspection at: Ashford, Alabama

Inspection conducted: December 10-14, 1979

Date of Last Physical Security Inspection Visit: March 12-16, 1979

Type of Inspection: Unannounced Physical Security

Inspectors: J. C. Howell 1-15-80
J. C. Howell, Physical Security Inspector Date

Approved by: William J. Tobin 1-17-80
W. J. Tobin, Acting Section Chief, S&I Section Date
Safeguards Branch

Summary

Areas Inspected: Included review of security plan, security program audit, security organization, protected and vital area physical barriers, lighting, access controls, detection aids, assessment aids, communications, testing and maintenance, compensatory measures, response, locks/keys, testing/maintenance and licensee action on previous inspection findings.

The inspection involved 36 inspector hours on site by 1 NRC inspector. The inspection was begun during an offshift period; 6 inspection hours were accomplished during offshift periods.

Results: The licensee was found to be in compliance with NRC requirements within the areas examined during the inspection except for the following item:

Testing and Maintenance - One intrusion alarm test was not conducted during the period examined (Deficiency 79-41-01)

S-F2 80 - 05P
Copy _____ of _____ Copies
9 Pages
This Document is not to be
reproduced without specific
approval of NRC
8008810 398

MATERIAL TRANSMITTED HERewith
CONTAINS 2.760 INFORMATION