



TERA

CHARLES CENTER • P.O. BOX 1475 • BALTIMORE, MARYLAND 21203

ELECTRIC ENGINEERING
DEPARTMENT

March 29, 1980

Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attn: Mr. D. G. Eisenhut
Acting Director
Division of Operating Reactors

Subject: Calvert Cliffs Nuclear Power Plant
Unit No. 2, Docket No. 50-318
Westinghouse Low Pressure Turbine Disc Inspection

Reference: BG&E letter dated 3/18/80 from A. E. Lundvall, Jr.
to D. G. Eisenhut, same subject.

Gentlemen:

Please revise Service Data Items G.2, G.3, and G.4 of
Attachment 3 to the referenced letter. The correct data are shown on
the attached sheet. We apologize for any inconvenience.

Very truly yours,

R. C. L. Olson
Senior Engineer

RCLO/smn

cc: J. A. Biddison, Esquire
G. F. Trowbridge, Esquire
Mr. E. L. Conner, Jr.

AΦΦL
5
111

P

8004010 212;

REVISED DATA
CALVERT CLIFFS UNIT NO. 2 LP TURBINE DISC INFORMATION

SERVICE DATA ITEMS G.2, G.3, G.4 ON ATTACHMENT 3 TO
 BG&E LETTER DATED 3/18/80

UNIT IDENTIFICATION LP#/LOCATION/DISC#	SERVICE DATA G.2 DA/DT (in/hr)	SERVICE DATA G.3 CALCULATED CRACK LENGTH (in)	SERVICE DATA G.4 A/A _{cr} (crack ratio)
1 GOV 1 2 3 4 5 6 GEN 1 2 3 4 5 6	0 .227 - 004 .785 - 005 .347 - 005 .228 - 005 0 0 .227 - 004 .785 - 005 .347 - 005 .228 - 005 0	0 .67 .23 .11 .067 0 0 .67 .23 .11 .067 0	-- .102 .032 .022 .015 -- -- .142 .038 .020 .011 --
2 GOV 1 2 3 4 5 6 GEN 1 2 3 4 5 6	0 .227 - 004 .785 - 005 .347 - 005 .228 - 005 0 0 .227 - 004 .785 - 005 .347 - 005 .228 - 005 0	0 .67 .23 .11 .067 0 0 .67 .23 .11 .067 0	-- .138 .038 .022 .015 -- -- .132 .036 .021 .016 --
3 GOV 1 2 3 4 5 6 GEN 1 2 3 4 5 6	0 .227 - 004 .785 - 005 .347 - 005 .228 - 005 0 0 .227 - 004 .785 - 005 .347 - 005 .228 - 005 0	0 .67 .23 .11 .067 0 0 .67 .23 .11 .067 0	-- .126 .042 .023 .015 -- -- .134 .045 .024 (No Data) --