

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

716 Edney Building

MAR 24 1980

Mr. James P. O'Reilly, Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - SEQUOYAH NUCLEAR PLANT UNIT 1 - DOCKET
NO. 50-327 - FACILITY OPERATING LICENSE DPR-77 - REPORTABLE OCCURRENCE
REPORT SQRO-50-327/8003

The enclosed report provides details concerning the loss of sample flow
through the iodine particulate filters in the auxiliary building ventilation
system gaseous effluent monitor. This report is submitted in accordance
with Sequoyah unit 1 Technical Specification 6.9.1.12.b.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

J. R. Calhoun
Director of Nuclear Power

Enclosure (3)

cc (Enclosure):

Director (3)
Office of Management Information and Program Control
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Director (40)
Office of Inspection and Enforcement
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. Bill Lavalise
Nuclear Safety Analysis Center
Palo Alto, California 94303

Mr. W. T. Cottle, NRC Inspector, Sequoyah

A002
S
1/1

POOR ORIGINAL