



## NARRATIVE REPORT

Georgia Power Company  
Plant E. I. Hatch  
Baxley, Georgia 31513

Reportable Occurrence Report No. 50-366/1980-025.

On March 8, 1980, during shutdown while performing RHR (LPCI) Pump Start Timers Calibration, relay 2E11-K75A was found to trip at 13 seconds, which exceeded Tech Spec Table 3.3.3-2, item 2.f.1, setpoint of  $10 \pm 1$  seconds. The associated time delay relays for RHR pumps 2E11-C002A,B and C were operable at the time.

The cause of this occurrence has been attributed to instrument drift. The instrument was recalibrated per General Electric Type CR2820 Time Delay Relay Calibration Procedure, and returned to service. This has not been a re-occurring problem. Unit I utilizes the same type of relays.

There was no effect upon public health or safety.