

ATTACHED IS A PART 21 REPORT FROM IE MAIL UNIT - ROOM 359E/W

PART 21 IDENTIFICATION NO. 80-191-002 COMPANY NAME Colt Industries

DATE OF LETTER 3/6/80 DOCKET NO. 50-375

DATE DISTRIBUTED 3/11/80 ORIGINAL REPORT SUPPLEMENTARY

DISTRIBUTION:

REACTOR(R)

FUEL CYCLE &

SAFEGUARDS(S)

MATERIALS(M)

NRR/DOR, DIRECTOR

AD/FFMSI

AD/SG-IE

NRR/DPM DIRECTOR

NMSS/FCMS

AD/ROI

AD/ROI (2)

REGIONS

REGIONS

AD/RCI

IE FILES

NRR/DOR, DIRECTOR

REGIONS

PDR

NMSS/SG SS-881

~~IE FILES (2)~~

LPDR

PDR

CENTRAL FILES

CENTRAL FILES-SS-396

LPDR

CENTRAL FILES (CHRON)

CENTRAL FILES(CHRON)
(016)

TERA

~~PDR~~

IE FILES (2)

LPDR

TERA

CENTRAL FILES 016

~~TERA~~

LOEB/MPA MNB 5715

CENTRAL FILES (CHRON)

LOEB/MPA MNB 5715

CENTRAL FILES - SS-396

LOEB/MPA MNB 5715

ACTION:

PRELIMINARY EVALUATION OF THE ATTACHED REPORT INDICATES LEAD RESPONSIBILITY FOR FOLLOW-UP AS SHOWN BELOW:

IE

NRR

NMSS

OTHER

~~RCI~~

ROI
SG
FFMSI

Colt Industries



Fairbanks Morse
Engine Division
701 Lawton Avenue
Beloit, Wisconsin 53511
608/364-4411

*Sent to X005
3-10-80.*

80-191-002

March 6, 1980

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Ill. 60137

Attention: Mr. James G. Keppler, Director, Region III

Subject: Colt Industries-Fairbanks Morse Engine Division
Emergency Diesel Generators
South Carolina Electric & Gas Co.-Summer Station
January 14, 1980 Part 21 Report-Failed Engine Thrust Bearing
Supplement No. 2
Second Summer Station Unit ("A" Unit)


Gentlemen:

We have completed our inspection of the crankshaft thrust bearing on the "A" generator set at South Carolina Electric & Gas Co., Summer Station. The plugs were properly installed in this unit. The unit is free of the reported potential defect.

We will be inspecting other shipped units prior to initial operation and will report the results of those inspections as they are made.

A copy of this report is being forwarded to the utility involved.

Very truly yours,


J. M. Moriarty
MANAGER UTILITY SALES

JMM:jc

cc: South Carolina Electric & Gas Co.
P. O. Box 764
Columbia, South Carolina 29210
Attention: Mr. Dan Nauman
Manager, Quality Assurance & Security

10 10 1980