

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
THE HARTFORD ELECTRIC LIGHT COMPANY
THE NEW HAVEN ELECTRIC COMPANY
THE WATERBURY ELECTRIC COMPANY
THE WASHINGTON MASSACHUSETTS ELECTRIC COMPANY
THE WASHINGTON WATER POWER COMPANY
THE WASHINGTON WATER SUPPLY COMPANY
THE WASHINGTON WATER SUPPLY COMPANY

P.O. BOX 270
HARTFORD, CONNECTICUT 06101
(203) 666-6911

March 31, 1980

Docket No. 50-336

Director of Nuclear Reactor Regulation
Attn: Mr. R. Reid, Chief
Operating Reactors Branch #4
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

- References: (1) D. G. Eisenhower letter to W. G. Council dated October 11, 1979.
(2) W. G. Council letter to D. G. Eisenhower dated November 28, 1979.

Gentlemen:

Millstone Nuclear Power Station, Unit No. 2
Proposed Revisions to Technical Specifications

In Reference (1), Northeast Nuclear Energy Company (NNECO) was requested to review Millstone Nuclear Power Station, Unit No. 2, against the applicable requirements of Enclosure (1) of Reference (1). The results of that evaluation and a schedule and commitment for implementation of changes were provided in Reference (2). Included in Reference (2) was a commitment to propose Technical Specifications by April 1, 1980 to add a Surveillance Requirement for an auxiliary feedwater flow test to be performed after a cold shutdown of greater than one month duration.

Pursuant to 10CFR50.90, NNECO hereby proposes to amend its operating license, DPR-65, by incorporating the changes identified in the attachment into the Millstone Unit No. 2 Technical Specifications.

The change proposes to add a Surveillance Requirement for an auxiliary feedwater flow test that verifies the flow path from the condensate storage tank (CST) to the steam generators, before entering MODE 3 after a cold shutdown of at least thirty (30) days. This change will enhance plant safety by verifying the operability of the auxiliary feedwater system after a shutdown of extended duration.

The above proposed changes have been reviewed pursuant to 10CFR50.59 and have not been found to constitute an unreviewed safety question.

8004030232


The Millstone Unit No. 2 Nuclear Review Board has reviewed and approved the above-proposed changes and concurred in the above determination.

NNECO has reviewed the proposed license amendment pursuant to the requirements of 10CFR170 and has determined that no fee is applicable in this instance. The basis for this determination is that the proposed change is the direct result of an NRC Staff requirement documented in Reference (1). In addition, this proposed change is administrative in nature and as such, will not require technical review.

We trust you find this information responsive to the Reference (1) requests.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY



W. G. Council
Vice President

Enclosure

WGC/MPC/jfp

STATE OF CONNECTICUT)

) ss. Berlin

COUNTY OF HARTFORD)

March 31, 1980

Then personally appeared before me W. G. Council, who being duly sworn, did state that he is Vice President of Northeast Nuclear Energy Company, a Licensee herein, that he is authorized to execute and file the foregoing information in the name and on behalf of the Licensees herein and that the statements contained in said information are true and correct to the best of his knowledge and belief.

Sheila M. Oates
Notary Public

My Commission Expires March 31, 1981