



ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

April 3, 1980

1-040-03  
2-040-02

Director of Nuclear Reactor Regulation  
ATTN: Mr. Darrell G. Eisenhut, Director  
Operating Reactors  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Subject: Arkansas Nuclear One-Units 1 and 2  
Docket Nos. 50-313 and 50-368  
License Nos. DPR-51 and NPF-6  
Quality Assurance Requirements  
Regarding Diesel Generator Fuel Oil  
(File: 3160, 2-3160)

Gentlemen:

Your letter of January 7, 1980 stated the regulatory staff's position that diesel generator fuel oil be included in our Quality Assurance Program. The letter also pointed out that because the diesel fuel was not on the Q list for ANO-1 and 2, it was not included in our Quality Assurance Program.

A review of our program indicated that diesel fuel is included in our program. Section 2.6.3 of Revision 5 of our Quality Assurance Manual includes diesel fuel in our program. We feel this meets the requirements of ANO-1 Technical Specification 4.6.1.4(e) and ANO-2 Tech. Spec. 4.8.1.1.2.(b).

Very truly yours

*David C. Trimble*

David C. Trimble  
Manager, Licensing

DCT:MAS:sh