

APPENDIX A

NOTICE OF VIOLATION

Power Authority of the State of New York

Docket No. 50-333

Based on the results of an NRC inspection conducted on December 12-14, 1979, it appears that one of your activities was not conducted in full compliance with NRC regulations and the conditions of your license as indicated below. This item is an infraction.

10 CFR 50, Appendix B, Quality Assurance Criteria for Nuclear Power Plants and Fuel Reprocessing Plants, Criterion II, "Quality Assurance Program," states, in part, "The applicant shall establish... a quality assurance program which complies with the requirements of this appendix... the program shall provide for indoctrination and training of personnel..."

The licensee's accepted Quality Assurance Program states in Section II, Subsection 2.8, that, "Education and training at the plant shall be provided for personnel engaged in activities affecting quality, as necessary, for the purpose of achieving and maintaining a suitable level of proficiency in their respective functions. The training program shall be applicable to both headquarters and plant personnel... A training procedure shall be established which will include provisions to implement an adequate training program and shall include provisions for maintaining training records which indicate such items as identification of specific training function, personnel in attendance, date of training and instructor."

The licensee's "Indoctrination and Training Procedure #3, General Employee Training," Revision 0, dated October 28, 1977, requires, in part, in Section 3.5.6, "General Employee Training," that, "Plant personnel qualified in radiation protection shall be provided with annual retraining."

Contrary to the above requirements, on December 13, 1979, two individuals had not received annual retraining in radiation protection. One individual had exceeded the annual retraining interval by 6 months and the other by 10 months.