

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone 205 323-5341



Alabama Power

the southern electric system

F. L. CLAYTON, JR.
Senior Vice President

March 26, 1980

Docket No. 50-348

Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555


Attn: Mr. Darrell G. Eisenhut

Dear Mr. Eisenhut:

As a result of discussions held with the NRC Lessons Learned Review Team on February 29, 1980, and telephone conversations on March 21, 1980, Alabama Power Company commits to installing a backup system to the normal instrument air supply for the pressurizer power operated relief valves (PORV). The design will assure that air is available at all times to operate the PORV's. Installation of the backup system will be completed by the end of the Unit 1 second refueling outage scheduled to begin in October, 1980.

If you have any questions, please contact us.

Yours very truly,


F. L. Clayton, Jr.

FLCJr/BDM:bhj

cc: Mr. R. A. Thomas
Mr. G. F. Trowbridge

am

8004080403

A039
S 1/0