

Thomas J. Martin
Vice President
Engineering and Construction

Public Service Electric and Gas Company 80 Park Place Newark, N.J. 07101 201/430-8316

February 13, 1980

Mr. Boyce H. Grier, Director
U. S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region 1
631 Park Avenue
King of Prussia, Pennsylvania 19406

Dear Mr. Grier:

NRC INSPECTION REPORT 50-354/79-09 and 50-355/79-08
NO. 1 AND 2 UNITS
HOPE CREEK GENERATING STATION

We have received and reviewed the report of your inspection conducted on November 26-30, 1979. The report was transmitted with your letter of January 15, 1980 and received on January 21, 1980.

The subject inspection identified an infraction regarding lack of complete adherence to Bechtel's Specific Work Plan/Procedure, SWP/P-C-1 entitled, "Concrete Operations." The following corrective actions have been taken relative to the infraction:

1. Corrective steps taken by Bechtel and the results achieved:
 - a) New pour cards have been opened to document incomplete repair work where original pour cards were closed. It should be noted that in all cases, Bechtel Quality Control Department's inspection records remained open, pending completion of concrete repairs.
 - b) The Lead Civil Engineer has updated the concrete repair filing system to reflect current status. Included in this update were those new pour cards issued, as described in (a) above.

80041 00 157

Mr. B. H. Grier

-2-


2/13/80

2. Corrective steps taken by Bechtel to avoid further items of noncompliance:
 - a) The procedural requirements (SWP/P-C-1) for closing pour cards and maintaining the concrete repair filing system have been emphasized to responsible personnel.
 - b) SWP/P-C-1, "Concrete Operations" has been revised to require responsible field engineer verification that Quality Control has no open inspection reports prior to final pour card sign-off for each placement.
3. Date when full compliance will be achieved:

Full compliance was achieved prior to February 11, 1980.

If you require additional information, we will be pleased to discuss it with you.

Very truly yours,



CC: Office of Inspection and Enforcement
Division of Reactor Construction and Inspection
Washington, D. C.

H. E. Morris (Bechtel)