

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

TIC  
50-259  
260  
396

March 21, 1980

Mr. James P. O'Reilly, Director  
Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Region II - Suite 3100  
101 Marietta Street  
Atlanta, Georgia 30303

11/11/85 10:20  
NO. 11

Dear Mr. O'Reilly:


OFFICE OF INSPECTION AND ENFORCEMENT (IE) BULLETIN 79-23, DATED  
SEPTEMBER 12, 1979, J. P. O'REILLY TO H. G. PARRIS

In response to IE Bulletin 79-23 we have conducted a sustained full-load operational test on emergency diesel generator 3A at the Browns Ferry Nuclear Plant. The test was completed on January 6, 1980. This test, with a typical diesel generator, demonstrated the ability of the diesel generators to function properly over a 24-hour period at the specified loads.

The successful completion of this testing completes the action required by IE Bulletin 79-23 for Browns Ferry. If you have any questions, please call Jim Domer at FTS 854-2014.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



L. M. Mills, Manager  
Nuclear Regulation and Safety