



**Florida
Power**
CORPORATION

March 24, 1980

File: 3-0-3-a

Mr. Mort B. Fairtile
Project Manager
Operating Reactors Branch No. 4
Division of Operating Reactors
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Subject: Crystal River Unit 3
Docket No. 50-302
Operating License No. DPR-72

Dear Sir:

Attached you will find a copy of proposed changes to the Crystal River Unit 3 Technical Specifications, Appendix A, regarding the items identified in communications which we have had with your Mr. Marty Vigillio, subsequent to issuance of Amendment 20. Amendment 20 incorporated changes to the SHUTDOWN MARGIN requirement for MODES 4 and 5 from $\geq 1\% \Delta k/k$ to $\geq 2.2\% \Delta k/k$.

If you should have any comments or questions concerning these items, please advise.

Very truly yours,

FLORIDA POWER CORPORATION

Ronald M. Bright
Acting Manager
Nuclear Support Systems

RMBekc(TSCRN49(Rev.1))DN-71

Attachments

A001
3
1/1

8004100365