



Telegram

50-313-75-5

319P EST JAN 19 75 AB061

AAE119(1514)(2-009159E019)PD 01/19/75 F514

ICS IPMBNGZ CSP

5012270221 TDBN LITTLE ROCK AR 126 01-19 0314P EST

FMS NORMAN C MOSELEY DIRECTORATE OF REGULATORY OPERATIONS REGION  
2 UNITED STATES ATOMIC ENERGY COMMISSION *DLR*

230 PEACHTREE ST NORTHWEST SUITE 218

ATLANTA GA 30303

SUBJECT ARKANSAS NUCLEAR 1 UNIT 1 NON ROUTINE, NON RADIOLOGICAL  
REPORT NUMBER 50-313-75-5 INVIRONMENTAL TECHNICAL SPECIFICATIONS  
REQUIRE A REPORT IF THE FISH IMPINGED ON THE INTAKE SCREENS  
EXCEED 3,000 POUNDS IN A 24 HOUR PERIOD. FISH IMPINGED DURING  
THE 8TH HOUR PERIOD FROM 8AM TO 4PM ON JANUARY 18 TOTALED 3,410  
POUNDS. PROJECTED FISH IMPINGEMENT FOR THE 24 HOUR PERIOD FROM  
8AM JANUARY 18 TO 8AM JANUARY 19 IS 10,230 POUNDS THIS IS BASED  
SF-1201 ON 8 HOUR SAMPLE. FISH IMPENGED WERE 100 PERCENT SHAD AND

8004110 740



Telegram

98 PERCENT OF THE TOTAL NUMBER WERE THREADFIN SHAD AT 4PM JANUARY

18 THE AIR TEMPERATURE WAS 49 DEGREES F WATER TEMPERATE WAS  
42 DEGREES F LOAD WAS APPROXIMATE 100 PERCENT AND 4 CIRCULATION  
WATER PUMPS WERE RUNNING .

J D PHILLIPS SENIOR VICE PRESIDENT ARKANSAS POWER AND LIGHT  
CO

SF-1201 NNNN