



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TIC

Docket No. 50-346


APR 2 1980

Toledo Edison Company  
ATTN: Mr. Richard P. Crouse  
Vice President  
Nuclear  
Edison Plaza  
300 Madison Avenue  
Toledo, OH 43652

Gentlemen:

IE Circular No. 80-03 dated March 6, 1980, was inadvertently sent to you without the enclosed attachments. We are sorry for any inconvenience this may have caused you.

Sincerely,

  
James G. Keppler  
Director

Attachments: Sections 2.2.1-2.2.2;  
2.2.3 and 6.4 of NUREG 75/087

cc w/attach:  
Mr. T. Murray, Station  
Superintendent  
Central Files  
Director, NRR/DPM  
Director, NRR/DOR  
PDR  
Local PDR  
NSIC  
TIC  
Harold W. Kohn, Power  
Siting Commission  
Helen W. Evans, State  
of Ohio

8004180

060



U.S. NUCLEAR REGULATORY COMMISSION  
**STANDARD REVIEW PLAN**  
 OFFICE OF NUCLEAR REACTOR REGULATION

SECTION 6.4

HABITABILITY SYSTEMS

REVIEW RESPONSIBILITIES

Primary - Accident Analysis Branch (AAB)

Secondary - Hydrology-Meteorology Branch (HMB)  
 Auxiliary Systems Branch (ASB)  
 Effluent Treatment Systems Branch (ETSB)

I. AREAS OF REVIEW

The control room ventilation system and control building layout and structures, as described in the applicant's safety analysis report (SAR), are reviewed with the objective of assuring that plant operators are adequately protected against the effects of accidental releases of toxic or radioactive gases. A further objective is to assure that the control room can be maintained as the center from which emergency teams can safely operate in the case of a design basis radiological release. To assure that these objectives are accomplished the following items are reviewed:

1. The zone serviced by the control room emergency ventilation system is examined to ascertain that all critical areas requiring access in the event of an accident are included within the zone (control room, kitchen, sanitary facilities, etc.) and to assure that those areas not requiring access are generally excluded from the zone.
2. The capacity of the control room in terms of the number of people it can accommodate for an extended period of time is reviewed to confirm the adequacy of emergency food and medical supplies and self-contained breathing apparatus and to determine the length of time the control room can be isolated before CO<sub>2</sub> levels become excessive.
3. The control room ventilation system layout and functional design is reviewed to determine flow rates and filter efficiencies for input into the AAB analyses of the buildup of radioactive or toxic gases inside the control room, assuming a design basis release. Basic deficiencies that might impair the effectiveness of the system are examined. In addition, the system operation and procedures are reviewed. The ASB has primary responsibility in the system review area under Standard Review Plan (SRP) 9.4.1. The ASB is consulted when reviewing hardware and operating procedures.

**USNRC STANDARDS**

Standard review plans are prepared for the guidance of the Office of Nuclear Reactor Regulation. These documents are made available to the general public of regulatory procedures and policies. Standard review plans compliance with them is not required. The standard review plan sections are for Nuclear Power Plants. Not all sections of the Standard Format have a corresponding section in this document.

Published standard review plans will be revised periodically, as appropriate.

Comments and suggestions for improvement will be considered and should be submitted to the Office of Nuclear Reactor Regulation, Washington, D.C. 20545.

DUPLICATE DOCUMENT

Entire document previously entered into system under:

ANO 7901020063

No. of pages: 26