

Official Transcript of Proceedings
NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards
US-APWR Subcommittee: Open Session

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, September 19, 2019

Work Order No.: NRC-0573

Pages 1-131

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS

1323 RHODE ISLAND AVE., N.W.

WASHINGTON, D.C. 20005-3701

(202) 234-4433

www.nealrgross.com

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

+ + + + +

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

US-APWR SUBCOMMITTEE

OPEN SESSION

+ + + + +

THURSDAY

SEPTEMBER 19, 2019

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear
 Regulatory Commission, Two White Flint North, Room
 T2D10, 11545 Rockville Pike, at 8:30 a.m., Matthew W.
 Sunseri, Chair, presiding.

1 COMMITTEE MEMBERS:

2 MATTHEW W. SUNSERI, Chair

3 RONALD G. BALLINGER, Member

4 DENNIS BLEY, Member

5 CHARLES H. BROWN, JR. Member

6 VESNA B. DIMITRIJEVIC, Member

7 WALTER L. KIRCHNER, Member

8 HAROLD B. RAY, Member

9 JOY L. REMPE, Member

10

11 DESIGNATED FEDERAL OFFICIAL:

12 CHRIS BROWN

13

14 STAFF PRESENT:

15 JOHN BUDZYNSKI, NRO/DESR/SRSB

16 LARRY BURKHART, ACRS/TSB

17 DAVID DESAULNIERS, NRR/DIRS

18 BRIAN GREEN, NRR/DIRS/IRAB

19 NADIM KHAN, NRR/DE/EENB

20 JASON PAIGE, NRR/DLP/PLPB

21 SHEILA RAY, NRR/DE/EENB

22 FANTA SACKO, NRR/DE/EENB

23 ANGELO STUBBS, NRO/DESR/SPRA

24 GETACHEW TESFAYE, NRO/DLSE/LB1

25

1 ALSO PRESENT:

2 ETSUKO GOOD, MHI

3 ROBERT HALL, MHI

4 SHINJI KAWANAGO, MHI

5 AKIRA KIRITA, MHI

6 ATSUSHI KUMAKI, MHI

7 KENJI MASHIO, MHI

8 TAKAYUKI MORI, MHI

9 TAKAFUMI OGINO, MHI

10 HIDEKI TANAKA, MHI

11 AKIHIRO TODA, MHI

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24

A G E N D A

Opening Remarks 5

Review History and Future Activities 14

Design Overview 16

MHI

 Chapter 8, "Electric Power" 45

 Chapter 18, "Human Factors Engineering" 69

NRO

 Chapter 8, "Electric Power" 105

 Chapter 18, "Human Factors Engineering" 117

Public Comments 130

Adjourn 131

P R O C E E D I N G S

8:30 a.m.

CHAIR SUNSERI: Good morning. The meeting will now come to order. This is a meeting of the Advisory Committee on Reactor Safeguards US-APWR Subcommittee.

I am Matt Sunseri, Chairman of the US-APWR Subcommittee. Members in attendance today are Ron Ballinger, Harold Ray, Walt Kirchner, Joy Rempe, Charlie Brown, and Dennis Bley. Let's see here. Chris Brown is our Designated Federal Officer for this meeting.

The Subcommittee will review the staff's evaluation of the US-APWR topical report, the advanced accumulator, along with SERs with no open items for Chapter 8 and 18. Today, we have members of the NRC staff and MHI to brief the Subcommittee.

The ACRS was established by statute and is governed by the Federal Advisory Committee Act. The Committee can only speak through our published letter reports. We hold meetings to gather information and perform preparatory work that will support our deliberations at full Committee meetings.

The rules for participation in the ACRS meeting were announced in the Federal Register on June

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 13, 2019.

2 The ACRS section in the USNRC public
3 website provides our charter, bylaws, agendas, letter
4 reports, and full transcripts of all full and
5 subcommittee meetings, including slides presented
6 there. The meeting notice and agenda for this meeting
7 were posted on that website.

8 Portions of this meeting can be closed as
9 needed to protect proprietary information, and we will
10 have a closed meeting today on the advanced
11 accumulator information.

12 As stated in the Federal Register Notice
13 and in the public meeting notice on the website,
14 members of the public who desire to provide written or
15 oral input to the Subcommittee may do so and should
16 contact the Designated Federal Officer five days prior
17 to the meeting, as practical.

18 We have also set aside ten minutes for
19 comments from members of the public in attendance or
20 listening in to our meeting. As a result, though, we
21 have not received any written comments or requests for
22 time to make oral comments from the public regarding
23 today's meeting.

24 A transcript of the meeting is being kept
25 and will be made available on the ACRS section of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 USNRC website. We request that participants in this
2 meeting speak, please use the microphones located
3 throughout the room and speak clearly and identify
4 themselves with sufficient volume so the transcriber
5 can hear.

6 Now, we had a meeting yesterday on human
7 errors, if you will, and we learned that the most
8 error-likely situation in this room is the operation
9 of these microphones. So, think about them kind of
10 like a walkie-talkie, you've got to push the button to
11 talk and then, when you're done, push the button to
12 turn off the mic.

13 The way you do that is, if you take a look
14 at these little speakers right here. So, if you can
15 see, if the green light is on for mine. There's some
16 words at the bottom and one of the words is push. So,
17 if you push that button, the green light comes on, you
18 push it again, the green light goes off. All right?

19 All right. A telephone bridge line has
20 been established for the public to listen in. To
21 minimize disturbance, the public line will be kept in
22 a listen-only mode.

23 And also, we have MHI on their own line,
24 a separate line, of which they can interact with us --
25 or, is that right? They can interact? So, at this

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 time, if the MHI could at least acknowledge that you
2 can hear us and that we can hear you, I would
3 appreciate that. So, somebody on the MHI line, please
4 speak.

5 MR. BURKHART: Chris is opening the line
6 right now.

7 CHAIR SUNSERI: Oh, I thought you said it
8 was going to be --

9 MR. BURKHART: He's doing it right now.

10 CHAIR SUNSERI: Okay. So, we'll have to
11 -- but it will be open throughout the meeting though,
12 right? Okay.

13 MR. BURKHART: Yes, is it ready? We're
14 going to ask them to --

15 CHAIR SUNSERI: They should --

16 MR. KUMAKI: Is MHI attending on the line?

17 PARTICIPANT: Yes, thank you.

18 CHAIR SUNSERI: Okay, very good.

19 MR. KUMAKI: Do you need the name?

20 MR. BURKHART: Do you need a name?

21 CHAIR SUNSERI: Only when they speak, if
22 they could state their name.

23 (Off-microphone comments.)

24 CHAIR SUNSERI: Thank you, we can hear
25 you. To avoid disturbance, I request now that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 attendees put their electronic devices, like cell
2 phones, in the off or noise-free mode. And I have
3 just a few remarks before we get started with the
4 agenda.

5 So, this is going to be a review of a
6 pressurized water reactor. And the Committee has a
7 lot of experience with pressurized water reactors.
8 So, as we go through the overview, just keep in mind
9 that we are experienced in this area and you don't
10 have to emphasize every aspect of the PWR, but focus
11 on the unique aspects as it relates to this design,
12 and that will help move the meeting along.

13 As far as the Committee goes, and for the
14 Applicant, we are entering something we call the Phase
15 4 review of this application. Phase 4 means we'll be
16 looking at the staff's Safety Evaluation Report with
17 no open items, all right? So, keep that in mind as we
18 go through here, and I'll ask the Committee members to
19 think about the process-wise.

20 In some of our more recent Applicants,
21 when we enter the Phase 4, we're testing a new way of
22 doing business, right? What we are following with
23 this application is the old way of doing business, all
24 right? So, we may think about making a shift, as we
25 have done with the more recent Applicants. So, think

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 about that and we'll take comments at the end.

2 Also, there's a large amount of material
3 that's going to be presented today, and some of what
4 we're going to hear about in Chapters 8, 18, and the
5 accumulator, may be in the overview as well.

6 So, I ask members to hold your comments on
7 any material that would be related to 8, 18, or the
8 accumulator until we get to those specific chapters,
9 unless it's necessary to clarify some point or
10 something else. So, the intention is not to get into
11 the details during the overview, but we'll get into
12 details during the chapter review.

13 Something that you will see that is unique
14 today, that I've not experienced in these meetings is,
15 we have an interpreter back here and the interpreter
16 is to aid the Applicant if through my Texas English,
17 which sometimes is not completely understandable, that
18 they have to translate for the Applicant.

19 (Laughter.)

20 MEMBER BLEY: Will she do both English and

21 --

22 MEMBER REMPE: And Texas?

23 CHAIR SUNSERI: English and Texas, right,
24 yes.

25 (Laughter.)

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: Right. And I've already
2 mentioned that we have MHI on the line. So, Chris,
3 you have something you want to add?

4 MR. BROWN: The MHI line, open all the
5 time?

6 CHAIR SUNSERI: Yes, we want them --

7 MR. BROWN: Okay.

8 CHAIR SUNSERI: -- to be able to interact.

9 MR. BROWN: Okay.

10 MEMBER BLEY: Matt?

11 CHAIR SUNSERI: Yes?

12 MEMBER BLEY: Can I ask that the speakers
13 really emphasize anything that's changed since the
14 last time around?

15 CHAIR SUNSERI: Okay, yes. And then, the
16 last point I was going to make, and I should have made
17 this during the processes, we've had extensive review
18 of this application already, and I think George is
19 going to give an overview, but we've written eight
20 letters already.

21 And we've written two letters on the
22 topics that we're going to be talking about today.
23 So, we've written letters on Chapter 8 and the
24 accumulator topical report. We held a meeting on 18,
25 but for whatever reason, we did not write a letter.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, that's kind of the status of where we are. I have
2 the letters here with me, if anybody wants to look at
3 them.

4 But the two points of interest that we had
5 from the last review are in the area of Chapter 8, we
6 wanted confirmation that the published reliability
7 estimates for gas turbine generator emergency power
8 supplies account for all relevant ancillary and
9 support equipment that is included in the reliability
10 for emergency use of generators. So, that's something
11 we can quiz how they do that would be different than
12 last time.

13 And then, the accumulator --

14 MEMBER BROWN: Was that the only Chapter
15 8 issue?

16 CHAIR SUNSERI: That was the only Chapter
17 8 issue --

18 MEMBER BROWN: The open phase thing was a
19 later thing that we did not review at that time, that
20 came up later, and I see the SER and the Applicant --

21 CHAIR SUNSERI: Probably.

22 MEMBER BROWN: -- covered that --

23 CHAIR SUNSERI: Probably.

24 MEMBER BROWN: -- in the revised
25 documents.

1 CHAIR SUNSERI: We did have a generic
2 statement in all of them that we would anticipate that
3 any open items that the staff had would be closed, and
4 that's the case too. So --

5 MEMBER BROWN: I'd also like --

6 CHAIR SUNSERI: -- there were --

7 MEMBER BROWN: I'd like to --

8 CHAIR SUNSERI: -- a few of those.

9 MEMBER BROWN: -- comment. It was seven
10 years ago when we looked at --

11 CHAIR SUNSERI: Yes, that was --

12 MEMBER BROWN: -- maybe even eight years
13 ago.

14 CHAIR SUNSERI: That was 2011.

15 MEMBER BROWN: Yes, 2010 for some of them.

16 CHAIR SUNSERI: And in 2014, we looked at
17 the accumulator and our only concern with that was
18 that we concur with the staff's recommendation to
19 increase uncertainties that are used in the loss of
20 coolant analysis for high-flow and low-flow injection
21 regimes.

22 And I'm just going to stop there, because
23 for whatever reason, we chose to write a proprietary
24 letter and this has proprietary markings all through
25 it. So, when we get to the accumulator section, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 know I've talked to the Applicant already, they've
2 done a lot of work in this area and we'll get to hear
3 the big difference there.

4 So, any other comments before we -- all
5 right. I think that suffices for an introduction.
6 So, at this point, I would like to turn to George
7 Wunder for any opening remarks. George is the Project
8 Manager for this review.

9 MR. WUNDER: I'll be very brief. Good
10 morning, Mr. Chairman, Lady and Gentlemen of the
11 Committee.

12 CHAIR SUNSERI: That's error one.

13 (Laughter.)

14 MR. WUNDER: Good morning, Mr. Chairman,
15 Lady and Gentlemen of the Committee, Chris. I'm
16 George Wunder and I'm the Project Manager for the
17 staff review of the US-APWR design certification
18 application. Thank you for having us here today.

19 It's been a while since there was a
20 Subcommittee meeting on this design center, so I'm
21 going to give you a very brief history of the project,
22 so you understand where we are and where we plan to
23 go.

24 The US-APWR design certification
25 application was submitted at the end of December in

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 2007 and it was docketed in February of the following
2 year.

3 The review progressed and SER chapter were
4 prepared. Between the summer of 2011 and the spring
5 of 2013, we held Phase 3 meetings on 14 of the 19
6 chapters.

7 On November 5, 2013, the Applicant
8 informed us that because significant resources would
9 be needed to support recovery from the events at
10 Fukushima, they were required to reduce support for
11 the design certification review. The Applicant made
12 clear their commitment to the completion of the
13 project. Since that time, the review has proceeded at
14 a slower pace.

15 In early 2018, the Applicant identified
16 some areas in which progress could be made. These
17 were the advanced accumulator, for which they had
18 recently revised the topical report, and several
19 chapters with RAIs that were either already resolved
20 or easily resolvable. And these were Chapters 5, 7,
21 8, 10, and 18.

22 The advanced accumulator safety evaluation
23 with confirmatory items was issued in June of 2018.
24 The final SER with no confirmatory items was issued in
25 June of 2019. Chapters 8 and 18 were issued in July

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and August of 2019 and Chapters 5, 7, and 10 are under
2 staff review and we hope to bring them to the
3 Subcommittee in 2020.

4 And that's pretty much where we are. If
5 you have any questions, it's fine, and if not, we can
6 turn it over to someone more interesting and I will
7 pick up my name tag and go home.

8 CHAIR SUNSERI: All right. Thank you,
9 George. So, at this point, I'll turn to the Applicant
10 and Kumaki-san, if you're ready?

11 MR. KUMAKI: Good morning, everyone. Can
12 you hear me? I'd like to start my presentation of US-
13 APWR design overview. My name is Atsushi Kumaki from
14 MHI NS Engineering. This is a subsidiary company of
15 Mitsubishi Heavy Industries. And so, MHI is Applicant
16 of US-APWR design certification application.

17 And this is Mr. Joseph Tapia. He's a
18 principal consulting engineer in Mitsubishi Nuclear
19 Energy System. So, he will support my presentation,
20 if I couldn't understand, he will support. Thank you.

21 So, this is the contents of the
22 presentation today, starting from introduction over
23 US-APWR licensing activities and also, objectives of
24 today's presentation. Then, the overview of US-APWR
25 design feature will be explained.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, MHI submitted the application for US-
2 APWR design certification in December 2007. NRC
3 performed it's safety review from that time and
4 several ACRS meetings have already been held. And so,
5 now, we are still continuing the review phase on US-
6 APWR DC.

7 So, today is very comfortable for us to
8 discuss about the Chapter 18 and 8 and advanced
9 accumulator. So, before that, I will introduce an
10 interview of US-APWR design.

11 So, today's meeting objective is to
12 provide the current ACRS with US-APWR design overview.
13 So, several member has already changed, but I saw same
14 people, I'm familiar with, so thank you very much for
15 attending.

16 And also, this morning, I will present the
17 design overview. And this afternoon, other experts
18 for the Chapter 18, human factor engineering, and the
19 Chapter 8, electrical system, and also, topical report
20 for advanced accumulator, will be introduced this
21 afternoon.

22 This is a kind of conceptual sketch of US-
23 APWR. It looks like very similar to normal PWR, but
24 we have, if you can see this, inside the containment,
25 the bottom, we have refueling water storage pit,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 inside the containment. It's one of our features for
2 US-APWR.

3 And it hidden here, we have advanced
4 accumulator, sorry to put figure, but we have advanced
5 accumulator inside the containment. And also, you can
6 see the Main Control Room, which is applied for the
7 digital I&C system. So, those are features on US-
8 APWR.

9 The first part is a main feature of US-
10 APWR. This table show the progression of Mitsubishi
11 PWR design. So, for each number of loops, two loops,
12 three loops, four loops, in pressurized water reactor.

13 So, you can see the output of power, and
14 the inner diameter of reactor vessel, a number of fuel
15 assemblies, some points of steam generator and reactor
16 coolant pump. And this is the later reference plant
17 in Japan, for those loops.

18 And at the bottom, we have APWR, it's a
19 four-loop. And this is the base of our US-APWR. So,
20 basic design concept of US-APWR is the same as our
21 Japanese APWR.

22 The new technologies of APWR are fully
23 tested and well-verified and established. So, those
24 new technologies were incorporated in also US-APWR.
25 Then, US-APWR generates 1700 megawatt class and it is

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 based on the established APWR technology.

2 And those, we have some enhancement point,
3 so we take the latest technology to improve plant
4 efficiency and also, we take minor modification to
5 meet U.S. regulatory and RTT requirement.

6 For example, for U.S. regulatory, we
7 assessed aircraft impact assessment and also, security
8 assessment. And it is very good experience for us and
9 we know the U.S. regulation. And also, we consider
10 about the RTT requirements -- yes?

11 MEMBER BROWN: When you said security, was
12 that physical security?

13 MR. KUMAKI: Yes.

14 MEMBER BROWN: Okay. It wasn't cyber, it
15 was physical security?

16 MR. KUMAKI: Not cyber, no.

17 MEMBER BROWN: Okay. I just wanted to
18 make sure we understood the differentiation there.
19 Thank you.

20 MR. KUMAKI: And also, as for utility
21 requirements, we consider about the online maintenance
22 for safety system. So, we provided for that kind of
23 thing.

24 This table show the comparison of major
25 parameters among conventional four-loop APWR and the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 US-APWR. APWR generates 1538 megawatt output by large
2 capacity core and large capacity main components, such
3 as steam generator, reactor coolant pump, and the
4 turbine, and so on.

5 Then, US-APWR generates 1700 megawatt
6 output, with ten percent higher efficiency than APWR.
7 And US-APWR provides the same thermal output, 4451
8 megawatt, but its steam generator, US-APWR steam
9 generator has high performance and the large capacity,
10 comparing with APWR. And its turbine also high
11 performance, applying 74 inches across low-pressure
12 turbine blade.

13 MEMBER REMPE: But just to remind me, it's
14 been a while since we discussed this, I know when we
15 discussed the steam generator years ago, the question
16 was raised, is it as big as what was deployed or was
17 attempted to be deployed at SONGS? And the answer, as
18 I recall, was no.

19 The one in the US-APWR is smaller than
20 what was used at SONGS, the replacement, and it was
21 within your experience base, that you had used it
22 elsewhere. Is that not a correct recollection?

23 MR. KUMAKI: And after that, so we
24 examined the SONGS program and those we understand the
25 reason why the problem was occurred. So, on that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 experience, we verified our US-APWR steam generator
2 and made the design review, kind of design review.

3 MEMBER REMPE: Okay.

4 MR. KUMAKI: And so, if we manufacture
5 next year we may consider, but --

6 MEMBER REMPE: Okay.

7 MR. KUMAKI: Okay. So, as for the size of
8 steam generator, it's smaller than SONGS.

9 MEMBER REMPE: That's what I recall and
10 that it had actually been deployed somewhere else in
11 Japan too, already?

12 MR. KUMAKI: It's not in operation phase.

13 MEMBER REMPE: It is not in operation?
14 Okay, I'd forgotten some details. Thank you.

15 MR. KUMAKI: Okay. This is a comparison
16 of parameters for reactor core and internals. The
17 middle of APWR has a large capacity core, the number
18 of fuel assemblies was increased from 193 conventional
19 plan to 257 assemblies. And the neutron reflector was
20 installed for enhancement of reliability on reactor
21 vessel, especially for radiation, and also fuel
22 economy.

23 Then, US-APWR has a low power density
24 core, using 14-foot fuel assemblies to enhance fuel
25 economy for 24 months long-term operation. And

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 applying the same core thermal output with APWR, US-
2 APWR could use the same design of related system, such
3 as ECCS or RHRS.

4 And the reactor vessel of US-APWR applies
5 top-mounted in-core implementation system, ICIS, to
6 enhance the reliability and the maintainability for
7 the vessel penetration on the bottom. And also,
8 comparing the conventional plant and the Japanese
9 APWR, we enhanced the checkpoint on US-APWR.

10 CHAIR SUNSERI: Let me interrupt for just
11 a sec. Just for the record, Vesna Dimitrijevic has
12 joined the Committee. Thank you, or good to see you,
13 Vesna. Please continue.

14 MR. KUMAKI: Okay. Next is the safety
15 system and I&C system. Comparison with conventional
16 four-loop plant, APWR enhanced safety by simplified
17 and reliable safety system.

18 Mechanical four-train system, with direct
19 vessel injection. And also, elimination of low head
20 safety injection pump by utilizing advanced
21 accumulators and elimination of recirculation
22 switching by in-containment refueling water storage
23 pit. So, those are the enhancement points on APWR.

24 And furthermore, US-APWR enhanced safety
25 by four-train electrical system. And also, online

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 maintenance capability, if we consider the single
2 failure phase. So, that means we provided a 50
3 percent times four trains. That means one train may
4 be failed from a single failure and one train may be
5 on the online maintenance. So, that's why other two
6 trains means 100 percent for safety capability of
7 that.

8 So, at the first summary on this
9 presentation. So, these are the main feature of US-
10 APWR. Enhanced economy was achieved by large capacity
11 and high plant performance and also, high fuel
12 performance for 24 months operation.

13 Enhanced safety is achieved by improved
14 safety response by using advanced technology, such as
15 advanced accumulator or four trains. And enhanced
16 reliability was achieved by well-designed and verified
17 proven technologies.

18 So, from this slide, I will introduce the
19 US-APWR design features in a little more detail, not
20 so detail, but a little more. This is advanced
21 technology applying in US-APWR.

22 So, reactor has 1700 megawatt across large
23 capacity and also, neutron reflector. Engineered
24 safety features has simplified configuration with four
25 mechanical subsystems and also, four electrical

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 subsystems.

2 In-containment refueling water storage
3 pit, which eliminates switching of the long-term core
4 cooling. And we also applied advanced accumulator.
5 And as for steam generator, it has a high performance
6 separator and increased capacity, with compact sizing,
7 applying the triangular arrangement of tubes.

8 For I&C, we applied the full digital
9 controls and protection systems and using compact
10 console, such as these pictures. More big picture
11 will be raised later.

12 And also, our turbine has 74-inch length
13 blade in low pressure turbine and fully integrated
14 turbine rotor.

15 MEMBER BALLINGER: When you say fully
16 integrated, does that mean mono-block?

17 MR. KUMAKI: Yes, mono-block.

18 MEMBER BALLINGER: Mono-block, not built
19 up?

20 MR. KUMAKI: Yes.

21 MEMBER BALLINGER: Okay.

22 MR. KUMAKI: So, a little detail for
23 nuclear design features. So, as I explained, we have
24 a large thermal output and low power density.

25 So, for conventional plant, 193 fuel rod

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 assemblies and the 12-foot. So, you can see, the
2 bottom power density varies. So, on APWR, the power
3 density was lower than conventional, and also, US-APWR
4 more lower than APWR to perform the long-term core
5 cooling and flexibility of core.

6 So, this is neutron reflector features.
7 So, stainless steel radial neutron reflector was
8 designed to improve neutron neutralization, which
9 reduce the fuel cost and significantly reduce reactor
10 vessel irradiation compared to the conventional plant,
11 which has baffle plate design.

12 So, this figure shows the critical
13 experimental results performed in Japan. In case of
14 conventional baffle plate, the thickness almost 20
15 millimeters, that measured the reactivity gain on
16 virtual axis is quite low.

17 On the other hand, neutron reflector have
18 155 millimeter thickness, will produce high gain. So,
19 this differential gain corresponds to the saved
20 enrichment of 0.1 weight percent Uranium-235.

21 MEMBER KIRCHNER: May I ask a question?

22 MR. KUMAKI: Yes.

23 MEMBER KIRCHNER: So, when you did that,
24 how did that change your seismic design for the
25 reactor core and vessel? That's a substantial

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increase in mass inside the vessel.

2 MR. TAPIA: We don't have the number to
3 characterize the differences between the conventional
4 and the added mass, but we'd be happy to provide that
5 in a subsequent submittal.

6 MEMBER BALLINGER: Was that baffle plate
7 -- I mean, that reflector's about six inches thick,
8 that's of the same order as the pressure vessel
9 thickness.

10 MR. TAPIA: It's thick, yes.

11 MEMBER KIRCHNER: Maybe that's just
12 something for --

13 CHAIR SUNSERI: Yes, we can --

14 MEMBER KIRCHNER: -- in the future.

15 CHAIR SUNSERI: Right, we'll --

16 MEMBER KIRCHNER: Not for today.

17 CHAIR SUNSERI: -- make a note for a
18 future, that's probably Chapter 3 or 4 issue, 3 and 4,
19 yes.

20 MEMBER KIRCHNER: Thank you.

21 MR. KUMAKI: We will provide the answer
22 later. So, this slide shows the fuel design features.
23 So, as I explained previously, US-APWR applied the low
24 power density core, using the 14-foot fuels.

25 And that enables flexible core operation,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 using gadolinium pellet. So, gadolinium is to reduce
2 the peak linear heat rate, so it's helpful to design
3 the core under the constraint of enrichment and also
4 burnup.

5 And fuel economy was enhanced applying 97
6 percent theoretical density pellet and also zircaloy-4
7 grid for neutron economy.

8 Right part of this slide shows kind of
9 high reliability points grid fretting-resistant design
10 was fully -- by 11 grids and grid span design. The
11 grid span lengths is shorter than conventional 14-foot
12 fuel plants, which is kind, South Texas is a 14-foot
13 fuel plant.

14 And corrosion resistant cladding
15 materials, ZIRLO, and also, anti-debris bottom nozzle
16 with built-in filter were applied.

17 This is a comparison of main structure on
18 reactor internals, the particular point is upper-
19 mounted ICIS. So, for conventional, they have a
20 bottom-mounted, and we changed to upper-mounted ICIS
21 to enhance the reliability and the maintainability of
22 bottom penetration of reactor vessels.

23 And the neutron reflector was installed
24 for enhanced strength of reliability in the reactor
25 internal and fuel economy. And this is kind of repeat

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 again, but also, for neutron reflector, the bolt
2 numbers, on conventional baffle plate, they have 2,000
3 bolts. But on neutron reflector, we were reduced to
4 50. And also, the material is stainless steel 316,
5 so, it's very good for erosion.

6 This is very typical diagram on reactor
7 coolant system. So, we have four loops, four primary
8 coolant loops, each loop has steam generator and
9 reactor coolant pump, but those are the large size.
10 And as for pressurizer, we also increase the volume of
11 pressurizer to make a good response and
12 controllability on the transient of the plant.

13 This table shows a ratio of reliability on
14 US-APWR to conventional four-loop plant. So, as for
15 core thermal output, it's almost 25 percent larger
16 than conventional plant. And also, steam generator
17 heat transfer area is around two-thirds larger than
18 conventional plant, for higher efficiency.

19 And reactor coolant pump flow, 20 percent
20 larger than conventional, for larger output. And
21 also, pressurizer volume was increased around 60
22 percent, for the greater margin for transients in
23 plant.

24 This also kind of repeat slide, but for
25 reactor vessel, we enhanced the reliability on reactor

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 vessel, applying the material Alloy 690. And also, we
2 apply the vessel head plenum temperature is colder
3 than conventional plant, for the vessel integrity.

4 And reduction of weld lines, using
5 integrated forging for the manufacturing of reactor
6 vessel and neutron reflector, for the neutron fluence
7 reduced to 1,000.

8 As for CRDM, control rod drive mechanism,
9 housing, conventional plant have a canopy seal for
10 this small part. This is very weak for the stainless
11 corrosion crack and we considered the program and we
12 improved the point to eliminate the canopy seal on
13 this CRDM.

14 This is the steam generator. Steam
15 generator has high performance moisture separation, to
16 avoid turbine blade erosion. And also, we applied
17 anti-vibration bar, to avoid vibration rupture of
18 steam generator tubes.

19 CHAIR SUNSERI: So, just let me, Kumaki-
20 san, just a quick question here. Back to the steam
21 generator, is this similar in flow characteristics to
22 the APWR? Which is -- you have some in service,
23 right? Some of those are in service, right?

24 MR. KUMAKI: APWR is not in service now.
25 Oh, for the standpoint of flow, it is the same.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: Okay. Thank you.

2 MR. KUMAKI: Okay. For reactor coolant
3 pump, has a large capacity and high efficiency and
4 with improved impeller and diffusor.

5 And the particular point is advanced seal.
6 This seal provides stabilization of number one seal
7 leak-off characteristics and also, extension of seal
8 life and countermeasure to station blackout. When
9 station blackout occurs, the seal injection and the
10 cooling for thermal barrier will be stopped.

11 Then, the hot and high pressure reactor
12 coolant will come up, but we need to stop for the SBO
13 phase. We made a test to endure the eight hours for
14 the SBO phase.

15 For safety system, reliable and simplified
16 design is achieved by 50 percent configuration for
17 safety injection with direct vessel injection. And
18 also, we applied advanced accumulator, which will be
19 explained in the afternoon. And also, in-containment
20 refueling water storage pit improved the reliability
21 and safety by eliminating the circulation switching.

22 So, this is a comparison between
23 conventional four-loop and the US-APWR. A four-train
24 system for the US-APWR, but conventional has a two-
25 train only. And the advanced accumulator, which can

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 eliminate low head SI pump.

2 And the in-containment refueling water
3 storage pit have a higher reliability for long-term
4 core cooling. So, conventional plant need a switch
5 for the injection phase and the long-term core cooling
6 phase, but in this US-APWR, it will have an inside
7 containment RWSP, we don't need to switch the suction
8 line of injection pumps.

9 Comparison of number of each components.
10 So, US-APWR has four accumulator, each advanced type,
11 and 50 percent times four trains safety injection
12 system. And also, containment spray pump, the bottom
13 is a containment spray. It also has 50 percent times
14 four trains. And this system is used for residual
15 heat removal from the normal shutdown phase.

16 This also is high head injection system
17 design features of four independent train, without
18 interconnection between trains, because of the direct
19 vessel injection line we have. And the sufficient
20 capacity for safety injection pumps meets safety
21 injection requirement in core re-flooding stage.

22 And this is design for the common
23 containment spray system and the residual heat removal
24 systems, pumps, heat exchanger.

25 For normal operation, containment spray

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 function will be standby, and for plant shutdown, RHR
2 function will be operated by taking from hot leg line
3 and using pump and cooled by heat exchanger and
4 returned to cold leg.

5 So, accident phase, the refueling water
6 storage pit, this water will be taken by pumps and
7 cooled by cooler and spray from the top of
8 containment.

9 This is a figure of in-containment RWSP.
10 I think I almost explained already, so I direct to go
11 next.

12 This is the containment vessel. This is
13 very typical for conventional, we have pre-stressed
14 concrete containment vessel. I think I don't need any
15 explanation.

16 And the full layout, we applied a
17 simplified layout, placing for each corners of reactor
18 building, we placed safety systems for each corners.
19 It can be reduced about 20 percent building volume,
20 comparing with conventional plant.

21 This is an explanation for advanced
22 accumulator, but the detail will be provided in
23 afternoon, but I need to explain as necessary things.
24 So, this is injection pattern for after LOCA, large
25 break LOCA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, for current conventional plant, this
2 red line is requirement for injection flow. And
3 normal accumulator will work for this blue line, for
4 conventional plant. So, injection will start, but
5 stop soon.

6 After that, to cover the requirement of
7 this red line, we have a low head injection pump right
8 here, and high head injection pump, yellow area.
9 Those will cover the requirement of injection.

10 For US-APWR, the advanced accumulator will
11 make a two-pattern flow, this blue line. So, this
12 phase, on core re-flooding phase, accumulator will
13 work for small injection flow. It will cover the low
14 head injection part, so we can eliminate this low head
15 injection pump. And after the accumulator stopping,
16 the safety injection pump, high head injection pump,
17 only work for that.

18 This is a mechanism of advanced
19 accumulator for switching. In the initial, the water
20 level is higher than the top of this standpipe. So,
21 the flow will made by main standpipe line and also,
22 side inlet line will make a large flow and the inject
23 to RCS.

24 When the water level come down below the
25 top of this standpipe, the inlet flow will come only

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 side and the inject as a small flow to reactor coolant
2 system.

3 So, from now on, several familiar system,
4 such as emergency feedwater system and also component
5 cooling water system, I will explain. But the point
6 is, all those have four trains system, 50 percent time
7 four-train systems.

8 As for the emergency feedwater system, we
9 apply the diversity consideration applying the
10 turbine-driven pump and also, motor-driven pump to
11 each. So, this system make high reliability with
12 simplified system and also, it allow online
13 maintenance, it weakens the single failure, but we
14 have two 100 percent trains.

15 I think this is kind of repeat again, so
16 diverse point of power source. And four train system
17 and also two independent feeds. I think it's enough
18 for us.

19 So, for component cooling water system and
20 also, essential service water system, we apply the
21 four-train system. For component cooling water, we
22 have four sets of pump and heat exchange and also, we
23 have two sets of surge tank. Those are available for
24 the online maintenance. And also, essential service
25 water system, the same independent four-train

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 configuration.

2 The mechanical part is over and from now,
3 I&C main features, I will explain. So, US-APWR
4 instrumentation and control system is fully digital
5 I&C system, including computerized main control board,
6 minimum conventional switches, only for regulatory
7 compliance, with is Reg Guide 1.26, the title is
8 Manual Initiation of Protective Actions.

9 And also, we have microprocessor-based
10 safety and non-safety systems, multiplex
11 communications, including Class 1E signals. It's
12 based on defense-in-depths and diversity concept, with
13 four-train redundant safety system. And non-safety
14 system also have a redundant configuration.

15 Considering the common-cause failure.
16 Diverse backup non-safety system is provided as a
17 maximum standard deviation.

18 This is a very complicated figure and very
19 detailed. It's in the DCD, but I don't want to
20 explain everything. But please look at this kind of
21 thing, only.

22 So, as for safety I&C design features,
23 protection and safety monitoring system is safety
24 features, including reactor trip and the engineered
25 safety features actuation function. And also,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 monitoring of the safety-critical parameters,
2 according to Reg Guide 1.97, which is Criteria for
3 Accident Monitoring Instrumentation.

4 We applied the four-train redundancy for
5 all safety systems and the electrical, physical,
6 functional communication and data isolation to
7 accommodate the signal interface between safety
8 systems, signal interface safety to non-safety system,
9 and also, non-safety human system interface for safety
10 functions with safety HSI.

11 Branch Technical Position 7-14, which is
12 Guidance on Software Reviews for Digital Computer-
13 Based Instrumentation and Control Systems, and 7-19,
14 which is Guidance for Evaluation of Diversity and
15 Defense-in-Depth in Digital Computer-Based
16 Instrumentation and Control Systems, are taken into
17 account for software integrity.

18 Our platform for main control board is a
19 MELTAC by Mitsubishi Electric, which was qualified
20 with extensive experience in Japanese plants.

21 For non-safety I&C design features, plant
22 control and monitoring system is non-safety features,
23 including reactor turbine generator, plans of plant
24 control room monitoring, and redundant configuration,
25 functional isolation of shared sensor signals.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Diverse actuation system is a
2 countermeasure for common-cause failure in the digital
3 safety system, according to BTP 7-19 and also, 10 CFR
4 50.62, for anticipated transient with scram.

5 Diverse automation is provided for reactor
6 trip, turbine trip, EFWS, emergency feedwater system,
7 based on actuation, are required within ten minutes of
8 an event.

9 Diverse manual controls are provided for
10 safety injection, containment vessel isolation, and so
11 on, and are critical safety functions. Diverse
12 monitoring is considered for safety critical
13 parameters.

14 So, this picture shows prototype console
15 of a main control board, with large display panel,
16 operator console, applying visual display units. This
17 control board is well considered for human system
18 interface. And that human system interface item will
19 be discussed also in the afternoon, Chapter 18
20 session.

21 So, the function of HSI system are fully
22 computerized video-based approach, integrated display
23 for monitoring and soft control, and dynamic alarm
24 prioritization and computerized procedures.

25 The system was developed according to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 NUREG-0711 program model, including task analysis and
2 human factor design, step-by-step prototyping and
3 verification and validation by plant operators.

4 The design basis of staff are operators,
5 supervisor, and safety technical advisors.

6 The main features are all operations are
7 available from non-safety VDUs. All safety operations
8 are performed from safety VDUs. And the inventory of
9 fixed-position HSI is minimum for convention HSI, for
10 manual system lever action, regarding Reg Guide 1.26,
11 which is Manual Initiation of Protective Actions, and
12 critical functions on bypass or inoperable status
13 regarding the Reg Guide 1.47, Bypassed and Inoperable
14 Status Indication for Nuclear Power Plant Safety
15 Systems.

16 CHAIR SUNSERI: I know you'll probably get
17 into this more later, but at this point, could you
18 just remind us what the number of staffing is? How
19 many operators, how many supervisors?

20 MR. KUMAKI: The actual operator is two,
21 one. And the supervisor is one.

22 CHAIR SUNSERI: One operator, one
23 supervisor?

24 MR. KUMAKI: Just a moment.

25 CHAIR SUNSERI: And one technical advisor?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TAPIA: We have our expert right here.

2 MR. MASHIO: My name is Kenji Mashio, from
3 MHI. I can respond your question. And so, the
4 minimum staffing we have -- this HSI control board can
5 operate by minimum one RO, reactor operator, and one
6 SRO. But based on the regulation, we have two reactor
7 operator.

8 CHAIR SUNSERI: Okay. All right. Thank
9 you.

10 MR. KUMAKI: Okay. Let's go to the
11 electrical system design features. It's very
12 conventional and we have two independent offsite
13 transmission systems. But we have a four-train onsite
14 safety power system and four-train safety gas turbine
15 generator for emergency and four-train safety
16 batteries.

17 And as for the non-safety AC power, we
18 provide, this one is a typo, so we have two non-safety
19 GTG alternate AC power.

20 This is also a very typical one-line
21 diagram on electrical system. We have safety
22 electrical, four trains, and also, we have a non-
23 safety, we need to provide one more, we will have two.

24 So, this is summary of this morning
25 presentation for design overview of US-APWR. US-APWR

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 is designed on proven and reliable technologies and it
2 provides improved plant efficiency, incorporating
3 improved steam generator and turbine system.

4 It provides reduced fuel cycle costs and
5 improved operational flexibilities, by low power
6 density core, applying 14-foot fuel assemblies. And
7 also, it provides minor modification of APWR for U.S.
8 and RTT requirements, such as online power maintenance
9 and so on.

10 And also, we don't need to forget about
11 safety point, we enhanced the safety, applying the
12 four-train systems, and also advanced accumulator and
13 so on.

14 Okay. This is end of my presentation.
15 Thank you for your kind attention.

16 CHAIR SUNSERI: Thank you very much. And
17 I think the few questions that you received is an
18 indication of our depth of knowledge on the PWR and we
19 appreciate you going through this in a deliberate
20 manner. Yes, go ahead, Walt.

21 MEMBER KIRCHNER: Just a quick question.
22 So, you're using gas turbine generators both for the
23 for-safety units, as well as the non-safety. So, is
24 the plan to have significant gas storage on-hand or
25 use propane or?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. TAPIA: It's actually diesel. It's
2 atomized diesel.

3 MEMBER KIRCHNER: So, you're using diesel
4 --

5 MR. TAPIA: Yes.

6 MEMBER KIRCHNER: -- as the fuel?

7 MR. TAPIA: Yes.

8 MEMBER KIRCHNER: Okay, thank you.

9 MEMBER BROWN: Matt?

10 CHAIR SUNSERI: Yes, Charlie?

11 MEMBER BROWN: I did restrain myself a
12 little bit on the I&C. When we reviewed this back in
13 2009 and 2010, the Chapter 7 stuff, we made some
14 considerable enhancements, thought processes, over the
15 last eight years, nine years, which I will save until
16 we do the subsequent one. Just let you know.

17 CHAIR SUNSERI: I was curious about that,
18 but I thought you were --

19 MEMBER BROWN: Well, I --

20 CHAIR SUNSERI: -- paying attention to the
21 --

22 MEMBER BROWN: No, I was paying --

23 CHAIR SUNSERI: -- other comments and not
24 saying --

25 MEMBER BROWN: -- very much attention.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: -- saving it to the --

2 MEMBER BROWN: Well, it's just not
3 appropriate now.

4 CHAIR SUNSERI: Right.

5 MEMBER BROWN: It's not the right form to
6 try to address those comments.

7 CHAIR SUNSERI: Right.

8 MEMBER BROWN: So, we'll wait until that.
9 I'm just trying to give the staff a heads-up to know
10 that we will have some additional questions, when it
11 comes to that.

12 And also, MHI might just remember that
13 Member Brown restrained himself and will have some
14 questions, politely restrained himself, will have some
15 questions when we get around to Chapter 7 again.
16 Okay. Thank you very much.

17 CHAIR SUNSERI: Very good. All right.
18 So, very good. You allotted the right amount of time
19 for our questions and we didn't have very many, so
20 that puts us ahead of schedule, so thank you for that.
21 I think we should now go ahead and move forward with
22 this into the next agenda item.

23 And that would be the Chapter 8,
24 Electrical Power. And it looks like that we have this
25 set up to where we're going to have the Applicant go

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 over all of your material for both Chapter 8 and 18.
2 And then, we'll turn it over to the staff and then,
3 they will provide their response. So, Dennis, you got
4 a question?

5 MEMBER BLEY: I was just remembering, we
6 had some concerns about the operating data for this
7 kind of gas turbine. We didn't think there had been
8 a lot, so I hope you're going to address that.

9 CHAIR SUNSERI: Right. That was one of
10 our follow-up items. Okay. So, let's go ahead and
11 transition then into the next group. And thank you
12 for that, Kumaki-san. And which are going to be the
13 lead for this? Tanaka-san? Okay. So, you got
14 schooled on the microphone? Okay.

15 So, just before we get started, I want to
16 just say that we are ahead of schedule, but somewhere
17 after 10:00-ish, if there's a good point in your
18 presentation, we'll stop and we'll take a break, okay?
19 So, if you are ready, we are ready.

20 MEMBER BROWN: Could you reemphasize on
21 this chapter, I took a, I mean, I looked at the SER
22 and part of the DCD, but could they emphasize,
23 hopefully, if there's any changes from the design as
24 it was presented back in 2010 and 2011? Is that going
25 to be covered and identify differences or what's

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 happened subsequent to nine years ago?

2

3 MR. TANAKA: In this presentation, I
4 explain the best point, based on the NRC comments or
5 ACRS comments.

6 MEMBER BROWN: So, you will cover
7 fundamentally emphasized differences from eight or
8 nine years ago? From the DCD to now, if there were
9 any major changes?

10 MR. KAWANGO: Yes, and my name is Shinji
11 Kawanago. And basically, we didn't change any basic
12 design of our electrical system. Only --

13 MEMBER BROWN: That's what it looked like,
14 when I looked at the basic overall diagrams, they
15 looked the same.

16 MR. KAWANGO: The same. The same. The
17 only --

18 MEMBER BROWN: The big picture overview
19 diagram, not --

20 MR. KAWANGO: No, only the changes are
21 minor change, because of the RAI by NRC, for example,
22 the open phase issue and so on.

23 MEMBER BROWN: Thank you. That's all
24 that?

25 MR. KAWANGO: Yes.

1 MEMBER BROWN: Okay, that's what I
2 thought. Thank you.

3 MR. TANAKA: Okay?

4 CHAIR SUNSERI: Okay. You may go ahead.

5 MR. TANAKA: Can I start? Okay. Good
6 morning. My name is Hideki Tanaka, electrical
7 engineer of MHI. I will explain the Chapter 8 on the
8 US-APWR. First, I'll explain the presenters, Joe
9 Tapia and Shinji Kawanago, with MHI NS Engineering,
10 and myself, Hideki Tanaka, of the MHI. Okay.

11 This page shows the contents of this
12 presentation. Especially in this presentation, I will
13 explain the features of the electrical system in the
14 US-APWR and closed open items identified in SER, Phase
15 3 SER and RAIs issued after the Phase 3 SER. Okay.

16 Overview of the chapter. Chapter 8 is
17 electric power. And in this chapter, we have the
18 subsections 8.1 through 8.4.

19 The next page, this page shows related
20 document. Opposite table shows status of the DCD. We
21 issued DCD before and this is latest DCD. And number
22 two is a tracking report of the DCD. So, we -- this
23 report shows revised point from the Revision 4 DCD
24 based on the RAI responses.

25 And this table shows technical report.

1 MEMBER BROWN: Can I make sure I
2 understand? The tracking report would then cover the
3 open phase circuit stuff, as opposed to the August 30,
4 2013 version? That's what I got from your comment
5 there.

6 MR. TANAKA: This tracking report does not
7 include the open phase.

8 MEMBER BROWN: It doesn't or it does?

9 MR. TANAKA: Does not.

10 CHAIR SUNSERI: They're going to do
11 something similar to other applicants and defer the
12 open circuit stuff to the COL applicant, I believe.

13 MEMBER BROWN: Well, they made some
14 comments in the SER identified that there were some
15 changes made, but then, there were the COL items for
16 some points of it. Some of the stuff looked like it
17 was okay, that they had proposed, and there seemed to
18 be a couple of items that were deferred to the COL.

19 So, I was just wondering where -- when
20 they went through the RAI response process, did
21 anything get reflected back into the DCD or was, I
22 guess we can ask the staff that also, or was something
23 actually incorporated into the DCD, one of the
24 versions of the DCD?

25 MR. KAWANGO: And actually, when we got

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 RAI and also, we had RAI response, in the RAI
2 response, we clearly indicate how to change the DCD
3 itself and also the ITAAC and also the --

4 MEMBER BROWN: Right.

5 (Simultaneous speaking.)

6 MR. KAWANGO: -- and so on.

7 MEMBER BROWN: I remember some of that.

8 I also remember something being deferred, a later RAI,
9 something moving towards the COL.

10 MR. KAWANGO: Yes.

11 MEMBER BROWN: All right. I'll just cover
12 that later.

13 MR. KAWANGO: Yes. And --

14 MEMBER BROWN: That's fine.

15 MR. KAWANGO: And also, the -- and in our
16 presentation, we will explain later, including on what
17 is a COL item and so on.

18 MEMBER BROWN: Okay, thank you. You can
19 go on.

20 MR. TANAKA: So, this table, number three
21 is onsite AC power system calculation. This report
22 shows this and other calculations and so on.

23 And number four and number five is
24 relating to the gas turbine generator. Gas turbine
25 generator is high reliability and compact and no

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 cooling water required. So, we use gas turbine
2 generator as emergency power source, instead of the
3 diesel generator usually used.

4 MEMBER BROWN: Did you say no water is
5 required?

6 MR. TANAKA: Yes.

7 MEMBER BROWN: That's what I -- okay.

8 MR. TANAKA: Yes, air cooling.

9 MEMBER BROWN: Another memory jogger here,
10 okay.

11 MEMBER BLEY: Was that the main reason you
12 chose the gas turbine or were there others?

13 MR. TANAKA: One of the reason.

14 MEMBER BLEY: Can you --

15 MR. TANAKA: One of the main reason.

16 MEMBER BLEY: Can you go through the other
17 reasons?

18 MR. TANAKA: Yes. Gas turbine generator
19 is compact, layout space is smaller than the diesel
20 generator. And reliability is, we believe reliability
21 is higher than diesel generator.

22 MEMBER BLEY: Okay, thank you.

23 MEMBER BALLINGER: Yes, Mitsubishi is one
24 of the world's leading --

25 MEMBER BLEY: I know.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BALLINGER: -- suppliers of gas
2 turbines.

3 MR. TANAKA: Okay. So, gas turbine
4 generator is a first of a kind, so we performed the
5 qualification testing. So, number four and number
6 five is the qualification program and the test result.
7 Okay.

8 Next is a feature of the electric power
9 system. This page shows features on the offsite power
10 system. I would like to explain this using this
11 single-line diagram.

12 We have two offsite source. One is from
13 the RAT, this is normal preferred power source. And
14 the other, from the main transformer and -- the
15 transformer. This is alternate preferred source. And
16 these are physically separated. Okay.

17 Next page, this page shows RAI issued from
18 the -- Page 2, I will explain later. The next page --

19 CHAIR SUNSERI: If I could ask you to be
20 careful with the microphone and done shuffle the paper
21 over the speaker. It makes noise.

22 MR. TANAKA: Oh, sorry. This page shows
23 details on the onsite power system, so you don't have
24 to use this single-line diagram for this explanation.
25 Okay.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In this figure, blue line shows Class 1E
2 system and red line shows the non-Class 1E system. We
3 have a four-train safety Class 1E system. And each
4 train has emergency power source, gas turbine
5 generator.

6 And we have a four times 50 percent
7 capacity. So, we can assume the online maintenance
8 and the single failure and even those considering, we
9 still have 100 percent of capability for the safety
10 function.

11 Also, we have two buses backed up by
12 generator. We call that permanent buses, this P1 and
13 P2. These buses can be backed up by alternative AC
14 power source.

15 Usual existing plant has investment
16 protection load, such as HVAC or pump or something
17 like that. That connected to the Class 1E bus.

18 But in US-APWR, those non-safety load is
19 connected to this permanent buses. So, in our US-APWR
20 Class 1E system and non-Class 1E system is completely
21 separate. And in SBO condition, the HVAC can be
22 connected to the Class 1E buses to cope with the SBO.
23 Okay.

24 From this page, gas turbine generator is
25 explained. And this page shows the specification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And unique point is the starting time. Diesel
2 generator starting time is usually ten or 15 second,
3 but the upright advanced accumulator, so the starting
4 time, requirement for the starting time is less than
5 100 second, so that we can use the gas turbine
6 generator.

7 MEMBER BLEY: On the previous slide, you
8 said you have four times 50 percent capacity. Give me
9 more details on what you mean by that. Is that on the
10 gas turbines? What do you have four times 50 percent
11 capacity on?

12 MR. KAWANGO: The meaning of the 50
13 percent is, as you know, on our --

14 MEMBER BLEY: We're talking gas turbine,
15 right?

16 MR. KAWANGO: Yes.

17 MEMBER BLEY: Okay.

18 MR. KAWANGO: No.

19 MEMBER BLEY: No?

20 MR. KAWANGO: No, no.

21 MEMBER BLEY: What are you talking about?

22 MR. KAWANGO: Basically, capacity, meaning
23 the capacity, definition of the capacity always
24 defined by what is safety load, okay? And safety
25 injection pump and CV spray pump and so on. Our

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 mechanical system is a 50 percent times four. Okay?
2 Fifty time four, our mechanical system.

3 MEMBER BLEY: Each train is 50 percent
4 times four?

5 MEMBER BROWN: You're talking about the
6 equipment that's powered?

7 MR. KAWANGO: Yes. And equipment which
8 needs power is --

9 MEMBER BLEY: So, you need, you're
10 basically saying on the safety systems, you need any
11 two trains out of four trains for safety equipment?

12 MR. KAWANGO: Any two trains.

13 MEMBER BLEY: Any two?

14 MR. KAWANGO: Two, any two. And this,
15 again --

16 MEMBER BLEY: So, that reflects back then
17 to the gas turbines as well, for the emergency gas
18 turbines, you need at least two of them working --

19 MR. KAWANGO: Yes, that's right.

20 MEMBER BLEY: -- to meet your --

21 MR. KAWANGO: That's right.

22 MEMBER BLEY: -- demands?

23 MR. KAWANGO: Yes.

24 MEMBER BLEY: Okay.

25 MR. KAWANGO: That's right.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: Okay.

2 MR. KAWANGO: Yes.

3 MEMBER BLEY: Okay. That's -- it was a
4 little too general for me, that's why I asked.

5 MEMBER BROWN: Can you back up to that
6 Slide 13? You say a short-time rating of 4950 kW, two
7 questions. I want to get them clear. How long is
8 short-time? That's question one. Is that five
9 minutes? Is it 30 minutes? Is it -- how long can you
10 overload it at 4950? If you --

11 MR. KAWANGO: I suppose --

12 MEMBER BROWN: -- don't know it, that's
13 okay.

14 MR. KAWANGO: I suppose your question is
15 related to the overload and the capacity and based on
16 IEEE requirement?

17 MEMBER BROWN: I -- let me back up. All
18 you've listed here is the capability to run short-time
19 rating at 4950 kW, as opposed to its continuance
20 rating of 4500. And so, my question is, how long can
21 you run it at 4950? How much time?

22 CHAIR SUNSERI: Charlie, aren't those
23 numbers usually related to things like starting the
24 single largest loads?

25 MEMBER BROWN: No, no, no, that's a load.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 You put a -- in other words, if you have enough load
2 that you can load it up that way before you shed, or
3 something like that. So, it's not a startup type
4 issue, that's a transient, you're talking seconds.

5 CHAIR SUNSERI: No, but what I'm saying is
6 the thing is running at 4950 or whatever and you, or
7 somewhere close to, yes, running at 4500 and you start
8 some big load, right?, and then, it's --

9 MEMBER BROWN: No, that's a starting
10 issue, not a continuance running issue.

11 CHAIR SUNSERI: But that's a short-time.

12 MR. KAWANGO: May I answer?

13 CHAIR SUNSERI: Yes.

14 MR. KAWANGO: Sorry.

15 CHAIR SUNSERI: Yes, please.

16 MR. KAWANGO: Yes. And simple answer to
17 you is two hours during a 24 hours.

18 MEMBER BROWN: Okay, that's fine.

19 MR. KAWANGO: Yes. That is a requirement
20 from the IEEE.

21 MEMBER BROWN: That's fine. That's fine,
22 that answers -- that's the point, two hours is a long
23 time.

24 CHAIR SUNSERI: Right.

25 MEMBER BROWN: When you do a transient and

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 start a motor, you're talking seconds.

2 CHAIR SUNSERI: Right.

3 MEMBER BROWN: And it's largely not kW,
4 many times it's reactive power. If it's a current,
5 it's a current issue and you heat windings and that
6 drives your starting type issues. But this is a long
7 time type. The second question, I've now forgotten.

8 (Laughter.)

9 MEMBER BLEY: That's good, Charlie.

10 MEMBER BROWN: To be honest.

11 MEMBER BLEY: Because I have another
12 question --

13 MEMBER BROWN: I'll remember it later.

14 MEMBER BLEY: -- then, on the four 50
15 percent capacity trains. If I have a safety injection
16 pump out for maintenance in one train and I have some
17 other big load out for maintenance in another train,
18 it's possible -- what's not possible?

19 MR. TAPIA: You can't take --

20 MEMBER BLEY: Tech specs don't stop
21 something from breaking.

22 MR. TAPIA: Oh, but you said maintenance
23 for both of them.

24 MEMBER BLEY: Okay. I'm sorry.

25 MR. TAPIA: And that's --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BLEY: I'm sorry. You've got two
2 major loads out of service in two different trains.

3 MR. TAPIA: So, you're allowed to take one
4 train out for maintenance. And then --

5 MEMBER BLEY: I understand.

6 MR. TAPIA: And then, the design
7 assumption is that you lose another train due to
8 single failure.

9 MEMBER BLEY: Okay.

10 MR. TAPIA: So, that leaves you with two
11 50 percent capacity --

12 MEMBER BLEY: Okay.

13 MR. TAPIA: -- trains left, which is 100
14 percent. That's the design basis for the four trains.

15 MR. KAWANGO: And Joe answered you. And
16 basically, our definition is online maintenance, okay?
17 And we just observed when we have the online
18 maintenance, just we allow to have the online
19 maintenance for only one specific train, okay?

20 So, that when we have the online
21 maintenance for the safety injection pump on Train A,
22 we cannot do the online maintenance for the B Train or
23 C Train, okay?

24 MEMBER BLEY: I understand.

25 MR. KAWANGO: Just the one train, so that

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 --

2 MEMBER BLEY: But you could have a failure
3 somewhere?

4 MR. KAWANGO: Yes, sure. Sure.

5 MEMBER BLEY: In fact, you could have more
6 failures. When we get to the PRA, we'll dig into that
7 a little bit, but I wanted to make sure I understand
8 the definitions here.

9 MR. TANAKA: Okay. This page shows Class
10 1E gas turbine generator testing program. So, our
11 testing performed based on the Reg Guide 1.9 and IEEE
12 387, ISG-21. And we issued technical report for the
13 test program and the test result.

14 And this page shows contents of the
15 initial type testing. We performed the load
16 capability tests to demonstrate the capability to
17 carry the load.

18 And we performed the start and load
19 acceptance tests to establish the capability to start
20 and accept load within the required time period. So,
21 in this test, we performed 150 start tests. This will
22 be discussed later.

23 And we also performed the margin tests to
24 demonstrate the capability to carry the most severe
25 load plus ten percent margin.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And in the Section 8.3, we had three open
2 items and one new RAI. This will be discussed later.

3 The next is Section 8.4, station blackout.
4 In the station blackout, we don't have -- I mean
5 offsite power, all offsite power and EPS are not
6 available, and we use alternate AC power source to
7 cope with SBO.

8 Design basis, we have diverse alternate AC
9 power source from the EPS system to minimize a
10 potential common-cause failure. And we use gas
11 turbine generator for the alternate AC power source.
12 And alternate AC power source can be connect to any of
13 the Class 1E buses. And coping duration for the SBO
14 is eight hours, in accordance with Reg Guide 1.155.

15 And in Section 8.4, we have two open items
16 and one new RAIs. So, in this section three, I will
17 explain the closed open item and the RAIs. First item
18 is regarding the open phase, the Section 8.2. We
19 received three RAI and our response is described in
20 the next page.

21 So, the detection and protection method.
22 We provide OPC detection system on the high voltage
23 side of the main transformer and reserve auxiliary
24 transformer. So, the both preferred power source will
25 have OPC protection device.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And second item, the single failure
2 criteria. This figure shows logic of the automatic
3 protection system for the open phase detection system.
4 Left side is for the main transformer and the right
5 side is for the reserve auxiliary transformer.

6 And each system has a System 1 and System
7 2. This means redundant system. And in the accident
8 condition, this SI signal initiated, we only use one
9 protection signal, we can protect. So, we consider
10 the single failure in this protection system.

11 And this page shows the COL item and the
12 ITAAC. We have two COL item. One is determined
13 specific type of OPC detection system device. And
14 determine the setting of the device. And the second
15 item, COL item, is determine the -- served as the
16 requirement of the device. Also, we -- this table
17 shows ITAAC for the operator's protection system.
18 Okay.

19 Next page --

20 CHAIR SUNSERI: Let me stop you there.
21 So, Charlie, does that address your --

22 MEMBER BROWN: No, it covered, I read the
23 SER response and I didn't have this detail. So, that
24 was -- or at least I couldn't find it at home.

25 CHAIR SUNSERI: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: I -- it's been accepted, at
2 least in the SER it sounded, their explanation sounded
3 reasonable.

4 CHAIR SUNSERI: Okay.

5 MEMBER BROWN: I didn't see this
6 particular detail, it just said it was going to be a
7 COL item, there it is.

8 CHAIR SUNSERI: Yes. Okay. All right.
9 Thank you.

10 MEMBER BROWN: Excuse me, I didn't have my
11 phone on, did you hear me okay? Okay.

12 CHAIR SUNSERI: All right. Continue.

13 MEMBER BROWN: Thanks, Matt.

14 MR. TANAKA: Next, this page shows open
15 item regarding the degradation of the medium voltage
16 cabling on the -- around the board. So, originally we
17 didn't provide a COL item, but we revised the DCD to
18 include the COL item, to describe the cable monitoring
19 program. So, that this has been closed.

20 Next one is regarding the gas turbine
21 generator reliability. Originally we didn't provide
22 target of the reliability. So, in the diesel
23 generator, IEEE 387 has a number of starting test as
24 100 times starting test.

25 And for the gas turbine generator, we set

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the reliability target 0.975 with 95 percent
2 confidence. This come from the Reg Guide 1.155. And
3 we calculated that this starting number was a starting
4 time based on this reliability target, we decided 150
5 start is required. And we have performed this number
6 of starts.

7 MEMBER BLEY: You're not doing the PRA
8 today, but do you have any idea what the PRA used for
9 the diesel generator reliability? I bet it wasn't --

10 MR. TANAKA: Yes.

11 MEMBER BLEY: -- one minus 0.975.

12 MR. TANAKA: Yes. Actually, in the PRA,
13 we use reliability of the diesel generator for the
14 conservatism. I mean, reliability of the gas turbine
15 generator is higher, so in the PRA modeling, we used
16 higher --

17 MEMBER BROWN: Lower?

18 MR. TANAKA: -- lower, lower --

19 MEMBER BROWN: Lower reliability?

20 MR. TANAKA: Lower reliability, yes.

21 MEMBER BLEY: You didn't use something
22 lower than this? So, I think I heard what you said
23 and you said, we know that our gas turbine generators
24 are more reliable than the diesels, so we'll use the
25 diesel generator failure rate, which might be at ten

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 to the minus three. But this testing hasn't given us
2 any confidence that these are more reliable than a
3 failure rate of ten to the minus three.

4 MR. KAWANGO: We will check the number
5 with our technical report and in our technical report,
6 we calculated the actual reliability data for the gas
7 turbine generator, by using the industrial actual
8 starting and test data, and also the actual some
9 experience.

10 MEMBER BLEY: This is the 07024 report?
11 07024-P?

12 MR. KAWANGO: Yes.

13 MEMBER BLEY: Okay. I'll study that a
14 little bit more carefully then.

15 MR. KAWANGO: And, hold on, may I explain
16 a little bit?

17 MEMBER BLEY: You could explain a lot.

18 (Laughter.)

19 MR. KAWANGO: And actually we calculated
20 the reliability data by using actual data with gas
21 turbine generator and calculation result is ten minus
22 five, or something like that. Very, very low --

23 MEMBER BLEY: These are from --

24 MR. KAWANGO: Actual data --

25 MEMBER BLEY: -- that are out in the field

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 being used?

2 MR. KAWANGO: Yes, that's right.

3 MEMBER BLEY: Okay.

4 MR. KAWANGO: So, we discussed --

5 MEMBER BLEY: I'll read that report more
6 carefully; I haven't had a chance to study that yet.

7 MR. KAWANGO: Okay.

8 MEMBER BLEY: Thank you.

9 MR. KAWANGO: Sorry, ten minus four.

10 (Laughter.)

11 MEMBER DIMITRIJEVIC: Well, then, what was
12 the reason that you decide to use the diesel
13 generator, which are less reliable data, if you have
14 the industry data for gas turbine?

15 MR. KAWANGO: Because, yes, because we
16 discussed with NRC and, of course, maybe good way to
17 use gas turbine generator data, but we thought, we
18 conclude, that conservative data is better for use.

19 MEMBER DIMITRIJEVIC: So, did you use also
20 diesel generator common-cause data or common-cause
21 failure of the --

22 MR. KAWANGO: Yes, data factor is the
23 same.

24 MEMBER DIMITRIJEVIC: So, do you have a
25 common-cause group of six gas turbine?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. KAWANGO: Oh, no, no, actually is
2 four.

3 MEMBER DIMITRIJEVIC: And what about your
4 backups?

5 MR. KAWANGO: Backup is a completely
6 different manufacture and design.

7 MEMBER DIMITRIJEVIC: So, it's separate?

8 MR. KAWANGO: Separate, yes, that's right.

9 MR. TANAKA: Okay. Next RAI is also
10 regarding the gas turbine generator. In our
11 qualification testing, in the starting testing, we
12 performed the maintenance of the injectors every 50
13 starts.

14 But we did not provide such information in
15 the technical report and the technical specifications.
16 So, we revised the DCD to incorporate technical
17 specification service requirement for this nozzle
18 cleaning maintenance.

19 And the next one is for the battery sizing
20 calculation. We originally used the Japanese
21 experience for the battery load profile. And we
22 revised those information based on the U.S.
23 manufacturer's information in detail.

24 And the next one is for the SBO, RCP seal
25 leakage rate. In the DCD, we indicate, the RCP seal

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 leakage rate is 0.2 gpm. But in the U.S. industry
2 standard, NUMARC 87-00 shows 25 gpm. So, we were
3 requested to justify the difference.

4 And our response was that isolation
5 barrier stops the leakage from the number one seal and
6 only number two seal easily meets it, so this item
7 also has been closed.

8 Next one is the AAC reliability. We
9 needed to show the inspection and the testing
10 requirement for the AAC to demonstrate the
11 reliability. So, we revised the DCD to include
12 service test of the AAC and during every refueling
13 outage, we perform the loading test also.

14 And this page shows also the station
15 blackout. In the station blackout, HVAC equipment is
16 stopped, so turbine driven emergency feedwater pump
17 room temperature will be increased. So, we needed to
18 calculate the room temperature. And we provided
19 conservative assumption and it uses numerically stable
20 calculation method. So, the result, we showed
21 temperature is below the 175 Fahrenheit during the
22 coping period.

23 Okay. Summary --

24 MEMBER DIMITRIJEVIC: Sorry, I have a
25 question on ventilation. Does your gas turbine need,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 where they're located, they do need ventilation for
2 operation? And how about ventilation in your switch
3 gear room?

4 MR. TANAKA: In the gas turbine generator
5 room, we have ventilation.

6 MEMBER DIMITRIJEVIC: But is it required?
7 I mean, your ventilation is component cooling water
8 cooled?

9 MR. TANAKA: Oh, no, no.

10 MEMBER DIMITRIJEVIC: What is it? Is it
11 --

12 MR. TANAKA: Yes, no cooling water
13 required.

14 MEMBER DIMITRIJEVIC: No, no, you don't
15 need the cooling for gas turbine, I got that, it's a
16 huge advantage. Now, I wonder if you need
17 ventilation, maybe on the other second, you need
18 cooling for the room?

19 MEMBER BLEY: If the room heats up, air
20 cooling may not work so well.

21 MEMBER DIMITRIJEVIC: Yes.

22 MR. KAWANGO: And our answer, regarding
23 room of the gas turbine generator, we needed to have
24 the fan, cooling fan, only fan. We don't need to have
25 the actually the air conditioner and a --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER DIMITRIJEVIC: But did you do
2 calculation to prove?

3 MR. KAWANGO: Sure, sure, sure, we --

4 MEMBER DIMITRIJEVIC: How about for your
5 switch gear room, where your AC buses are?

6 MR. KAWANGO: We need --

7 MEMBER DIMITRIJEVIC: Or especially --

8 MR. KAWANGO: Yes, we need to have
9 ventilation cooling system, which needed to rely on
10 cooling water, yes.

11 MEMBER DIMITRIJEVIC: So, my question for
12 you is in the case of the blackout, station blackout,
13 do you need the cooling water? Can you survive --
14 because if you need ventilation where your buses are,
15 then you do need cooling water and then, you need the
16 service water.

17 MR. KAWANGO: I needed to answer be
18 careful, but based on the requirement of the 10 CFR
19 50.63, okay, 50.63 we will start this alternate AC
20 power source within one hour, okay? Within one hour.
21 So, during this one hour, just from the station
22 blackout starting and this one hour duration, okay?,
23 we evaluate the room temperature of the, of course,
24 the switch gear and also, the I&C control room and the
25 turbine room, feedwater pump room.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: He had questions about the
2 break process. Well, let me ask the other members if
3 you have any questions for the MHI folks? Nothing
4 else? Dennis? Vesna? Joy? I think, I know Charlie
5 had some questions about the I&C infrastructure. Is
6 that in a different chapter? That's 7? Oh, okay.
7 All right, then.

8 Well, I suppose we are done with this one
9 then. Thank you. And we will, at this point, while
10 we transition to the next group, which will be Chapter
11 18, we'll take a break. So, we'll come back at 10:30
12 and reconvene. So, we are recessed until 10:30.

13 (Whereupon, the above-entitled matter went
14 off the record at 10:14 a.m. and resumed at 10:31
15 a.m.)

16 CHAIR SUNSERI: Okay. We're going to
17 reconvene the meeting now. And this will be the start
18 of Chapter 18 presentation by the Applicant.

19 MR. MASHIO: Good morning, ladies and
20 gentlemen. I'm Kenji Mashio from MHI. I present
21 Chapter 18, Human Factors Engineering Program. And I
22 lead this presentation, but as a person sitting here,
23 Bob Hall and Joe Tapia, help your question me that you
24 may have.

25 I have three talking point in this

1 presentation. First is the structure of the
2 submittal. Second one is basically our basis for the
3 US-APWR HFE application. And also, I'm talking about
4 HFE program management.

5 CHAIR SUNSERI: I know your speaker is on,
6 but could you move it a little closer to you, you're
7 kind of soft spoken.

8 MR. MASHIO: Okay. So, first, structure
9 of the submittal. So, as explained in Chapter 8, we
10 submit DCD Revision 4 and tracking, update tracking
11 report. In addition, for the Chapter 18 mockup we
12 submit and docket. This mockup, is purpose of this
13 mockup to consolidate all associate mockup for the
14 Chapter 18 and submit by the data.

15 And we have technical report, based on the
16 human factor engineer program plan. And so, I have
17 one program management plan and eight HFE program
18 implementation plan.

19 And we also have our imaging -- our
20 document, which is not docketed, but audit by NRC
21 staff. And the topical report, this describes our US-
22 Basic HSIS, which I explain in detail later.

23 The technical report, we -- the following
24 element of HFE program is submitted for the
25 implementation plan. And so, one program management

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 plan and eight implementation plan.

2 And this PMP and IPs address specific HFE
3 activities and provide detailed methodology for those,
4 addressing the criteria in Chapter 18. And all our
5 PMP and IPs have same configuration with the document
6 from Section 1 through Section 8. So this, NRC staff
7 is really reviewing information for each section.

8 And regarding the procedure development
9 and training program development, these element are
10 addressed by the Chapter 13 review. And we have one
11 COL item for the human factor performance monitoring.

12 So, audit, NRC staff audit the following
13 design. So, one is HSI design style guide, which
14 applied the HSI designer developed the screen design
15 as a HSI design based on the style guide. And the
16 feature is comply with NUREG-0700.

17 And also, staff reviewed OER result and
18 this include US-Basic HSI. So, this include not only
19 the U.S. OE, but also the Japanese operating
20 experience. So, I will talking later.

21 And a topical report, this topical report
22 actually has been approved and the SER was issued.
23 But in this presentation, this topical report is vital
24 source for the US-APWR application, because this US-
25 Basic HSIS is applied for the US-APWR HSI design.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And this summary report we resubmitted
2 after completion with HFE activity. And OER is basic
3 HSI portion has been completed. But the rest of the
4 plant-specific US-APWR application will be
5 implemented.

6 We have two ITAACs. First ITAAC is we
7 conduct integrated system verification, which ensures
8 operator performance is stable and that there are no
9 failure criteria which touch on the human engineering
10 discrepancy issue.

11 And also, we have another ITAAC. This is
12 as-built control room design actually installed in the
13 site, according to the design specification feature,
14 which are being verified using the ISV.

15 CHAIR SUNSERI: So, I'm actually going to
16 ask my colleague Dennis over here, is that typical for
17 that control room design to be part of the ITAAC? It
18 just seems like it would be a design qualification.

19 MEMBER BLEY: Yes, I don't remember for
20 sure. If you go across the design certs, on a lot of
21 them, they weren't as far along when they got here as
22 this plant was, on having its control room design
23 pretty well along. So, I don't think there's a
24 standard thing, but I don't remember the ITAACs, so
25 I'd have to go back and --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: No, no, that's okay. It
2 just kind of stood out to me, but if it doesn't to
3 you, that's fine.

4 MEMBER RAY: Well, it would depend, I
5 think, Matt, on what credit was taken for the benefits
6 that they're describing there. And that's -- I can't
7 imagine, but normally, I agree with you, it would be
8 unusual to have it be an ITAAC.

9 MR. TAPIA: There are similar types of
10 ITAACs with regard to the structures of the reactor
11 buildings and such. Such as the thickness of the wall
12 is inspected and conforms to the design. So, this is
13 not unlike some of those ITAACs.

14 CHAIR SUNSERI: Yes, no, I probably
15 understand that Joe. I guess, it just, in my mind, if
16 I look at these two together, it seemed like Item 1 is
17 just, there's nothing wrong with it, it's just that
18 whoever's building it is going to assume all the risk
19 for any problems with it, right? Thank you. You can
20 continue.

21 MR. MASHIO: This picture shows basic
22 process. So, first, our topical report describes US-
23 Basic HSIS and feature applied to the US-APWR HSI
24 design process.

25 And then, we submit our technical report,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 which includes a program management plan and eight
2 implementation plans. And those document is docketed
3 and reviewed by NRC staff.

4 And then, after implementation plan have
5 been approved, then we implement it based on these
6 implementation plan. Then, after we complete
7 implementation, then we will submit to a docket as a
8 summary report.

9 And so, I'm going to the next topic for
10 the HFE program management plan. The US-APWR HFE
11 program management plan is in accordance with NUREG-
12 0711 Revision 2. And this HFE program assures HFE,
13 human factors principles satisfy applicable regulatory
14 requirements.

15 And following are HFE element covered by
16 our US-APWR HFE program. And as notes show, procedure
17 development and training program has been reviewed by
18 Chapter 13. And COL applicant will address human
19 performance monitoring program as COL items.

20 The next, this picture shows the overall
21 process for the HFE. And blue portion are covered by
22 the US-Basic HSI process, which described in our
23 topical report. And the green portion are covered by
24 US-APWR DCD and the technical report, as
25 implementation plan.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 So, I focus on the green portion, because
2 this blue portion has been approved by the -- so, now,
3 I focus on the green portion.

4 So, HFE will be implemented based on the
5 US-APWR plant design and then, we build US-APWR
6 inventory, featuring our control and monitoring and
7 information, is actually contents of the systems and
8 the plans.

9 But in other hand, we also utilize US-
10 Basic HSI. This is generic HSI functions, such as
11 around present or plant operator interact with
12 systems. Such kind of basic functions is utilized and
13 incorporated for the U.S. HSI design, here.

14 And this is standard portion, but we have
15 some site-specific information, we also integrate as
16 site-specific inventory information. And then, we
17 conduct V&V. Then, we implement the design.

18 CHAIR SUNSERI: So, back on that one, is
19 it fair to say that the blue part of this diagram is
20 basically done now? That work is complete and --

21 MR. MASHIO: Yes.

22 CHAIR SUNSERI: Okay. So, when you were
23 in the middle block there, U.S. operator assessment of
24 US-Basic, there's a step leading into that, I think
25 I'm missing it here, but the translation, U.S.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 conversion --

2 MR. MASHIO: Here?

3 CHAIR SUNSERI: Yes. Was there any
4 significant -- what was significant about that? I
5 mean, was there any significant way? It's not just
6 converting metrics and units, right? There's some
7 fundamental principles, right?

8 MEMBER BLEY: This was a big deal, we
9 talked about it a lot at the last meeting. In fact,
10 Bob Hall gave us a couple of technical papers that
11 described the process. I'll let them talk about it,
12 but it was a whole lot more. I think they first tried
13 that and then, that didn't work.

14 And then, they did some more work, and
15 then, they found just the whole operating practice
16 over here affected how you have to set this up. So,
17 it was a major conversion, but you guys ought to talk
18 about it some.

19 MR. MASHIO: Yes, actually, this -- I will
20 touch on this issue in the later, because my
21 presentation covers some US-Basic HSI design process.
22 So, I talk later.

23 But in summary, we tested with U.S.
24 licensed operator, using the dynamic simulator. And
25 then, we have some adjustment based on the gap between

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the U.S. operator framework and Japanese operator
2 framework. So, we had a gap and we resolved gap and
3 incorporated design procedures and training.

4 CHAIR SUNSERI: Okay, that's good. I can
5 --

6 MR. MASHIO: Okay.

7 CHAIR SUNSERI: -- I'll be patient.

8 MEMBER REMPE: I can't remember what we
9 discussed back then, but just from my -- a question
10 has been running through my mind since I read this
11 chapter. Is MHI a member of the PWR Owners Group?
12 Other design centers are.

13 MR. MASHIO: No, we are not member of the
14 PWR Owners Group.

15 MEMBER REMPE: So, there's a lot of
16 things, especially when you talk about accident
17 management procedures, that I would envision that the
18 COL applicant surely would want to be a member of it.

19 And that -- how does one convey, or is it
20 appropriate to convey that as part of the design
21 certification, that one would -- I mean, there's been
22 a lot of things that have happened over the years,
23 that it would seem prudent, or is that just beyond the
24 scope of the design certification? You see what I'm
25 saying?

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: It's an interesting
2 question, yes, I see what you're saying.

3 MEMBER REMPE: Especially with what
4 happened with the post-Fukushima actions.

5 CHAIR SUNSERI: So, that may be --

6 MEMBER REMPE: I don't know who answers
7 that question, but --

8 CHAIR SUNSERI: Yes, I don't know who,
9 right.

10 MEMBER REMPE: -- it's something that,
11 when I was reading this, I was wondering about that.
12 And maybe I'll ask the staff about that, unless MHI --

13 CHAIR SUNSERI: Yes, or maybe --

14 MEMBER REMPE: -- has a response.

15 CHAIR SUNSERI: -- direct it at Joe, maybe
16 that would be something that might be worthy to think
17 of going forward, when you get a U.S. customer or
18 whatever, how are they going to stay plugged in with
19 the PWR fleet, if you will.

20 MR. TAPIA: I understand the question.
21 And typically, the PWR Owners Group is comprised of
22 utilities, not designers. And the functions there
23 would be incorporated, I believe, into the COL
24 applicant's documents.

25 This is a good question, I'm speculating

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on my part here and thinking out loud about the answer
2 to your question. But I would imagine that the COL
3 applicant would apply all of those PWR Owners Group's
4 inputs into their application.

5 MEMBER REMPE: I would hope so, especially
6 during operation. And it's my experience that there
7 are other design centers who are actually leading
8 members of the Owners Groups over the years. And it's
9 good to have that industry interface. But anyway,
10 that's just an observation.

11 CHAIR SUNSERI: Well, yes, well, we kind
12 of evolved over the years, I mean, as there were three
13 different distinct vendors, right? You'd just see the
14 combustion engineering owners group, Westinghouse, and
15 GE. But as the industry consolidated, it just turned
16 into the PWR Owners Group and the BWR Owners Group,
17 right?

18 And so, this would almost be like taking
19 it back to the old way, where there were separate NSSS
20 vendors with their own design. But I don't know, I'd
21 have to think about it a little.

22 MR. TAPIA: We haven't had that
23 interaction --

24 CHAIR SUNSERI: Yes.

25 MR. TAPIA: -- with the utilities, I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 guess, is the answer, from our perspective, at this
2 point.

3 CHAIR SUNSERI: Okay.

4 MEMBER REMPE: Okay. Thank you. It's
5 just something that's been running through my mind.

6 MR. MASHIO: Okay. May I go to the next
7 slide?

8 CHAIR SUNSERI: Yes.

9 MR. MASHIO: Okay. So, the scope of the
10 HFE program management plan include following subject,
11 based on the NUREG-0711 review criteria.

12 And the second bullet means this HFE
13 activity methodology is described in the
14 implementation plan and each element if we complete
15 activities and we submit document and submit by staff
16 as a summary report.

17 The next couple of slide include
18 assumptions and constraint. And first, US-APWR HSI is
19 based on the application US-Basic HSI. And so, this
20 generic HSI technology is combined with specific HSI
21 Inventory for the US-APWR plant design, to create US-
22 APWR HSIS.

23 And the third bullet is, if we have some
24 or any other site-specific information, we integrate
25 the same into our site-specific HSI.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And fundamental design assumption and
2 constraint is, again, we utilize our US-Basic HSI and
3 so, this RO, the one RO and one SRO can operate all
4 condition, including the postulated accident. But
5 again, this morning, I explained based on the
6 regulatory requirement, we accommodate two operators
7 in the control room.

8 And the next is scope of the planned
9 facility. So, this is not only the MCR, but also the
10 other HSI which our operator staff can interact. But
11 other facility, we utilize our graded approach. So,
12 we take our graded approach to the implement HFE
13 process to other facilities.

14 So, that all for the PMP. And then, I'm
15 going to explain about US-Basic HSIS. And again, this
16 US-Basic HSI feature is described in the topical
17 report. And this contains our concept of operation
18 and the other HSI key feature.

19 And in appendix, there are some history of
20 the development of Japanese PWR control room, which is
21 starting point to develop the US-Basic HSI, which I
22 explain later. And we also have our V&V experience in
23 Japan in the Appendix B and US-Basic HSI design
24 process described in the Appendix C.

25 And background, so MHI used the fundament

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 element Japanese Basic HSIS as starting point to
2 create US-Basic HSIS. And Appendix A contains
3 information about Japanese Basic HSIS and development
4 history.

5 And the Japanese HSI is composed with
6 Basic HSI and HSI Inventory. This HSI Inventory is
7 developed as part of our US-APWR DCD, in accordance
8 with US-APWR HFE program.

9 So, this is a general process to develop
10 the US-Basic HSI and the site-specific HSI
11 development. And the first Phase 1 are described in
12 topical report. This is like translation from our
13 Japanese Basic HSI to the US-Basic HSIS.

14 And the Phase 2 is, this is development of
15 plant-specific, which is US-APWR application
16 inventory, which combined with US-Basic HSIS. And the
17 Phase 3 is confirm site-specific assumptions of Phase
18 2, or make minor changes, if needed.

19 And Phase 1, this is US-Basic HSIS design
20 process. So, we separate several subsidiary process,
21 which is Phase 1a and 1b. And the 1a is just a
22 convert from the Japanese language or in general
23 unique signs to the American style.

24 And then, we also implement, for the U.S.
25 operating procedures. And also, we incorporate the OE

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 result to the US-Basic HSI preliminary design
2 specification. Then, we developed the simulator.
3 Then, we had a test with U.S. licensed operators,
4 using the U.S. operating procedures.

5 Then, there are many comments regard our
6 human factor discrepancy. Then, we address those
7 discrepancy and to change the design specification.

8 So, one of the major comment is computer-
9 based procedure functions, because this Japanese style
10 of the operation is different from the U.S. operating
11 style. So, we adjust CBP functions and format. So,
12 again --

13 MEMBER BLEY: Could you tell us a little
14 the second test, that you made the changes on the
15 simulator?

16 MR. MASHIO: Yes. So, we also changed the
17 simulator, because we need to verify the operator
18 performance using the dynamic simulator. So, we also
19 made a change for the dynamic simulator and test again
20 in the Phase 1b. And to confirm the design change
21 specification is appropriate one.

22 So, as described here, we invited eight
23 crews in Phase 1a, and five crews in Phase 1b, to
24 verify HSI.

25 MEMBER BLEY: These were American

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 operators?

2 MR. MASHIO: That's correct. And again,
3 this Phase 1 Alpha is, we identify the difference,
4 then we improve the design to adjust U.S. operation
5 scheme.

6 And during the review, we coordinate,
7 organize multi-disciplinary, such as not only HFE
8 person, also the associated member, such I&C, plant
9 operations, system engineers. And the results of
10 those are implemented in the various points.

11 And the operating experience sources
12 include NUREG/CR-6400, each required by NUREG-0711.
13 And we mentioned that we also reviewed our INPO
14 database, also the Japanese OE sources.

15 And these HSIs are experiences, very
16 limited for the nuclear industry, so we decide other
17 non-nuclear industries, such as airplane or trains,
18 both U.S. and Japan.

19 And all of OE information is screened by
20 the HFE related issue, such as human error type,
21 training type, procedure type thing. We analyze which
22 are causes. Then, we reflect the design. So, those
23 document is documented internally and NRC staff is
24 audit that document.

25 And the next couple of slide explain the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 concept of operation. So, I just explain the key
2 feature. So, the normal MCR mode, so this slide will
3 be -- may send a different message, but I just collect
4 by brief.

5 So, this control room console can conduct
6 one operator, one RO and one SRO can operate all
7 remote. But based on the U.S. regulation, we staff
8 two RO and one SRO and one STA. So, that means the
9 next is --

10 MEMBER BLEY: Excuse me, when you did
11 that, did you layout a division of responsibilities?
12 We usually see one RO focused on the primary systems
13 and another on the balance of plant and electrical
14 plant. Did you do that or is it up to the COL to
15 figure out what to do with the extra operator you
16 have?

17 MR. MASHIO: Yes, actually, the scenarios
18 for the, to test it is, we utilize U.S. operating
19 procedures, which basically is we split the role. One
20 RO responsible for the reactor side and another RO is
21 responsible for the turbine side. So, we, basically,
22 we use normal U.S. configuration, I think. But in
23 addition, that we also tested just one operator, using
24 he responsible for both side.

25 MEMBER BLEY: Everything?

1 MR. MASHIO: Yes, yes. So, but --

2 MEMBER BLEY: Any difference in the tests?

3 MR. MASHIO: Different --

4 MEMBER BLEY: Results of the tests?

5 MR. MASHIO: Yes, different, yes. This
6 HSI VDU is integrate. And so, this reduce operator
7 work, physical workload. And so, basically, he can go
8 through one-by-one, based on the SRO's direction. So,
9 it's -- we verify they could go through it.

10 But challenging thing is for the dedicated
11 HSI condition, so normal operating, non-safety VDU is
12 not working, then they switch to the safety VDU only.
13 This is challenging for the operators to mitigate the
14 accident.

15 But they -- we have some modification,
16 such as -- this is very detailed. But we made a
17 change with the safety VDU HSI design, we verified
18 they can complete accident mitigation using only
19 safety HSIS.

20 MEMBER BLEY: Okay.

21 MR. MASHIO: So, yes.

22 MEMBER BLEY: Thank you.

23 MR. MASHIO: So, next picture, this is the
24 console layout and so, we have a large display screen
25 here and operator console, and two RO can sit in front

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 of the operator console.

2 Then, behind that, supervisor console, SRO
3 can sit here. And we have SRO -- STA can sit and he
4 can advise control room staff, in case of the
5 accident.

6 And we also have diverse HSI panel here.
7 So, all these HSIs down, as a common-cause failure,
8 then they move to here and to cope with the accident
9 using these panels.

10 MEMBER BLEY: There were some interesting
11 tests done at Halden, I wonder if you were privy to
12 those, where they took the shift technical advisor,
13 the STA, and had him in sort of this configuration.
14 And then, they moved him separate from all the other
15 people, just observing.

16 And they got some very interesting results
17 on the effectiveness of the STA under those different
18 circumstances. You might take a look at that, I think
19 you might find it interesting. It's been about four
20 years ago, yes. I can give you a contact over there.

21 MR. MASHIO: Okay. Can I go to next
22 slide? So, this computer-based HSI provide operation
23 display and it features fundamental interface.
24 Basically, operator can touch on the display and all
25 action can be conducting using VDU.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And the operator workload is reduced,
2 providing the information at the integrated display.
3 And they cannot movement inside the console. So, they
4 just utilize VDUs in front of him. So, those
5 workload, these functions can, one RO operate whole
6 remote.

7 And diverse HSI also have some operating
8 supporting function. So, these are computer checking
9 status, plant status, then provides information to the
10 operators. And this operating supporting function
11 also contributes workload as well and also reach our
12 ends.

13 And the large display panel provide -- I
14 can show this picture. So, we have -- this is
15 pictures of the control room. And this one is the
16 large display panel. And we have three fixed display
17 and one variable display.

18 So, this fixed area, all major
19 information, such as, you can see these are primary
20 power systems and the turbine and the generator
21 system, all important parameters can be shown in this
22 fixed display. And all alarms is pop-up in the fixed
23 display. So, the operator can view this information
24 over other information.

25 In addition, in the variable area, any

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 display feature the operator console, also the
2 supervisor console, can display here. So, this can
3 allow MCR staff has the same information and use them
4 to communicate with each other.

5 So, I explained those. And in this
6 control room, we also have paging feature, all
7 facility from MCR. Also, we have intercom functions,
8 which are communication from between MCR staff and
9 LOCA staff.

10 And they are not in this picture, but we
11 also have maintenance console, which can use during
12 the periodic maintenance or shutdown condition. And
13 the tagging feature also implemented in this diverse
14 HSI.

15 So, I think that that's all. Yes. That's
16 all our presentation.

17 CHAIR SUNSERI: That's the end? Okay. We
18 had a lot more slides in the material that was sent to
19 us.

20 MR. MASHIO: Yes, I think I --

21 CHAIR SUNSERI: Seventy.

22 (Simultaneous speaking.)

23 (Laughter.)

24 CHAIR SUNSERI: Now we can ask all kinds
25 of questions. Okay. So, thank you. We'll ask the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 members if you have any additional questions?

2 MEMBER DIMITRIJEVIC: I'm just curious,
3 did you have to provide the list of important human
4 actions from your PRA Chapter 19 in Chapter 18?

5 MR. MASHIO: Yes. Yes, we documented and
6 we collect all our list of significant actions from
7 PRA --

8 MEMBER DIMITRIJEVIC: Right.

9 MR. MASHIO: -- and HRA, yes.

10 MEMBER DIMITRIJEVIC: So, do you remember,
11 like ad hoc, which actions seem to be important?

12 MR. MASHIO: Yes. One was, this is steam
13 generator activation of the ruptured SG, this one --
14 yes.

15 MEMBER DIMITRIJEVIC: For the steam
16 generator tube rupture?

17 MR. MASHIO: Tube rupture, yes.

18 MEMBER DIMITRIJEVIC: How about switching?
19 You don't have to switch to recirculation, so there is
20 nothing in the LOCA which is important?

21 MR. MASHIO: Yes, LOCA is no, I think
22 there's no action. In the large LOCA, it's automatic
23 function, such as SI injection by automated, so
24 they're not necessary for the operator action in the
25 LOCA.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER DIMITRIJEVIC: And those gas
2 turbines, can they be manually loaded?

3 MR. MASHIO: No, gas turbine also
4 automatically started, initiated.

5 MEMBER DIMITRIJEVIC: But do you credit
6 the manual backups of the recovering power or loading
7 the --

8 MR. MASHIO: Yes, in general, yes,
9 basically, this is safety interlock, so they are not
10 necessary to take manual action, yes. But if -- we
11 also consider the degraded HSI mode, which is if, you
12 know, our system is not functioning, such as common-
13 cause failure, then we --

14 MEMBER DIMITRIJEVIC: You go to recovery?

15 MR. MASHIO: Yes, yes.

16 CHAIR SUNSERI: Dennis, did you have
17 something?

18 MEMBER BLEY: I didn't, just checking
19 things.

20 CHAIR SUNSERI: All right. Any other
21 comments?

22 MEMBER BROWN: Yes.

23 CHAIR SUNSERI: Charlie?

24 MEMBER BROWN: I've got to find it now.
25 You had a slide we talked about how the operators --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: Mic.

2 MEMBER BROWN: I'm sorry, mic. There was
3 a slide where you talked about how the operators
4 accessed the VDUs. Ah, here it is, it was Slide 36.
5 I'm going backwards now to eight years ago, when we
6 first looked at this, because they're the same, it's
7 the touch screens. And have you all got any of these
8 touch screen control panels in service anywhere in
9 actual plants today.

10 MR. MASHIO: Yes, actually, Tomari
11 Industry, this latest three-loop plant in Japan,
12 utilize this touch screen based --

13 MEMBER BROWN: How long have they been in
14 service?

15 MR. MASHIO: This commercial operation is
16 2009, December.

17 MEMBER BROWN: Okay, about ten years --

18 MR. MASHIO: Yes, yes.

19 MEMBER BROWN: -- ago, then?

20 MR. MASHIO: Yes, but after the Fukushima
21 accident, Tomari Industry also stopped and is
22 currently --

23 MEMBER BROWN: I lost track of what you
24 just said.

25 MR. TAPIA: They shut down.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. MASHIO: Shut down, yes.

2 MEMBER BROWN: After what? After
3 Fukushima?

4 MR. MASHIO: After Fukushima, yes.

5 MEMBER BROWN: Okay, so that was 2011?

6 MR. MASHIO: Yes.

7 MEMBER BROWN: Okay. My memory's locator
8 bits are not working real well right now. The reason
9 I ask is, I hate touch screens.

10 (Laughter.)

11 MEMBER BROWN: Personal opinion, based on
12 experience, that every time I've touched one thing,
13 all of a sudden, the screen disappeared and something
14 else popped up.

15 How much -- did you all get any feedback
16 in that period of time? It says you have two ways of
17 doing it, either by touching a screen or clicking, so
18 I presume you click on it with a mouse of some kind
19 like this?

20 MR. MASHIO: Yes, actually, I had some
21 interview with, actually the Comanche Peak person
22 participated in the test and I remember their feedback
23 for the touch screen is very efficient.

24 Because the -- all the touch screens are
25 not have accuracy to, pointing device is not accuracy,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 but this touch screen feature, we made the text, this
2 is, I think, 2008 or 2009, maybe ten years ago. Even
3 though ten years ago, these touch screens are
4 efficient, so, this accuracy to pointing.

5 MR. TAPIA: He's also asking about, do you
6 have feedback from the Japanese operators?

7 MR. MASHIO: Yes. Sorry. So, in the
8 operating plant in Japan, actually, I did not go to
9 the interview for them, so actually I have no
10 opportunity to get feedback from them.

11 MEMBER BROWN: Okay, all right. That's --

12 MR. MASHIO: Yes.

13 MEMBER BROWN: -- fair answer. I just,
14 it's just a particular -- I've watched a few where
15 people's laptops and they touch and all of a sudden,
16 things move around.

17 And these are dedicated, they're fixed
18 screen panels, as you all have described them, I just
19 went back and looked at the DCD, okay. So, it's not
20 like a smartpone, where things are sliding all over
21 the place. So, I was just curious as to, number one,
22 the sensitivity to the touch.

23 MR. HALL: Let me talk about the testing
24 we did during --

25 MEMBER BROWN: Oh, that would be --

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MR. HALL: -- that Phase 1a and b.

2 MEMBER BROWN: -- if you have some, that
3 would be nice.

4 MR. HALL: And there are a number of
5 papers out there. There was a test report written,
6 but it was never submitted to the NRC, but there are
7 papers out there, Dennis referred to one of them.
8 They sent -- just staying with the touch screen. U.S.
9 operators, all from Comanche Peak --

10 MEMBER BROWN: Okay.

11 MR. HALL: -- Phase 1 had 22 of them,
12 because we were looking at two operators versus one
13 operator, very little difference between the two.
14 Phase 2, we did ten operators, we never doubled up on
15 the -- ten people from Comanche Peak.

16 As far as the touch screens were
17 concerned, the first go around, there were questions
18 and concerns. And the questions and concerns were
19 size of the touch --

20 MEMBER BROWN: Fat fingers versus small
21 fingers.

22 MR. HALL: Exactly -- on the screen. And
23 touching what you thought you were touching, but not.
24 Sensitivity of it, how long you had to touch it, how
25 hard you had to touch it to make it respond. Changes

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 were made and during the Phase 1b tests, resolved.
2 So, the outcome of all of those tests had very
3 positive operator response to how the screens
4 functioned.

5 MEMBER BROWN: Okay.

6 MR. HALL: But some of your questions, and
7 what happens on my Apple Watch, those were
8 investigated and changes made. Because I touch on the
9 wrong things too.

10 MEMBER BROWN: Well, when I go to the
11 grocery store here, I have to get a number for the
12 deli section, and there's a little touch screen and
13 you'll touch, nothing happens. I have to touch it
14 eight, nine, ten times, put my whole hand on it, still
15 doesn't go.

16 MEMBER BLEY: Lick your finger.

17 MEMBER BROWN: That doesn't work either,
18 but that's -- I don't want to do that the third or
19 fourth time --

20 MEMBER BLEY: I will tell you --

21 MEMBER BROWN: -- because I don't want to
22 get other people's germs.

23 MEMBER BALLINGER: Have you thought about
24 there being a no-fly list at your grocery store?

25 MEMBER BROWN: Ron, I'll defer you to you

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 on that one.

2 MEMBER BLEY: I'm going to give you
3 another example. Out at Palo Verde, they tried one of
4 these glass-top simulators and put their whole control
5 room simulator on it. And they ended up liking it so
6 much, they bought about 20 of them, put them all
7 around the plant, so people could run the simulator
8 anywhere. And they've had no trouble with it.

9 MEMBER BROWN: That's good.

10 MEMBER BLEY: They've really --

11 MEMBER REMPE: Did it ever lock up and
12 they had to reboot? Or did they -- was that part of
13 your testing?

14 MR. HALL: It never did in reality, but we
15 forced some things such as that. What we did is, the
16 first time around, and please don't quote me on the
17 exact numbers, but the first time around, I think we
18 ran six scenarios, with secondary and tertiary
19 failures built into them.

20 Second set of tests, we ran I think eight
21 scenarios, again with anything from a screen lock-up
22 to total loss of display systems to alarm lock-ups, et
23 cetera. And ended up with quite good responses, if
24 you look at the test results.

25 MEMBER REMPE: So, they just had to wait

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 and reboot? Or what did they do? Go to an alternate
2 screen?

3 MR. HALL: Typically, go to an alternate,
4 unless in fact everything locked up at once. And we
5 looked at response times for deciding whether the
6 screen had in fact locked up or not.

7 We didn't -- initially, it was, you didn't
8 realize the screen was locked up until you touched it
9 and nothing happened. We changed that and put an
10 indication, where you could see a heartbeat, that it
11 was or was not functioning, things like that.

12 MEMBER REMPE: Okay, thanks.

13 MEMBER BROWN: The other reason for my
14 question was that I was in the Naval Nuclear Program
15 and we had great debates, starting from 1970, there
16 weren't touch screens in 1979, shows you how old I am,
17 but as we transitioned up to the later classes of
18 ships, the ones that we started developing in the late
19 '90s, before I retired in '99, we were still having
20 all control functions with switches, so that you could
21 maintain a touch-feel for where they were, as opposed
22 to selecting actual control functions.

23 We selected touch screens for pulling up
24 a menu of alarm details or something like that, but
25 not for the actual starting or stopping of a pump,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 whether it's a reactor coolant pump or a safeguard
2 pump or feed pump or et cetera, et cetera, et cetera.
3 Now, I don't know what they're doing on the new plant,
4 I don't remember reviewing that.

5 But I do know there was a lot of very, for
6 the sailors, since actions are happening very, very
7 fast in some of the submarines, well, in all of the
8 submarines or the carriers, that you wanted -- this
9 way, they could have the touch, actual positional
10 feel, and know whether they were in slow, fast,
11 intermediate, or what have you.

12 So, I was just curious what you experience
13 you had. So, that was the purpose of my question.
14 Thank you for your elucidation.

15 CHAIR SUNSERI: Any other member comments?

16 MEMBER BROWN: And Dennis's feedback.

17 CHAIR SUNSERI: Any other comments? Okay.

18 So, wrapping up the section with the Applicant. I
19 recorded two items that I think we'll give to you as
20 part of follow-ups for future presentations.

21 The first one will be, and I'm not sure
22 where, I'm just going to throw these out and you'll
23 decide when you hear the topic, but it's either going
24 to be Chapter 3 and 4, and it will be the follow-up on
25 the seismic analysis of the reactor vessel due to the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 increased mass of the neutron reflector.

2 The second item will probably be a Chapter
3 7 discussion, but I just want you to be aware that,
4 since we reviewed the digital I&C system in the first
5 go round, there's been some lessons learned in our
6 area, and we have developed some principles of
7 operation around digital systems.

8 I think there's five principles. You
9 talked about two of them, defense-in-depth and
10 diversity, there's others. So, I would commend you to
11 emphasize how you're addressing these principles in
12 your presentation when you come to Chapter 7 on
13 digital I&C. And Charlie can give you the five
14 principles.

15 MEMBER BROWN: Of course. There was a
16 staff engineer, NRC staff, asked also what I was
17 talking about, so I explained it to him during the
18 break.

19 The point is, we've been emphasizing five
20 fundamentals in developing the architecture. You have
21 an architecture defined in your DCD and it's amplified
22 by one of your topical report or technical report, I
23 can't remember what the term is, which I just went
24 back and looked at also.

25 But they were independence, redundancy,

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 deterministic processing, diversity, and defense-in-
2 depth, and control of access. We didn't cover -- the
3 control of access wasn't amplified as much back in
4 2010 and 2011 as they are today.

5 Largely, that was -- you have networks in
6 your plant and the networks communicate exterior to
7 the plant. And the point of that was that protection
8 systems and safeguard systems, outputs, can go to the
9 control room, which is internal to the plant.

10 But when you go to networks that have
11 external access out to the internet world, they should
12 be, any information passed on should be hardware-
13 based, one-way communications, not software controlled
14 firewalls.

15 And we've emphasized that pretty strongly,
16 just from a -- it's a control -- forget cyber, that's
17 a whole 'nother world. This is strictly access
18 control. And so, and I explained that to him.

19 The other point was watchdog timers and
20 how they communicate. You do have a whole section on,
21 or there is a section on, I went back and checked this
22 also, just to make sure, on watchdog timers, in your
23 tech topical report on the MELTAC platform.

24 There may be some nuances, I went back and
25 took a quick read on it, and there's a few nuances

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 that we'll probably bring up. So, I presume you'll
2 have people that can discuss that at that time.
3 That's all I want to make sure we cover. Okay?

4 CHAIR SUNSERI: You don't have to get back
5 to us, it'll just be part of your presentation.

6 MEMBER BROWN: That's right. You don't --
7 I'm not expecting anything, other than --

8 MR. TAPIA: Is that the same for the first
9 one on the seismic --

10 CHAIR SUNSERI: Yes.

11 MR. TAPIA: Okay.

12 CHAIR SUNSERI: Yes.

13 MR. TAPIA: So, I don't owe you anything?

14 CHAIR SUNSERI: You don't owe us.

15 MEMBER BROWN: No.

16 CHAIR SUNSERI: I don't recall --

17 MR. TAPIA: Just be sure we cover that.

18 CHAIR SUNSERI: -- anything that you owe
19 us as a result of Chapters 8 or 18.

20 MR. TAPIA: Understand, thank you.

21 CHAIR SUNSERI: Okay.

22 MEMBER BROWN: I'll amplify one other
23 thing on the watchdogs. If you look at the last
24 projects that we looked at, the new design certs, you
25 have to vote on trip signals from each of the

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 independent channels.

2 And there's -- you use a processor for
3 that as well, it's not an analog voting, like the old
4 days. So, if they lock up, the watchdog timer needs
5 to detect that.

6 And all your tech report says, it says
7 there's a failure. It doesn't say what is processed
8 as a failure, what does that do? Does it send a trip
9 out as one of the trips to the reactor trip breaker,
10 the two out of four that runs for that, or not? Or is
11 it just an alarm that goes to somebody?

12 For the safeguards part, you obviously
13 don't want to start safeguard systems. But for
14 reactor trip, you really need to initiate a reactor
15 trip for that one channel, just to make sure -- as
16 well as an alarm.

17 So, that's kind of the context. And we'll
18 bring that up when we get to that particular chapter
19 review.

20 MR. TAPIA: Understand your comment.

21 MEMBER BROWN: And there's no feedback you
22 need to do anything right now, you got totally clear.

23 MR. TAPIA: Sure.

24 MEMBER BROWN: Okay?

25 MR. TAPIA: We're engaged with the staff

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 right now on this very item.

2 MEMBER BROWN: And I did explain that to
3 one of the staff, who knew exactly what I was talking
4 about.

5 MR. TAPIA: Thank you.

6 MEMBER BROWN: All right.

7 MR. TAPIA: We'll be prepared.

8 MEMBER BROWN: Thank you.

9 CHAIR SUNSERI: All right. So, we've
10 completed this agenda item. Mashio-san, thank you for
11 your presentation, very good.

12 And what I would like to do is, it's a
13 little too early to break for lunch, so I'd like to
14 have the staff come up here and present the Chapter 8
15 SER. It's only a few slides and I think we might be
16 able to get through that. Then, we will break for
17 lunch.

18 So, George, as you're getting together
19 here, I would also think that, depends on how fast
20 this goes, we might just roll into 18, and I don't
21 know if we can complete that.

22 MR. WUNDER: Okay.

23 CHAIR SUNSERI: And then, if we could, I
24 mean, the advantage to that is, that's a perfect
25 breaking point for the public session and we can close

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 the public and go into closed session after lunch for
2 the accumulator.

3 MR. WUNDER: We've got the people here and
4 we're ready to do it, if that's your desire.

5 CHAIR SUNSERI: Okay. We'll see how this
6 goes, all right?, the first chapter. And whenever,
7 you just let us know when you're ready.

8 MR. WUNDER: Okay. I got the button this
9 time, I made a little note there, so that I'd remember
10 it.

11 One of the challenges we face when we
12 resume work on a safety evaluation that's been idle
13 for some time is that the technical staff who worked
14 on the document may have moved on to other positions.
15 One of the things that makes us such an effective
16 agency, though, is that not only do we have first-rate
17 talent, but we have a very deep bench.

18 And in the case of both Chapters 8 and 18,
19 the principal contributors for the Phase 2 review have
20 moved on. So, we went to the bullpen. Sheila, Nadim,
21 and Brian all have a wealth of experience as technical
22 reviewers and they have a complete mastery of the
23 subject matter. And I will leave it now in their
24 capable hands.

25 CHAIR SUNSERI: Well, you have an

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 advantage over us, when the ACRS members leave, they
2 just leave, right?, there is no bench for us.

3 (Laughter.)

4 CHAIR SUNSERI: So, go ahead, please.

5 MR. KAHN: Thank you, George. As George
6 mentioned, my name is Nadim Khan. The US-APWR
7 electrical power system consists of --

8 CHAIR SUNSERI: Is your -- yes, could you
9 pull that a little closer, please?

10 MR. KAHN: Okay. The US-APWR electric
11 power system consists of the offsite power system and
12 the AC and DC power system.

13 During the staff's review, there were two
14 open items. Both issues were closed in Phase 4 and
15 today, I will discuss the open items and the
16 resolution of these items. The open items are related
17 to open phase condition and GTG reliability.

18 The first open item is regarding the open
19 phase condition and the staff's position is outlined
20 in BTP 8-9. BTP 8-9 discusses the electrical power
21 system's design vulnerability due to an open phase
22 condition in the offsite electrical power system.

23 The staff requested the Applicant explain
24 how its electrical system design would detect, alarm,
25 and respond to an open phase condition. The

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 protection features for the open phase condition per
2 BTP 8-9, the Applicant provided COL Item 8.212, in
3 which the COL applicant is to determine the type of
4 open phase detection and protection system and address
5 the guidance in BTP 8-9.

6 The staff determined that COL Item 8.212
7 will ensure that the COL applicant will determine an
8 open phase detection and protection system that meets
9 the guidance in BTP 8-9, including detection, alarm in
10 the main control room, and protection features, in
11 that the Class 1E medium voltage buses will transfer
12 to a power source without an open phase condition.

13 DCD Tier 2 Section 8.2 includes a general
14 description of the criteria for addressing OPC. Since
15 the Applicant has provided a COL item, ITAAC, and tech
16 spec to ensure the open phase detection and protection
17 system provides detection, alarm in the main control
18 room, and protection features, the staff finds this
19 issue closed.

20 With that, I will turn it over to Sheila.

21 MEMBER BROWN: Before you leave --

22 MR. KAHN: Yes?

23 MEMBER BROWN: -- oh, jeez, I lost it.

24 Oh, here it is. In your SER, which I can't find now,

25 oh, there it is, I'm recollecting this, my notes are

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 crummy, you made the -- in your evaluation of the open
2 phase, you summarize their response to you all.

3 And I thought, in their response, they
4 identified that the present design would do a certain
5 amount of things, but there were a couple of items
6 that you all identified in a follow-up RAI that it
7 wouldn't and that they would -- and their response
8 was, that's what they would incorporate.

9 Is my -- in other words, it's not like
10 they're totally devoid of any open circuit protection
11 going into this. So, the current design had some
12 features.

13 MR. KAHN: Yes, there is protection for
14 the high side.

15 MEMBER BROWN: For the high side, that's
16 what I thought. And then, they said that in the --

17 MR. KAHN: The RAT.

18 MEMBER BROWN: Both the RAT and the UATs?

19 MR. KAHN: So, the main transformer is on
20 top of the UATs.

21 MEMBER BROWN: Yes.

22 MR. KAHN: So, there's protection on the
23 high side of the main transformer and the RATs --

24 MEMBER BROWN: Okay.

25 MR. KAHN: -- which is a non-Class 1E.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And then, they proposed to use the undervoltage
2 detection system on secondary side of the UATs and the
3 RATs.

4 MEMBER BROWN: That's already existing?

5 MR. KAHN: Yes.

6 MEMBER BROWN: Okay. It's already there?

7 MR. KAHN: Yes.

8 MEMBER BROWN: Okay.

9 MR. KAHN: But when you use undervoltage
10 detection system, there isn't a change in voltage
11 magnitude, but there is a change in the phase.

12 MEMBER BROWN: That's what I remember you
13 discussed, the phase shift that you get and --

14 MR. KAHN: And that's why -- and they will
15 have a COL item that will address how to -- the
16 protection on the secondary side --

17 MEMBER BROWN: All right. So, it will --

18 MR. KAHN: The UAT and the RAT.

19 MEMBER BROWN: I got it. That's -- all
20 right. So, that's a loose end. In other words, they
21 were kind of covered, but not totally covered?

22 MR. KAHN: Yes.

23 MEMBER BROWN: And that's fundamentally
24 what the COL item covers?

25 MR. KAHN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MEMBER BROWN: Okay, thank you.

2 MS. RAY: Any other questions?

3 MEMBER BROWN: No.

4 MS. RAY: All right. Thank you. My name
5 is Sheila Ray and I will be presenting the second item
6 on GTG reliability.

7 MHI proposed the use of gas turbine
8 generators as the Class 1E emergency power source for
9 the onsite AC power systems. GTGs have not been used
10 in the operating fleet as Class 1E power sources.
11 Therefore, there is no operating experience and no
12 reliability data for the U.S.

13 In the absence of operating experience and
14 reliability data, the staff requested the Applicant to
15 perform type tests to ensure the GTGs will perform
16 their intended function and achieve their target
17 reliability level.

18 MHI discussed the qualification
19 methodology and initial type tests for the GTGs in
20 Technical Report MUAP-07024. Specifically, the type
21 test includes load capability testing, start and load
22 testing, and margin tests, per IEEE standard 387-1985,
23 as endorsed by Regulatory Guide 1.9.

24 The Applicant documented the successful
25 qualification of the Class 1E GTGs in Technical Report

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 MUAP-10023. MHI successfully performed 150 start and
2 load acceptance tests of the GTGs.

3 The report demonstrated that the GTGs were
4 able to start and ready to accept load well within 100
5 seconds, which is the GTG start time used in the
6 accident analysis. The successful starts satisfy the
7 reliability criterion of 0.975 with 95 percent
8 confidence.

9 In conclusion, the staff finds that the
10 Applicant's approach to demonstrating the Class 1E GTG
11 reliability is adequate, considering compliance with
12 GDC-17, conformance to Reg Guide 1.155, as well as
13 successful qualification via type testing. This
14 concludes the staff's presentation.

15 MEMBER BROWN: I guess one question, when
16 you -- and this is my interpretation of what you're
17 saying, to make sure I understand it. You said it was
18 they did the 150 starts and ready to accept load
19 within 100 seconds, fine. Did they actually apply the
20 load within 100 seconds? Full load?

21 MS. RAY: I will have to go back and
22 check.

23 MEMBER BROWN: Being ready to accept it is
24 one thing, being able to accept it is another.

25 MS. RAY: Understand. I know they did

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 have load banks, so they may have put load on. I
2 would request the Applicant, if they have any
3 information.

4 MEMBER BROWN: The rating of these is 50
5 --

6 MS. RAY: It's 4500 kW.

7 MEMBER BROWN: Forty-five hundred, that's
8 right, thank you.

9 MS. RAY: Right. And then, 4950 for the
10 short-time.

11 MEMBER BROWN: That's overload, but, I
12 mean, you should be able to start.

13 MS. RAY: Correct.

14 MEMBER BROWN: And I don't know what the
15 maximum, whether they -- do they time the loads coming
16 in? Or is it based on applying -- I'm going back to
17 my Navy experience, because I just, if I had a 450 kW
18 turbine generator set or a 1000, we applied the full
19 load to it.

20 MS. RAY: Right. So, they also did
21 another test, this is a test not required by IEEE 387,
22 but recommended by the manufacturer, where they loaded
23 the GTG from 25 percent to 100 percent and also
24 checked the reject of that load. So, they would have
25 done loading 75 percent all the way, and 100 percent

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 --

2 MEMBER BROWN: That's starting at 25?

3 MS. RAY: Right.

4 MEMBER BROWN: They started -- so, they
5 already -- my point was, if you have to time your
6 loads, if you have to have a timed load application,
7 that's fine, I don't have a problem with that. But
8 that ought to be explained and at least identified so
9 a COL doesn't not understand that when they actually
10 do their plant design.

11 MS. RAY: The technical report, the second
12 one, and I believe also the first one --

13 MEMBER BROWN: This is the 23, right?

14 MS. RAY: The 23, and I believe the 07024,
15 showed the loading sequence for all of the trains of
16 the GTG. So, it's very clear for the COL applicant,
17 the timing and amount of load being applied.

18 MEMBER BROWN: So, it doesn't have to --
19 these, then, would not be designed to accept a full
20 4500 kW load instantaneously?

21 MS. RAY: Instantaneously, no.

22 MEMBER BROWN: Okay. So, that's --

23 MS. RAY: It's sequenced on.

24 MEMBER BROWN: All right. And when -- I
25 don't know what you all's requirements are, but I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 presume that means when it's loaded, the deviation
2 from the final allowable steady-state frequency and
3 voltage, it has to -- you can dip only a certain
4 amount out of the band and you have to recover, I
5 don't remember what the IEEE specs are.

6 MS. RAY: That is correct. There is a --

7 MEMBER BROWN: And then, you have to
8 recover within a couple of seconds or something like
9 that.

10 MS. RAY: That is correct. And the second
11 report, the 10023, demonstrated that, that they were
12 able to, I believe they were able to come back to
13 nominal voltage and frequency within approximately
14 four seconds.

15 MEMBER BROWN: Okay. All right. Okay,
16 you answered my question.

17 MS. RAY: Okay.

18 MEMBER BROWN: Thank you.

19 MS. RAY: Thank you.

20 MEMBER DIMITRIJEVIC: But if you have the
21 second test, where they loaded, to show the disconnect
22 and connect and sequence of load, then they have some
23 running data too, right? The diesel generators always
24 have a problem with the first hour of running. So,
25 did they have any -- this is all starting failure

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 data, which you presented here, right? Did you have
2 any running failure data?

3 MS. RAY: I do believe the -- there is an
4 initial test program where they will run the GTGs two
5 hours short-time, 22 hours continuous.

6 MEMBER DIMITRIJEVIC: Okay.

7 MS. RAY: So, there are tests where they
8 will be demonstrating the GTG that is actually
9 installed. Does that answer your question?

10 MEMBER DIMITRIJEVIC: Yes, that answer my
11 question. I was just wondering, would that data be
12 available to look in that way. Because it will be
13 interesting, because we do have a gas turbine, not as
14 a safety system, but we don't have good data for it.

15 MS. RAY: Correct.

16 MEMBER DIMITRIJEVIC: Yes.

17 MS. RAY: And I believe at the COL stage,
18 I believe there are ITAAC for the GTG.

19 MEMBER BROWN: The way I -- I'm sorry, are
20 you finished?

21 MEMBER DIMITRIJEVIC: Yes.

22 MEMBER BROWN: My interpretation of that
23 is, they ran tests on gas turbine generators that they
24 have. When the COL, if you actually go build one of
25 these, that doesn't mean they're going to get the same

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 gas turbine generator, it might not be available
2 anymore. So, they'll develop one, but it has to meet
3 these requirements.

4 MS. RAY: Correct. The --

5 MEMBER BROWN: Is that -- okay.

6 MS. RAY: The DCA will say, these are the
7 ratings that I request. The COL applicant, if they
8 use a different manufacturer, then they would have to
9 show qualification testing.

10 MEMBER BROWN: If it's different from the
11 one that was tested via these --

12 MS. RAY: Correct.

13 MEMBER BROWN: Okay. Thank you.

14 CHAIR SUNSERI: Did you have any other
15 material?

16 MS. RAY: No, that was all we had. Any
17 other questions?

18 CHAIR SUNSERI: Any other questions from
19 the members? Okay. Well, then, I guess, we thank you
20 for that presentation. And we will take Chapter 18
21 now.

22 MS. RAY: Thank you.

23 CHAIR SUNSERI: Thank you. No, no, no,
24 we're going to roll into Chapter 18 and see how far we
25 get. We may break, we'll probably go -- if we don't

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 finish by 12:30, we'll break for lunch at 12:30. No,
2 no, just the public part.

3 MR. WUNDER: Okay. I guess we're ready to
4 move on to Chapter 18.

5 CHAIR SUNSERI: And we're ready for you.

6 MR. WUNDER: I guess we're ready to move
7 on to Chapter 18 and the man without a name card is
8 Dr. Brian Green.

9 DR. GREEN: I had written down my
10 introductory notes here and I had good afternoon, but
11 I've got to adapt, so good morning, everybody. I'm
12 Brian Green, I'll be summarizing the Chapter 18 review
13 today.

14 I played a small role in this review.
15 Actually, I was on the acceptance review and then, I
16 went to NRR for a while, and now, I'm back. So, I'll
17 do my best to represent the material the staff did
18 here. All right.

19 Staff's review of the US-APWR was somewhat
20 unique from the design certifications of applications
21 that preceded it. This is because MHI submitted MUAP-
22 07007, the topical report which describes a generic
23 human system interface platform for NRC review, in
24 addition to the application materials that are
25 typically submitted for design certification.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 The generic platform described in the
2 topical report was reviewed by the staff and it was
3 concluded that it conformed to NUREG-0700, the staff
4 guidance that the staff uses to assess the design of
5 human system interfaces.

6 The submission of the topical report
7 describing the generic platform was unique from
8 previous design certifications. The DCD describes a
9 human factors design program that will be used to
10 build upon the generic HSI platform described in the
11 topical report.

12 Staff reviewed MHI's human factors program
13 and found that it conformed the NUREG-0711, the staff
14 guidance for reviewing human factors programs.

15 While reviewing the transcripts of the
16 previous ACRS meeting, I noticed there was a fair
17 amount of confusion as to why there was a need for a
18 human factors program, if the staff had already
19 reviewed the human system interface platform described
20 in the topical report.

21 I think Kenji did a great job of
22 describing that this morning. I prepared a slide to
23 discuss it and I'll dig into it, but if you feel
24 you've heard enough of it, we can move on.

25 So, the initial APWR design is being

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 licensed and constructed in Japan. The design was
2 created using a process that is similar to the one
3 described in NUREG-0711. This design process helps to
4 ensure that designers conduct appropriate human
5 factors analyses, design activities, evaluations, and
6 implementation activities that focus on human
7 performance.

8 The adequacy of the HFE activities
9 associated with the Japanese HSI design was not a
10 significant consideration in the staff review.
11 However, the staff acknowledges that these design
12 activities provided MHI with an early opportunity to
13 identify and resolve potential issues with the
14 Japanese HSI design. This is shown in the first arrow
15 on the graphic above.

16 Since the Japanese predecessor design was
17 created using good human factors principles, it forms
18 a solid baseline for the US-APWR design, with regards
19 to the human performance.

20 MHI recognized that some aspects of the
21 predecessor design did not universally apply to
22 operators in other countries. In other words, some
23 modifications were necessary for the US-APWR to
24 support U.S. operators and to comply with U.S.
25 regulations.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 Some examples of these changes include
2 converting units to U.S. standards, translating and
3 adapting procedures to English and to the U.S. concept
4 of operations, as well as other considerations.

5 Topical report refers to these activities
6 as Phase 1a, which I think of as Americanizing the
7 Japanese design, and Phase 1b, which is used to
8 resolve any issues associated with these
9 modifications. You'll find this is demonstrated in
10 the second arrow on the slide in front of you.

11 What is more similar to the other design
12 certifications that you've reviewed before is the
13 third arrow here. And that's the third iteration,
14 where MHI will conduct the activities described in the
15 DCD and the implementation plans.

16 The outcome of this process will be the
17 US-APWR human system interface design. The activities
18 conducted during this iteration are in many ways
19 similar to the activities conducted by previous design
20 certification applicants.

21 These activities are the primary focus of
22 the staff's review that we're discussing today.
23 Activities include a variety of human factors analyses
24 and design activities that guide the development of
25 the US-APWR human system interface inventory.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 In addition, a series of verification and
2 validation tests will be used to provide performance
3 based data to confirm that operators can safely
4 operate the plant.

5 Moreover, MHI provides yet another
6 iteration of design activities and evaluations during
7 a future site-specific design phase, which will
8 consider any unique aspects associated with a
9 particular site. And that's illustrated in the fourth
10 arrow.

11 As you can see, MHI's design of HFE
12 processes started long before the design certification
13 process and it continues after the design
14 certification is over. The iteration is, in my
15 opinion, a strength of the processes they have and
16 it's one of the human factors principles described in
17 0711.

18 A few -- the topical report has already
19 been approved, but I want to summarize it briefly
20 here.

21 At the time that the Phase 4 SER was being
22 written, the US-Basic Human System Interface was, I
23 believe to be the most detailed design description
24 that the staff had seen at this point. Many years
25 have passed since then, so things are a little

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 difficult to describe.

2 But part of that, staff had to rely
3 primarily on reviewing implementation plans,
4 essentially promises about how the plan will one day
5 be designed. So, in a sense, the fact that the
6 topical report was available to us, we actually got to
7 see it interact with the design in way we hadn't had
8 yet.

9 Staff conducted an audit of the HFE design
10 descriptions and found that they were consistent with
11 NUREG-0711. This provided confidence that good human
12 factors design principles were applied to the US-Basic
13 HSI.

14 Some brief comments about the design
15 certification. Design certification review builds
16 upon the US-Basic HSI described in the topical report
17 by completing the work according to the implementation
18 plans that are in the DC.

19 The staff reviewed the implementation
20 plans to ensure they met the acceptance criteria in
21 NUREG-0711 and to ensure that they were consistent
22 with the high level descriptions in the DCD. The
23 ITAAC described in Tier 1 helped to ensure that the
24 activities described in the implementation plans are
25 conducted appropriately.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 This slide has a summary, I know it's a
2 little bit of an eye chart here. These are -- this
3 demonstrates the 12 different elements of the human
4 factors review, as described in 0711. This basically
5 just shows what level of interaction the staff has had
6 with these different elements.

7 For instance, the HFE program management
8 plan is a complete element, we don't expect to do any
9 future work with that. We have several implementation
10 plans, which is consistent with what we've seen in
11 previous reviews.

12 The procedure development and training
13 program development were reviewed under Chapter 13.
14 There's significant overlap between these two
15 technical areas, so that was done to reduce
16 redundancy.

17 And the human performance monitoring is a
18 COL action item.

19 There are no open items and there are no
20 confirmatory items in Chapter 18.

21 In conclusion, the topical report
22 describes an acceptable generic platform called the
23 US-Basic HSI. This basic design will be iterated upon
24 using the implementation plans incorporated by
25 reference in the DCD, which the staff has found

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 consistent with the applicable guidance.

2 The implementation plans provide the staff
3 with confidence that future iterations on the basic
4 HSI will be consistent with the state of the art human
5 factors principles, as required by 10 CFR 50.34 and
6 other U.S. regulations.

7 In addition, ITAAC are used to verify that
8 the human factors practices described in the DCD and
9 implementation plans produce adequate results that are
10 ultimately incorporated into the final US-APWR design.

11 This concludes my prepared remarks. Have
12 you got questions?

13 CHAIR SUNSERI: So, there was a -- thank
14 you, Dennis. There were two ITAACs that the Applicant
15 discussed. One dealt with essentially confirming the
16 design aspects of the human system interaction, which
17 is going to be done very near the operational phase,
18 right --

19 DR. GREEN: That's right.

20 CHAIR SUNSERI: -- this ITAAC? And then,
21 the second one, I think was confirmation that the
22 installed equipment conformed with the design, right?
23 So, two would, in my mind, normally be separated in
24 time, but they've been put together --

25 DR. GREEN: Yes.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 CHAIR SUNSERI: -- in some way. What's
2 your thoughts on that?

3 DR. GREEN: Well, and I was looking at it
4 too, as you brought up the question earlier. They can
5 be separated in time and I think that's why there are
6 two of them.

7 The first one, and I'm sorry, I don't have
8 this on a slide, the first one that MHI had showed had
9 a reference to the integrated system validation, which
10 is the testing.

11 It's controlled by one of the
12 implementation plans, where they would take the final
13 design and the simulator and run it through a bunch of
14 scenarios, to make sure that the operators can do the
15 things that they claim that they can do.

16 So, the first one references the
17 integrated system validation. So, they're looking to
18 make sure that those results are adequate and that
19 those tests are run appropriately.

20 The second one is based on design
21 implementation, and this is focused more on the as-
22 built design, so that, in the case that there is some
23 distance in time between an integrated system
24 validation is run and when the as-built is done, the
25 design implementation implementation plan -- I

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 apologize for the clumsy terminologies, it's really
2 difficult to say implementation twice in a row --

3 CHAIR SUNSERI: That's all right.

4 DR. GREEN: -- but that's what it's
5 called. It basically is a check to make sure that the
6 assumptions that you validated in the ISV remain true
7 at the as-built.

8 So, let's say the design looks one way on
9 paper, when they put it in the simulator and then,
10 they run the tests and everything looks good. And
11 then, you get into the building and something needs to
12 change.

13 The DIIP, or design implementation
14 implementation plan, the second ITAAC, is a
15 reconciliation to make sure that they go back to the
16 ISV, make sure that those assumptions remain true, and
17 if they don't, then maybe a design change is warranted
18 or additional testing.

19 So, that's why there are two that look
20 kind of similar, it's to address that potential impact
21 in time.

22 CHAIR SUNSERI: I mean, I was just
23 thinking a bit more simplistically, like you buy a
24 digital system or whatever and there's usually a
25 factory acceptance test and a site acceptance test.

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 And that's -- I was kind of equating those two ITAACs
2 as a similar kind of thing, but you described it very
3 well though, I think it's different in my mind.

4 DR. GREEN: Yes, they look kind of similar
5 in the wording, the ITAAC wording is always a bit of
6 -- it's a very specific thing. And I agree, it looked
7 a little -- I could see why you had the question you
8 have.

9 CHAIR SUNSERI: Okay.

10 DR. GREEN: But the intent behind them is
11 different.

12 CHAIR SUNSERI: Okay, thanks. That clears
13 it up for me.

14 MEMBER REMPE: So, I have a question that
15 I raised with the Applicant that I'd like to discuss
16 with you, too, about the fact that they have the
17 procedures -- and maybe this comes under Chapter 13
18 and your statement about state of the art human factor
19 principles, and thinking about the follow-up about
20 what's happened with the severe accident management
21 guidelines, as well as some of the accident management
22 procedures.

23 The fact that there's not an owners group
24 membership with MHI, and maybe this comes up solely
25 with the applicant, but where they have developed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 procedures to pass off to the applicant already, that
2 I guess you've reviewed, right?

3 DR. GREEN: I'm not sure specifically what
4 the staff reviewed, I'd have to go look back into
5 that. But there is not a requirement for them to have
6 the procedures done at the time of the design
7 certification.

8 MEMBER REMPE: And some people do pass it
9 off to the applicant, but it almost --

10 DR. GREEN: Right.

11 MEMBER REMPE: -- sounded like, from what
12 I read in this chapter, that they had done a lot of
13 their procedures. They explicitly stated it in
14 Chapter 18.

15 DR. GREEN: Yes, I'd have to go back and
16 look at it. I mean, my understand was that during the
17 Phase 1a, the Americanization, that there was some
18 consideration of that done. I wasn't part of that
19 team, so I'm not sure to what degree that is complete.

20 MEMBER REMPE: They split the load for the
21 operators, they mentioned too.

22 DR. GREEN: Yes. So, part of Chapter 13,
23 at a COL stage is where they would look at final
24 procedures. So, we're looking at, in Chapter 18
25 space, it's more of a preliminary set, that may

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 change. And then, there are validation processes for
2 those down the line.

3 MEMBER REMPE: And would the staff not be
4 a bit concerned that they don't have any membership in
5 an owners group? And I mean, the reactor oversight
6 process is where one would be reviewing the severe
7 accident management guidance. Is there a way to
8 encourage the applicant to belong to an owners group
9 of some sort?

10 DR. GREEN: I don't know of one, I mean,
11 I think there would be benefit to it, I don't know
12 that there's a means to force them to join one. But
13 I don't --

14 MEMBER REMPE: If there's no --

15 DR. GREEN: -- a lot about that.

16 MEMBER REMPE: Yes, I guess you'll get it
17 with the ROP then, is how you would deal with it. I
18 just was curious on the process.

19 DR. GREEN: I'm unsure how to -- of the
20 full answer to that.

21 MEMBER REMPE: Okay, thanks.

22 CHAIR SUNSERI: Any other member
23 questions? All right. So, thank you, Dr. Green, for
24 the presentation, very helpful. And we have no other
25 questions. So, at this point in time, I'd like to

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 turn to the public.

2 So, first, we'll ask the members of the
3 public in the room for comments and then, we'll turn
4 to the phone line. And while we're doing this, I'll
5 ask for the phone line to be open.

6 So, for members of the public in the room,
7 if you want to make a statement, please come up to the
8 microphone, state your name and make your statement.
9 All right. There are none. So, now, we will turn to
10 the public phone line.

11 If somebody is on the public phone line,
12 could you just speak up, say you're here, just so we
13 know the line is open. Once we confirm the line is
14 open, we'll ask for comments. Anybody on the public
15 line?

16 So, I will just go ahead and assume it's
17 open and ask for comments. Any comments on the public
18 line? Okay. We're going to close the public line.
19 And with no other questions, we've completed the
20 agenda now through the opportunity for public
21 comments.

22 What we're going to do is take a break for
23 lunch. We're going to resume at 1:00 and we will
24 start with the advance accumulator. Applicant will go
25 first and then, the staff. And those will be a closed

NEAL R. GROSS

COURT REPORTERS AND TRANSCRIBERS
1323 RHODE ISLAND AVE., N.W.
WASHINGTON, D.C. 20005-3701

1 session, due to protection of proprietary information.

2 All right. We are recessed until 1:00.

3 (Whereupon, the above-entitled matter went
4 off the record at 12:03 p.m.)

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

US-APWR

Design Overview

September 19, 2019

Mitsubishi Heavy Industries, Ltd.

Presenters



Atsushi Kumaki

MHI NS Engineering Co, Ltd.

Joseph Tapia

Mitsubishi Nuclear Energy Systems, Inc.

UAP-HF-19001-1

Contents

- 1. Introduction and Objectives**
- 2. US-APWR Design Overview**
 - Main Features of US-APWR**
 - US-APWR Design Features**
- 3. Future Plan**


- **The US-APWR Design Certification (DC) application was submitted in December 2007.**
- **The safety review by NRC has progressed, and several ACRS meetings have been held in the past.**
- **After Fukushima in 2011, MHI has concentrated the resources to support domestic plant restarts and the slowdown of US-APWR DC activities is still needed.**

Today's Meeting Objectives



- **To provide the current ACRS with US-APWR design overview**
- **To provide the ACRS with details on;**
 - **Chapter 18 (Human Factor Engineering),**
 - **Chapter 8 (Electrical System) and the**
 - **Topical Report for the Advanced Accumulator**

US-APWR Design Overview



UAP-HF-19001-5

Main Features of US- APWR

Progression of Mitsubishi PWR Designs



Number of Loops	Output of Electric Power	Reactor Vessel	Number of Fuel Assembly	Steam Generator/ Reactor Coolant Pump	Reference Plant
2 Loop	600 MWe Class	I.D. 11.15 ft (3.4 m)	121 Assemblies	Standard	Tomari Units 1 & 2 (Commercial Operation : 6/1989 & 4/1991)
3 Loop	900 MWe Class	I.D. 13.12 ft (4.0 m)	157 Assemblies	Standard	Tomari Unit 3 (Commercial Operation : 12/2009)
4 Loop	1200 MWe Class	I.D. 14.44 ft (4.4 m)	193 Assemblies	Standard	Genkai Units 3 & 4 (Commercial Operation : 3/1994& 7/1997)
4 Loop (APWR)	1500 MWe Class	I.D. 17.06 ft (5.2 m)	257 Assemblies	Larger Capacity with the same concept	Tsuruga Units 3 & 4 (Under licensing)

UAP-HF-19001-7

US-APWR Design Basis

- **Basic design concept of US-APWR is the same as APWR**
- **New technologies of APWR are fully tested, well-verified and established**
- **US-APWR, 1700MWe class, is based on the established APWR technology with**
 - ✓ **Latest technologies to improve plant efficiency**
 - ✓ **Minor modifications to meet U.S. Regulatory and utility requirements**

Comparison of Main Features

Plant Parameters and Major components

		Conventional 4 Loop	APWR	US-APWR
Electric Output		1,180 MWe	1,538 MWe	1,700 MWe Class
Core Thermal Output		3,411MWt	4,451 MWt	4,451 MWt
Steam Generator	Model	54F	70F-1	91TT-1
	Tube size	7/8"	3/4"	3/4"
Reactor Coolant Pump	Design Flow	93,600gpm	112,000gpm	112,000gpm
Turbine	LP last-stage blade	44 inch	54 inch	70 inch class

➤ APWR

- ✓ 1538MWe output is achieved by large capacity core and large capacity main components such as SG, RCP, turbine, etc.

➤ US-APWR

- ✓ 1700MWe class output is achieved from a 10% higher efficiency than APWR.
 - Same core thermal output with APWR
 - High-performance, large capacity steam generator
 - High-performance turbine

UAP-HF-19001-9

Comparison of Main Features

Reactor Core and Internals

		Conventional 4 Loop	APWR	US-APWR
Core Thermal Output		3,411MWt	4,451 MWt	4,451 MWt
Core and Fuel	NO. of Fuel Assem.	193	257	257
	Fuel Lattice	17 × 17	17 × 17	17 × 17
	Active Fuel Length	12ft	12ft	14 ft
Reactor internals		Baffle/former structure	Neutron Reflector	Neutron Reflector
In-core Instrumentation		Bottom mounted	Bottom mounted	Top mounted

➤ APWR

- ✓ Large capacity core by increasing number of fuel assemblies
- ✓ Installation of neutron reflector to enhance reliability and fuel economy

➤ US-APWR

- ✓ Low power density core using 14ft. fuel assemblies to enhance fuel economy for 24 months operation
- ✓ Enhanced reliability and maintainability of reactor vessel by top mounted ICIS

UAP-HF-19001-10

Comparison of Main Features

Safety system and I&C

			Conventional 4 Loop	APWR	US-APWR
Safety Systems	Trains	Electrical	2 trains	2 trains	4 trains
		Mechanical	2 trains	4 trains	4 trains
	Systems	HHSI pump	100% × 2	50% × 4(DVI)	50% × 4(DVI)
		LHSI pump	100% × 2	-	-
		ACC	4	4 (Advanced)	4 (Advanced)
	RWSP		Outside CV	Inside CV	Inside CV
Containment Vessel			PCCV	PCCV	PCCV
I & C	Control Room		Conventional	Full Digital	Full Digital
	Safety I&C		Conventional		
	Non-Safety I&C		Full Digital		

➤ APWR

- ✓ Enhanced safety by simplified and reliable safety systems
 - Mechanical 4 train systems with direct vessel injection design
 - Elimination of LHSI pump by utilizing advanced accumulators
 - Elimination of recirculation switching by In-containment RWSP

➤ US-APWR

- ✓ Enhanced safety by 4 train safety electrical systems
- ✓ Enhanced on line maintenance capability

UAP-HF-19001-11

➤ Enhanced Economy

- ✓ Large capacity and high plant performance
- ✓ High fuel performance for 24 months operation

➤ Enhanced Safety

- ✓ Improved safety response by using advanced technologies


➤ Enhanced Reliability

- ✓ Well designed and verified proven technologies

US-APWR Design Features

Advanced Technologies

Reactor



- ◆ 1700 MWe class large capacity
- ◆ Neutron reflector

Steam Generator




- ◆ High performance separator
- ◆ Increased capacity with compact sizing

I & C

- ◆ Digital control & protection systems
- ◆ Compact console



Engineering Safety Features



- ◆ Simplified configuration with 4 mechanical sub-systems
- ◆ In-containment RWSP
- ◆ Advanced accumulator

Turbine


- ◆ 74 inch-length blades in LP turbine
- ◆ Fully integrated LP turbine rotor



UAP-HF-19001-14


Nuclear Design Features

➤ Large thermal output and low power density



Improved Core Design

Neutron Reflector Saves Uranium



UAP-HF-19001-16

Fuel Design Features

Enable Flexible Core Operation

Fuel Active Length : 14ft
Fuel Rods Array : 17x17

Higher Gadolinium
Content Pellet (10wt%)

Enhance Fuel Economy

Higher Density Pellet
(97%T.D.*1)



Zircaloy-4 Grid
(for Neutron Economy)

High Reliability

Grid Fretting
Resistant Design
(Shorter Span Length*2
with 11 grids & Grid Spring
Design)

Corrosion Resistant Cladding
Material (ZIRLO™)

Anti-debris bottom nozzle
with built-in filter




*1 T.D. : Theoretical Density

*2 compared with conventional 14ft Fuel

UAP-HF-19001-17

Reactor Internals Design

Comparison of main structures



UAP-HF-19001-18

Reactor Internals Design

Large volumetric core structure

Large reactor internals for large output


Enhanced reliability

Neutron Reflector for simplified structure
(Number of bolts :
2,000 → 50)

Improved Tie Plate for stabilized flow

Enhanced performance


Neutron Reflector for fuel cost reduction



Reactor Coolant System

➤ Design concept of the RCS

- ✓ Basic configuration is the same as conventional 4 loop plants
- ✓ Large main components with large thermal output and high efficiency
- ✓ Enhanced plant response and controllability with large volume Pressurizer



Reactor Coolant System

➤ Larger main components

- ✓ Larger diameter and height of Reactor Vessel with enhanced reliability
- ✓ Larger heat transfer area in SG contributes high efficiency
- ✓ Larger reactor coolant flow rate of RCP with 8000 HP motor

➤ Enhanced plant response and control

- ✓ Larger Pressurizer volume provides greater margin for the transients

Specifications	US-APWR	Conventional 4 Loop Plant	Ratio
Core thermal output	4,451MWt	3,565MWt	1.25
SG Heat transfer area	91,500ft ²	55,000ft ²	1.66
Reactor Coolant Flow	112,000gpm	93,600gpm	1.20
Pressurizer Volume	2,900ft ³	1,800ft ³	1.61

Reactor Vessel / CRDM

Enhanced reliability


Reactor Vessel

Vessel head
nozzle material:
Alloy 690

Vessel head
plenum
temperature:
Tcold


Reactor
Vessel:
**Reduction
of weld
lines using
integrated
forging**

Neutron
reflector:
**Reduction
of Vessel
fluence
(Reduce to 1/3)**



CRDM housing

Elimination of canopy seal



Canopy seal
for Latest 4 Loop
plant

US-APWR

UAP-HF-19001-22

Steam Generator

Design Features


➤ Primary separator

- ✓ High performance moisture separation
Moisture carry over at SG outlet:
less than 0.1%

➤ Anti-vibration Bar

- ✓ Sets of 5 V-shaped AVBs with 10 support points of the outer most tube

Tube material	Alloy 690
Tube OD	0.75 inch
Tube arrangement	triangular
Tube pitch	1 inch
Heating surface	91,500 ft ²



UAP-HF-19001-23

Reactor Coolant Pump


➤ Improved hydraulic performance

✓ Large capacity and high efficiency by improved impeller and diffuser

- Pump Efficiency : Over 85%
- Flow Rate : 112,000 gpm/loop
- Head : Approx. 310 ft

➤ Advanced seal

- ✓ Stabilization of No.1 seal leak-off characteristics
- ✓ Extension of seal life
- ✓ Countermeasure to station-blackout



UAP-HF-19001-24

Safety Systems

➤ Simplified and Reliable Safety Systems

- ✓ Safety systems with enhanced redundancy and independency
- ✓ Reliable and simplified design is achievable by 50% × 4 configuration for Safety Injection (HHSI*) Pumps in conjunction with adoption of Direct Vessel Injection (DVI) design

* : High Head Safety Injection

➤ Utilization of Advanced Accumulators


- ✓ Accumulators with function of Low Head Injection Pumps

➤ In-Containment Refueling Water Storage Pit

- ✓ Improved reliability and safety by eliminating recirculation switching


ECCS Configuration

Conventional 4 Loop PWR (2 train)



US-APWR (4 mechanical train)

- ◆ 4 train (DVI)
 - Higher Reliability
 - Simplified Pipe Routing
- ◆ Advanced Accumulator
 - Elimination of LP
- ◆ In-containment RWSP
 - Higher Reliability



ACC : Accumulator
HP : High Head SIP
LP : Low Head SIP
SIP : Safety Injection Pump
CSP : Containment Spray Pump
SH : Spray Header
RV : Reactor Vessel
RWSP : Refueling Water Storage Pit


UAP-HF-19001-26

Comparison of ECCS Equipment

	Conventional 4 Loop Plant	US-APWR
Accumulator	4 (conventional type)	4 (advanced type)
SI Pump - High Head Pump - Low Head Pump	100% × 2 100% × 2 (used also as RHR)	50% × 4 —
CS Pump	100% × 2	50% × 4 (used also as RHR)

Design feature of high head injection system


- **4 independent trains without interconnections between trains**
- **Sufficient capacity of safety injection pumps**
 - ✓ Meets the safety injection requirement in core reflooding stage



Item	US-APWR	Conventional 4 Loop Plant	Reason and/or Advantage
Train	4 train	2 train	<ul style="list-style-type: none"> • Enhance the reliability • Provide On-line Maintenance under single failure
High head Injection	DVI 4 SIP	Loop injection 2 SIP + 2 Charging/SIP	<ul style="list-style-type: none"> • No interconnection between trains
Refueling Water Storage Pit	Inside CV	Outside CV	<ul style="list-style-type: none"> • Eliminate recirculation switchover

Design Feature of CSS/RHRS



- Common CSS and RHRS Pumps / Heat exchangers
- CSS and RHRS are not required for operation at same time
 - ✓ Normal operation: Stand by as CSS
 - ✓ LOCA: Operated as CSS
 - ✓ Plant shut down: Operated as RHRS
 - ✓ Pump suction and discharge valves are interlocked for prevention of human errors



Item	US-APWR	Conventional 4 Loop Plant	Reason and/or Advantage
Containment Spray	4 CS/RHRP 4 CS/RHR Hx	2 CSP 2 CS Hx	<ul style="list-style-type: none"> • Enhance the reliability • Achieve OLM under single failure
Residual Heat Removal	Integrated to CSS	Integrated to LHSIS 2 RHRP 2 RHR Hx	<ul style="list-style-type: none"> • Simplify safety system configurations

In-containment Refueling Water Storage Pit

- ✓ Located at the lowest part of containment
- ✓ Provides a continuous suction source for both the safety injection and the CS/RHR pumps (Eliminates the switchover of suction source)
- ✓ 4 recirculation sumps are installed





UAP-HF-19001-30

Containment Vessel Design

➤ Robust and reliable pressure vessel with steel liner


Design Pressure	68 psig
Maximum Allowable Leakage Rate	0.1 percent / day



UAP-HF-19001-31

Simplified Layout for Safety Systems

- Lay down safety equipment at corner area of reactor building just close to RCS loops
 - ⇒ Building volume / piping quantity is reduced
- Building volume (per kW) was reduced about 20% in US-APWR by total plant effective layout



UAP-HF-19001-32

Advanced Accumulator


➤ Automatic Switching of Injection Flow Rates

➤ Elimination of Low Head Injection Pumps


- ✓ Improvement of reliability
- ✓ Reduction of total capacity of safety injection pumps
- ✓ Substitution for RHR function by CS* Pumps/Coolers

* : Containment Spray

Current 4 Loop plant




US-APWR



UAP-HF-19001-33

Mechanism of Advanced Accumulator

Flow damper passively switches the flow rate.



Large Flow Rate

Reduced Flow Rate

UAP-HF-19001-34


Emergency Feedwater System

➤ Design concept of the EFWS

- ✓ Achieve high reliability with simplified systems
- ✓ Allow On-Line Maintenance assuming single failure

➤ Feature of the EFWS

- ✓ Independent 4 train system
- ✓ 2 safety grade water sources
- ✓ Diverse power sources for the pumps
- ✓ Cross connection inlet and outlet of the pumps (normally isolated)



UAP-HF-19001-35

Emergency Feedwater System

- **4 train configuration allows simplicity and high reliability**
 - ✓ 4 pumps with diverse power sources
 - 2 motor-driven pumps
 - 2 turbine-driven pumps
 - ✓ Cross connection inlet of the pumps allows On-Line Maintenance (OLM)
- **2 safety grade independent feedwater sources**
 - ✓ Two 50% capacity emergency feedwater pits
 - ✓ Cross connection inlet of the pumps backs up each feedwater source

Item	US-APWR	Conventional 4 Loop Plant	Reason and/or Advantage
System Configuration	4 train	2 train	A pump is allowed OLM under the single failure
Emergency Feedwater Pump	M/D EFWP: 2 T/D EFWP: 2	M/D EFWP: 2 T/D EFWP: 1	Diverse power sources
Emergency Feedwater Source	2	1	2 independent pits (backup available)

UAP-HF-19001-36

CCWS & ESWS



(Component Cooling Water System & Essential Service Water System)

➤ Design concept


- ✓ CCWS and ESWS constitute a safety cooling chain
- ✓ Achieve high independency and high reliability
- ✓ Allows On-Line Maintenance assuming single failure

Component Cooling Water System

➤ Component Cooling Water System

- ✓ 4 safety train configuration
- ✓ Separated into 2 independent sections even in normal operation

- OLM available in each train
- 2 train safety components (e.g.; SFP Hx.) are supplied with cooling water from 2 of 4 safety trains




UAP-HF-19001-38

Essential Service Water System

➤ Essential Service Water System

✓ Independent 4 train configuration



UAP-HF-19001-39

I&C Main Features

➤ Full Digital I&C System

- ✓ Computerized main control board
- ✓ Minimal conventional switches, only for regulatory compliance
- ✓ Micro-processor based safety and non-safety systems
- ✓ Multiplexed communication including class 1E signals


➤ Based on Defense-in-Depth & Diversity concept

➤ 4 train redundant Safety System configuration

➤ Redundant configuration for Non-Safety Systems

➤ Maximum standardization with diverse back-up Non-Safety System for CCF (Common Cause Failure)

I&C Overall Architecture



DAS : Diverse Actuation System PSMS : Protection and Safety Monitoring System HSI : Human System Interface System PCMS : Plant Control and Monitoring System

Safety I&C Design Features



- **PSMS: Protection & Safety Monitoring System**
 - ✓ Reactor Trip and ESF Actuation Functions
 - ✓ Monitoring of the Safety Critical Parameters (RG 1.97)
 - ✓ Control of ESF, Safe Shutdown and Important Interlocks
- **4 train redundancy for all Safety Systems**
- **Electrical, physical, functional, communication and data isolation to accommodate**
 - ✓ Signal interface between safety systems
 - ✓ Signal interface safety to non-safety systems
 - ✓ Non-safety HSI for safety functions with safety HSI
- **Integrity of software per BTP 7-14 and BTP 7-19**
- **Qualified platform with extensive experience**

UAP-HF-19001-42

Non-safety I&C Design Features MITSUBISHI HEAVY INDUSTRIES, LTD.

➤ PCMS: Plant Control and Monitoring System

- ✓ Reactor, Turbine / Generator, BOP control & monitoring
- ✓ Redundant and fault tolerant configuration
- ✓ Functional isolation of shared sensor signals from PSMS with Automatic Signal Selector
(for compliance with 10CFR 50 Appendix A GDC 24)


➤ DAS: Diverse Actuation System

- ✓ Countermeasure for CCF in the digital safety system
(according to BTP 7-19 for Software CMF & 10CFR 50.62 for ATWS)
- ✓ Diverse automation: Reactor Trip, Turbine Trip, EFWS
(based on actuations required within 10 minutes of event)
- ✓ Diverse manual controls: SI, CV Isolation, etc.
(diverse component level actuation for critical safety functions)
- ✓ Diverse monitoring: Safety critical parameters
(diverse signal processing and HSI)

UAP-HF-19001-43

HSI System

Computerized Main Control Room



UAP-HF-19001-44

HSI System Design Features



- **Functions of HSI System (Human System Interface System)**
 - ✓ Fully computerized video based approach
 - ✓ Integrated display for monitoring and soft control
 - ✓ Dynamic alarm prioritization & computerized procedures
- **Development Process (NUREG 0711 Program Model)**
 - ✓ Task analysis and human factor design
 - ✓ Step by step prototyping and V&V by plant operators
- **Staffing**
 - ✓ Operator, Supervisor & Safety Technical Advisor
- **Main features**
 - ✓ All operations are available from non-safety VDUs
 - ✓ All safety operations from safety VDUs
 - ✓ Minimum inventory of Fixed Position HSI
 - Conventional HSI for manual system level actuation (RG 1.62)
 - Critical Functions & Bypass or Inoperable Status (RG 1.47)

UAP-HF-19001-45


Electrical System Design Features MITSUBISHI HEAVY INDUSTRIES, LTD.

- **2 independent offsite transmission systems**
- **4 train onsite Safety Power Systems**
- **4 train Safety Gas-Turbine Generators (GT/G)**
 - ✓ Starting time requirement is extended with GT/G
 - ✓ Higher reliability and easier maintenance than DG
- **4 train Safety Batteries**
 - ✓ 2 hours capability for loss of AC power
 - ✓ Supplies power to equipment that must be energized prior to starting time requirement of GT/G
- **One non-safety GT/G alternate AC power**
 - ✓ Supplies power to equipment required during SBO
 - ✓ Starting time requirement : 5 minutes
 - ✓ Manually connected to safety bus at SBO initiation

UAP-HF-19001-46

Electrical System Diagram

Safety Electrical



US-APWR Overview

- **US-APWR is designed on proven and reliable technologies and provides:**
 - ✓ **Improved plant efficiency incorporating improved steam generators and turbine system**
 - ✓ **Reduced fuel cycle cost and improved operational flexibilities by low power density core with 14 ft. fuel assemblies.**
 - ✓ **Minor modifications of APWR for U.S. utility requirements.**

MOVE THE WORLD FORWARD

**MITSUBISHI
HEAVY
INDUSTRIES
GROUP**

US-APWR

Design Certification Application

Tier 2: Chapter 8

September 19, 2019

Mitsubishi Heavy Industries, Ltd.

Joseph Tapia

Mitsubishi Nuclear Energy Systems, Inc.

Hideki Tanaka

Mitsubishi Heavy Industries, LTD.

Shinji Kawanago

MHI NS engineering Co, Ltd.



- 1. Overview of Chapter**
- 2. Features of Electrical Power System**
- 3. Closed Open Items and RAIs**
- 4. Summary**

1. Overview of Chapter



1. Overview of Chapter

➤ **Title of Chapter**

Chapter 8: Electric Power

➤ **Scope of Chapter**

According to RG 1.206 and SRP, Chapter 8 consists of following subsections:

8.1 Introduction

8.2 Offsite Power System

8.3 Onsite Power Systems

8.3.1 AC Power Systems

8.3.2 DC Power Systems

8.4 Station Blackout

1. Overview of Chapter

DCD

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
1	-	4	DCD	-	Aug. 30, 2013	UAP-HF-13212
2	-	0	DCD Revision 4 Update Tracking Report	-	Mar. 14, 2014	UAP-HF-14025

Technical Reports

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
3	MUAP-09023	1	Onsite AC Power System Calculation	Aug. 2013	Sep. 3, 2013	UAP-HF-13221
4	MUAP-07024	3	Qualification and Test Plan of Class 1E Gas Turbine Generator System	Sep. 2012	Sep. 28, 2012	UAP-HF-12270
5	MUAP-10023	7	Initial Type Test Result of Class 1E Gas Turbine Generator System	Dec. 2013	Dec. 18, 2013	UAP-HF-13311

2. Features of Electrical Power System



Offsite Power System (8.2)

➤ Design Features

- ✓ The two (2) sources of offsite power provide:
 - 1.) Normal Preferred Power from Reserve Auxiliary Transformers (RAT)
 - 2.) Alternate Preferred Power from Unit Auxiliary Transformers (UAT) thru Main Transformer
- ✓ The two (2) offsite power supply circuits are independent and physically separated.
- ✓ Either offsite power supply circuit has the capacity for normal operations and Design Basis Events (DBE) to comply with the applicable GDC's.

2. Features of Electrical Power System




Figure-1 Main One-Line Overview



Offsite Power System (8.2)

- **Closed Open Items and RAIs (discussed later in detail)**
 - ✓ ***RAI on 8.2 “Bulletin 2012-01”***
Protection against OPC (Open Phase Condition)

Onsite Power System (8.3)

➤ Design Features

- ✓ Four train Class 1E AC electrical power systems
- ✓ Each train includes an independent Class 1E GTG as its emergency power source
- ✓ On-Line Maintenance with Single-Failure Criterion remains satisfied
- ✓ “Permanent” buses supplied from Alternate AC Power Source (AAC-GTG)
- ✓ Non-safety related loads are electrically separated from class 1E buses.
- ✓ Required non-safety related loads are supplied from AAC during LOOP
- ✓ AACs provide power to all SBO required loads to bring and maintain the unit in safe-shutdown.

2. Features of Electrical Power System




Figure-1 Main One-Line Overview

2. Features of Electrical Power System

Class 1E Gas Turbine Generator Specifications/Ratings

- **Gas Turbine Ratings**
 - ✓ Continuous Rating: 4500 kW
 - ✓ Short time Rating : 4950 kW

- **Generator Ratings**
 - ✓ Continuous Rating: 4500 kW / 5625 kVA
 - ✓ Power Factor of 0.8
 - ✓ 6900 Volt; 3 Phase, 60 hertz

- **Start time**
 - ✓ < 100 Seconds start time

Class 1E GTG Testing Program

- **Regulatory guide 1.9**
 - ✓ Application and Testing of Safety-related Diesel Generators in Nuclear Power Plants

- **IEEE 387**
 - ✓ IEEE Standard Criteria for diesel Generator Units Applied as Standby Power Supplies for Nuclear Power Generating Stations.

- **ISG-21 (Draft)**
 - ✓ Interim Staff Guidance On the Review of Nuclear Power Plant Designs using a Gas Turbine Driven Standby Emergency Alternating Current Power System

- **MHI Technical Report**
(Qualification Test Plan and Initial Type Test Result)
 - ✓ Qualification and Test Plan for Class 1E Gas Turbine Generator System : MUAP-07024
 - ✓ Initial Type Test Result of Class 1E Gas Turbine Generator System : MUAP-10023

Class 1E GTG Initial Type Tests

➤ Load Capability Test

- ✓ IEEE 387 6.2.1
- ✓ To demonstrate the capability to carry rated load

➤ Start and Load Acceptance Test

- ✓ IEEE 387 6.2.2
- ✓ To establish the capability to start and accept load within the required time period.
- ✓ 150 Start Tests

➤ Margin Test

- ✓ IEEE 387 6.2.3
- ✓ To demonstrate the capability to carry the most severe load step + 10%

- **Closed Open Items and RAIs (discussed later in detail)**
 - ✓ ***Open Item 08.03.01-1 :
Maintenance and Testing of Inaccessible Cables***
 - ✓ ***Open Item 08.03.01-2 :
Gas Turbine Generator Reliability (GTG)***
 - ✓ ***Open Item 08.03.02-1 :
Battery Sizing Calculations***
 - ✓ ***RAI on 8.3.1.4.4.2 “Conformance with RG 1.9”
GTG’s qualification test which was stopped every 50
starts to perform maintenance***

Station Blackout (8.4)

- **Basic Concept for Coping with SBO**
 - ✓ The AACs are available in the event of SBO, when all offsite power sources and EPS's are not available to bring the unit to a safe shutdown condition and maintain that status

- **Design Basis**
 - ✓ Diverse AACs to minimize the potential for common cause failures between EPS system
 - ✓ The non-class 1E AAC is a packaged gas turbine-generator connected to a 6.9kV AC “Permanent” bus
 - ✓ AAC can be aligned to any of the 4 class 1E buses in response to an SBO
 - ✓ AAC supplies safe shutdown loads during the SBO coping period (8 hours)

- **Closed Open Items and RAIs for Section 8.4
(discussed later in detail)**
 - ✓ ***Open Item 08.04-1 :
RCP Seal Leakage Rate***
 - ✓ ***Open Item 08.04-2 :
AAC Power System Periodic Testing***
 - ✓ ***RAI on 8.4.4.3 “Station Blackout Coping Analysis”
(Effects of Loss of Ventilation)***

***Justification of stable operation of the TDEFW
pumps for one hour without room cooling***

3. Closed Open Items and RAIs

3. Closed Open Items and RAIs

RAI on 8.2 “Bulletin 2012-01”

RAI 1017-7058, Question 08.02-17

RAI 1096-8266, Question 08.02-18

RAI 1100-9574, Question 08.02-19

Protection against OPC (Open Phase Condition) (Bulletin 2012-01)

- Concerning Bulletin 2012-01, “Design Vulnerability in Electric Power system,” (ADAMS ML 12074A115) related to the recent operating experience that involved the loss of one of the three phases of the offsite power circuit (single-phase open circuit condition) at Byron Station
 - (1) Detection and Protection Method
 - (2) Single Failure Criteria
 - (3) COL and ITAAC

Response to NRC RAI

US-APWR DCD Section 8.2, ITAAC and COL Item were revised.

More detail design information is as follows;

3. Closed Open Items and RAIs



➤ MHI Response

(1) Detection and Protection Method

OPC detection systems are provided on the high voltage side MT and RAT.

(2) Single Failure Criteria

OPC detection system has redundancy.



3. Closed Open Items and RAIs

(3) COL Item and ITAAC

- ✓ COL items on detail designs and surveillance requirement were added DCD section 8.2.

COL 8.2(12)	Deleted <u>The COL applicant is to determine the specific type of the OPC detection devices which properly address and meet the requirements of B.1. & B.2. of BTP 8-9, taking into account the site-specific design configuration, installation condition, (field) performance testing and qualification status, and operation experiences of the OPC Detection and Protection system. The COL applicant is also to provide the detailed design of the OPC Detection and Protection system for the COL applicant site.</u> <u>The COL applicant is to perform a field simulation on the site-specific design of the offsite power system to ensure that the settings of the OPC Detection and Protection system are adequate and appropriate for the COL applicant site.</u>
<u>COL 8.2(13)</u>	<u>The COL Applicant is to provide surveillance requirements for the device(s) used to detect open phase condition on the high voltage side of the RATs and MT, with or without grounding.</u>

- ✓ One ITTAC was added Tier 1 of DCD.

Table 2.6.1-3 AC Electric Power Systems Inspections, Tests, Analyses, and Acceptance Criteria (Sheet 8 of 8)

Design Commitment	Inspection, Test, Analyses	Acceptance Criteria
28 The Class 1E equipment is protected from open phase conditions with monitoring, detecting and alarming in the main control room.	28.i Analysis will be performed verify the Class 1E equipment is protected from open phase condition.	28.i A report exists and concludes that the Class 1 E equipment is protected from open phase condition by open phase protection system.
	28.ii Inspection and test will be performed to verify the as-built protection system bounds the result of analysis for Class 1E equipment protection from open phase condition and to verify that open phase condition will be monitored, detected and alarmed in the main control room.	28.ii The as-built protection system bounds the result of analysis for Class 1E equipment protection from open phase condition. The as-built detection system design monitors, detects and alarms in the main control room.

3. Closed Open Items and RAIs

Open Item 08.03.01-1

Maintenance and Testing of Inaccessible Cables

- Generic Letter 2007-01 guidance on preventing the degradation of medium voltage cables that are installed in underground duct bank.
- The applicant has not provided a COL Information Item for this.

Response to NRC RAI NO.10

REVISION 4

US-APWR DCD Section 8.3.3 and Subsection 8.3.1.1.9 were modified to include COL Information Item; "The COL Applicant is to describe the cable monitoring program for underground and inaccessible cables within the scope of the maintenance rule."

3. Closed Open Items and RAIs

Open Item 08.03.01-2

Gas Turbine Generator Reliability (GTG)

- Technical Report MUAP-07024-P, Rev. 2, provides technical information about the GTG and their qualification plan, but does not provide type test data that supports reliability target.

Response to NRC RAI No.394-3048

MHI has developed one technical report “Initial Type Test Result of Class 1E Gas Turbine Generator System” (MUAP-10023).

MHI performed 150 start and load acceptance tests of the GTGs with zero failures. These tests prove that the GTGs satisfy the reliability criterion of 0.975 with 95 percent confidence.

3. Closed Open Items and RAIs

RAI on 8.3.1.4.4.2 “Conformance with RG 1.9”

RAI 818-5872, Question 08.03.01-42

RAI 876-6210, Question 08.03.01-43

RAI 962-6578, Question 08.03.01-46

- The qualification testing was stopped every 50 starts to perform maintenance on the injectors, but this information was not provided in the submitted technical reports (MUAP-07024-P (R2), MUAP-10023-P (R3)) and Technical Specifications.
- The applicant to provide information to support that the scheduled maintenance activity conducted, the fuel nozzle cleaning, was part of the test procedures.

Response to NRC RAI

US-APWR DCD Section 8.3.1.1.3.9 and Technical Specification Surveillance Requirement (SR) were revised to perform fuel nozzle cleaning as a maintenance activity. MUAP-07024-P and MUAP-10023-P were revised to include a summary of the fuel nozzle cleaning procedure and parameters monitored during the qualification testing.

3. Closed Open Items and RAIs

Open Item 08.03.02-1

Battery Sizing Calculations

- The applicant indicated that its assumptions for the types of loads were made based on Japanese experience and products.
- The applicant agreed to provide a more in-depth explanation of this issue which will be incorporated in the upcoming DCD revisions

Response to NRC RAI No.388-2858

MHI provided detailed information regarding current for loads included in the battery sizing calculations. The calculations factored US manufacturers' information and differences from the Japanese manufacturers.
US-APWR DCD Table 8.3.2.1 was revised.

Open Item 08.04-1

RCP Seal Leakage Rate

- The applicant has stated that : The leakage of reactor coolant through the seals of each RCP is assumed to be 0.2 gpm. Therefore, the total loss of coolant inventory within 1 hour from the seals on all four RCPs is expected to be 48 gallons.
- The applicant needs to justify the deviation from industry standards for its RCP design by actual test results or demonstrate that the design can cope with the higher leakage rate.

Response to NRC RAI No.419-3126

MHI answered that the isolation valve stops the leakage in No. 1 seal and the leakage from the No. 2 seal is limited.

3. Closed Open Items and RAIs

Open Item 08.04-2

AAC Power System Periodic Testing

- The applicant's DCD states that the AAC power system will be inspected and tested periodically to demonstrate operability and reliability.
- The inspection and testing will be conducted by the COL applicant over the lifetime of the NPP, therefore, the DCD should include these inspection and testing requirements as a COL Information Item.

Response to NRC RAI No.683-5251

During the quarterly surveillance test, the AAC is started and brought to operating conditions. Additionally, during every refueling outage, the AAC generator is tested by performing a timed start and rated load capacity test. Testing and maintenance of the AAC is evaluated under the reliability assurance program and the maintenance rule program as described in the DCD.

3. Closed Open Items and RAIs

RAI on 8.4.4.3 “Station Blackout Coping Analysis”

RAI 938-6535, Question 08.04-16
RAI 991-7026, Question 08.04-17

(5) Effects of Loss of Ventilation

- Justification of stable operation of the TDEFW pumps for at least one hour without active room cooling

Response to NRC RAI


The heat-up analysis is based on conservative assumptions and uses a numerically stable calculation method. The TDEFW pump room air temperature remains below the 175 °F acceptance criterion up to 24 hours after a complete loss of cooling under SBO, which covers the coping period.

4. Summary

4. Summary

- ✓ All open Items with Phase 2 SER have been closed.
 - Open Item 08.03.01-1
 - Open Item 08.03.01-2
 - Open Item 08.03.02-1
 - Open Item 08.04-1
 - Open Item 08.04-2

- ✓ Additional RAIs have been closed.
 - RAI on 8.2 “Bulletin 2012-01”
 - RAI on 8.3.1.4.4.2 “Conformance with RG 1.9”
 - RAI on 8.4.4.3 “Station Blackout Coping Analysis”



MITSUBISHI
HEAVY INDUSTRIES

MOVE THE WORLD FORWARD

**MITSUBISHI
HEAVY
INDUSTRIES
GROUP**

Presentation to ACRS Subcommittee

Chapter 18

September 19, 2019

Mitsubishi Heavy Industries, Ltd.

- **Lead Presenters**

- Joseph Tapia,
Principle Consulting Engineer, MNES
- Kenji Mashio,
Engineering Manager, MHI
- Robert E. Hall,
Consultant, MHI/RTS

- 1. Structure of the submittals**
- 2. US-Basic HSI**
- 3. US-APWR HFE Program Management Plan**

1. Structure of the submittals

Document Lists (1/2)

DCD

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
1	-	4	DCD	Aug. 2013	Sep. 10, 2013	UAP-HF-13212
2	-	0	DCD Revision 4 Update Tracking Report	-	Mar. 14, 2014	UAP-HF-14025
3	-	-	DCD Markup - DCD Tier 1 Section 2.9 Markup - DCD Tier 2 Chapter 1 Markup - DCD Tier 2 Chapter 18 Markup	-	Jun. 4, 2014	UAP-HF-14042

Technical Reports (1/2)

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
4	MUAP-09019	5	Human Factors Engineering Program Management Plan	Aug. 2014	Aug. 22, 2014	UAP-HF-14047
5	MUAP-13005	1	Operating Experience Review Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
6	MUAP-13007	1	Functional Requirements Analysis and Function Allocation Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
7	MUAP-13009	1	Task Analysis Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042

Technical Reports (2/2)

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
8	MUAP-10008	4	Staffing and Qualifications Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
9	MUAP-13014	1	Human Reliability Analysis Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
10	MUAP-10009	4	Human-System Interface Design Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
11	MUAP-10012	4	Human Factors Verification and Validation Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042
12	MUAP-10013	4	Design Implementation Implementation Plan	May 2014	Jun. 4, 2014	UAP-HF-14042

MHI Internal Documents

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
13	JEJC-1763-1001	2	HSI Design Style Guide	May 2008	-	
14	7DS-UAP-20140002	0	Operating Experience Review Results	Aug 2014	-	

Topical Report

#	No.	Rev.	Document Title	Issue Date	Submittal Date	MHI Ref.
15	MUAP-07007	6	Human-System Interface System Description	May 2014	Jun. 4, 2014	UAP-HF-14042

Technical Reports

The US-APWR HFE submittals prior to design certification cover the HFE program management plan (PMP) and 8 HFE element IPs;

- HFE Program Management Plan
- Operating Experience Review (OER)
- Functional Requirements Analysis and Function Allocation (FRA/FA)
- Task Analysis (TA)
- Staffing and Qualifications (S&Q)
- Human Reliability Analysis (HRA)
- HSI Design (HD)
- Verification and Validation (V&V)
- Design Implementation (DI)

- The PMP and IPs address specific HFE activities and provide detailed methodologies for addressing review criteria
- The PMP and IPs each follow the same outline as defined below;
 - Section 1: Purpose
 - Section 2: Scope
 - Section 3: Methodology Overview
 - Section 4: Methodology
 - Section 5: Implementation Team
 - Section 6: Results Summary Report Content
 - Section 7: NUREG-0711 Compliance Evaluation
 - Section 8: References

- HFE activities related to procedure development and training program development are addressed by programs discussed in Chapter 13, Conduct of Operations

COL Items

- COL Applicants address the HFE requirements associated with Human Performance Monitoring

For audit

Following supporting documents were not docketed but audited by NRC staff;

- HSI Design Style Guide
- OER Results

Topical Report

Human-System Interface System Description,
MUAP-07007, Revision 6, May 2014

Purpose/Key issues

- Document and obtain an approval of the US-Basic Human-System Interface (HSI) System (HSIS), incorporating HEDs identified through testing performed with U.S. licensed operators
- Introduced US-Basic HSI simulator
- Formed the foundation of the HFE Implementation Plans (IPs)

Results summary reports will be submitted following the completion of each HFE activity;

- OER (The Basic HSIS OER completed)
- FRA/FA
- TA
- S&Q
- HD
- V&V
- DI

1.3 Future Submittal & ITAAC (2/2)


ITAAC, DCD Tier 1 Section 2.9 Table 2.9-1 (UAP-HF-14042)

Design Commitment	Inspections, Tests, Analyses	Acceptance Criteria
1. The Control Room design incorporates human factors engineering principles that minimize the potential for operator error.	1. An Integrated System Validation (ISV) test will be performed in accordance with the Human Factors Verification and Validation implementation Plan.	1. All pass/fail criteria associated with each test scenario are passed either on initial performance of the scenarios or following remediation of failures.
2. The as-built Control Room Human-System Interface is consistent with the final validated design specifications.	2. An inspection of the as-built Control Room Human-System Interfaces will be performed.	2. The as-built Control Room Human-System Interface conforms to the validated design with no configuration deviations.

1.4 Summary of Document Structure

US-Basic HSI Plant Specific Design Application

Licensing Phase Design Phase



2. US-APWR HFE Program Management Plan

2. US-APWR HFE PMP (1/7)

- ✓ The US-APWR HFE program implementation is in accordance with NUREG-0711, Revision 2, “Human Factors Engineering Program Review Model,” issued February 2004.
- ✓ The HFE program assures that the HSI reflects modern human factors principles and satisfies the applicable regulatory requirements.


2. US-APWR HFE PMP (2/7)

- ✓ The following HFE elements (as defined in NUREG-0711, Revision 2) are covered by the US-APWR HFE Program:
 - HFE PMP
 - OER
 - FRA/FA
 - TA
 - S&Q
 - HRA
 - HD
 - Operating Procedure Development*
 - Training Program Development*
 - V&V
 - DI
 - HPM**

* Procedure Development and Training program development will be reviewed in Chapter 13, Conduct of operation

** COL applicants will develop HPM program

2. US-APWR HFE PMP (3/7)



- ✓ The scope of the HFE PMP includes:
 - HFE design team and organization, roles and responsibilities
 - HFE process and procedures
 - HFE issues tracking (HED process)
 - HFE technical program
 - Combined license (COL) information

- ✓ For HFE activities completed within the scope of the US-APWR design, the program element methodology is described within an implementation plan (IP) and the element is documented in a results summary report (ReSR) as per the IP.

➤ **Assumptions and Constraints Identification**

- ✓ The US-APWR HSIS is based on application of the US-Basic HSIS, which establishes the generic monitoring, alarm, control, and computerized procedure technologies to be employed in the MCR for all plant systems.
- ✓ The generic HSI technologies of the US-Basic HSIS are combined with the specific HSI inventory needed for the US-APWR plant design to create the US-APWR HSIS.
- ✓ The development process for a US-APWR site-specific HSIS confirms or changes the HSI inventory to reflect a site-specific plant.

➤ Assumptions and Constraints Identification (Cont.)

- ✓ A fundamental design assumption and constraint of the US-Basic HSIS that also applies to the US-APWR HSIS is that the plant can be operated with minimum operation staff, one RO and one SRO in the MCR during postulated plant operating modes.

➤ **Applicable Plant Facilities**

- ✓ MCR
- ✓ Remote shutdown room (RSR)
- ✓ Technical support center (TSC)
- ✓ Local control stations* (LCSs)
- ✓ Emergency operations facilities* (EOFs)

* Portion of stations or facilities

3. US-Basic HSI

Documentation of US-Basic HSI features and functions

- Submitted as a topical report, MUAP-07007

The document structure:

- Concept of Operation
- Control room layout
- Display overview and display navigation
- Operational VDU display
- Safety VDU
- Alarms

3.1 Documentation (2/2)

- Computer-based procedures
- Large Display Panel
- Automatic Checking of Actuators
- Diverse HSI Panel
- History of Development of Japanese PWR Main Control Room by Mitsubishi and Japanese PWR Power Utilities (Appendix A)
- HFE V&V Experience in Japan (Appendix B)
- US-Basic HSIS Evaluation Program (Appendix C)

Background

- MHI used the foundational elements of the Japanese-Basic HSIS as a starting point to create the US-Basic HSIS, applying combinations of design review, redesign, and design validation through a phased implementation
- Appendix A contains information about the Japanese-Basic HSIS & development history
 - Developed Japanese-Basic HSIS with Japanese utilities from 1987 to 2003 with guidance from NUREG-0711 and NUREG-0700
 - Japanese operators were involved in conducting V&V
 - Introduced Japanese HSIS to Japanese latest plant design and MCR modernization
 - No performance issues identified

3.3 Structure of the HSIS

- The Japanese HSIS, as applied in the U.S., is comprised of;
 - The Basic HSIS
 - The HSI Inventory (i.e., controls, displays, alarms) which will be developed as a part of the plant-specific analysis phase of the HFE design program

- The HSI Inventory is developed as part of the US-APWR DC in accordance with the US-APWR HFE program

3.4 Phased Implementation

Phase 1 (Topical Report scope)

Translated the Japanese-Basic HSIS to the US-Basic HSIS

Phase 2

Develop an application specific (e.g. US-APWR) inventory, which will be combined with the US-Basic HSIS to yield an application specific design

Phase 3

Confirm the site-specific assumptions of Phase 2 and/or make minor site specific changes to finalize the application design

Phase 1

Translated the Japanese-Basic HSIS to the US-Basic HSIS

Phase 1a

- Addressed language, engineering units, anthropometric changes to the consoles for American body types
- Adopted the US-style step-by-step operating procedures
- Made improvements identified from completing the OER program element from NUREG-0711 which included U.S. nuclear plants and additional, generic, digital HSI technology experience

Phase 1b

- Resolved deficiencies from Phase 1a, validated design changes, and updated Section 4 of the topical report (Revision 2) to reflect these changes

3.6 The US-Basic HSIS test

- In Phase 1a and 1b, the tests were implemented using the
 - US-Basic HSIS simulator
 - Static portable HSIS analysis tool
- U.S. licensed operators participated in dynamic testing: 8 crews (22 persons in total (Phase 1a)) and 5 crews (10 persons (Phase 1b))
- Went through seven scenarios that included normal and emergency events under normal as well as degraded HSI conditions
- Phase 1a results identified difference between Japan and U.S. operation style and identified design improvements documented via HEDs
- An expert panel (HFE, I&C, plant operations, US-APWR systems engineers) was organized to resolve HEDs
- Phase 1b tested design changes

- OE Sources include;
 - NUREG/CR-6400, “HFE Insights For Advanced Reactors Based Upon Operating Experience,”
 - INPO database
 - Japan Nuclear Technologies Institute (JANTI) Nuclear Information Archives (NUCIA) database
 - Issues obtained from non-nuclear industries (similar HSIS technologies) in U.S. and Japan
- Findings were evaluated and included in the US-Basic HSIS



Presentation to the ACRS Subcommittee

**Mitsubishi Heavy Industries, Ltd.
US-APWR Design Certification Application Review**

Project History and Recent and Future Actions

George Wunder – Lead Project Manager

September 19, 2019

Project History – US-APWR Design Certification Review

Application submitted December 31, 2007

Application docketed February 29, 2008

Phase 3 meetings held on between summer 2011 and spring 2013

On November 5, 2013, applicant announced reduced support

Applicant made clear their commitment to completing project

Review has continued at reduced pace since 2013.

Recent and Future Actions

In early 2018 applicant identified areas for progress

Applicant revised advanced accumulator (MUAP-07001) topical report

Applicant identified Chapters 5, 7, 8, 10, 18, for Phase 4 completion

Advanced accumulator SER with CIs submitted June 2018

Advanced accumulator Cis closed June 2019

MUAP-07001, Chapters 8 and 18 submitted June-August 2019

Chapters 5, 7, and 10 under review for 2020 Subcommittee meeting

- The concept of operation is addressed in Section 4.1

- The US-Basic HSIS addresses the following subjects:
 - Crew composition
 - Roles and responsibilities
 - Personnel interaction with plant automation
 - Use of control room resources by crewmembers
 - Methods used to ensure good coordination of crewmember activities, including non-licensed operators, technicians, and maintenance personnel

3.8.1 Concept of Operation (2/6)


- Operating crew composition
 - The normal MCR staffing consists of one RO and one SRO
 - The normal MCR staff is supplemented by one additional SRO and one additional RO that will be at the plant to accommodate unexpected conditions
 - While the HSIS is designed to support the minimum MCR staffing described above, the space and layout of the MCR are designed to accommodate the foreseen maximum number of operating and temporary staff

The S&Q IP handles further staffing levels for the US-APWR

3.8 US-Basic HSI Design Features

3.8.1 Concept of Operation (3/6)

MCR personnel allocation



3.8.1 Concept of Operation (4/6)

- The computer-based HSIS provides operational visual display units (VDUs) as the fundamental interface. The operator monitors plant status and initiates actions from a VDU by touching or clicking on the appropriate sections of the screen
- The operators workload is significantly reduced by providing relevant process control information in integrated displays on the VDUs and utilizing a compact console that minimizes required operator movement
- The HSIS also provides operational support functions that utilize the computer to consolidate large amounts of data into meaningful displays
- Section 4.1 identifies further specific interfaces and responsibilities between the crew and the HSIS

- Control Room Crew coordination with the HSIS
 - Control Room Crew coordination with the HSIS is described in each HSI design feature
 - The Large Display Panel (LDP) provides Spatially Dedicated Continuously Visible (SDCV) information to the operation personnel to enhance situation awareness
 - Helps operators maintain continuous awareness of overall plant status and critical status changes
 - The secondary purpose is to help the operations staff coordination and communication by providing a common visualization of plant information
 - The Operator Console provides all monitoring and control functions which are available in the MCR so that ROs can perform all operation tasks using the Operator Console from a seated position

3.8 US-Basic HSI Design Features

3.8.1 Concept of Operation (6/6)

- The Supervisor Console, located behind the RO, provides the same display set as those on the Operator Console, without control functions
- The STA console provides the same display set as those on the Operator Console, without control functions as well
- Each console has paging phones and internal phones to communicate with local staff
- Maintenance console, which is a temporary console (disconnected from the digital data communication bus during normal plant operation) used to support an additional operator in the MCR for tests during plant shutdown conditions and periodic inspections
- Tagging feature on the O-VDU and physical tag for local component are also addressed to support maintenance activities between MCR crew and maintenance staff

3.8 US-Basic HSI Design Features

3.8.2 The US-Basic HSIS Overview

US-Basic HSIS simulator



3.8.3 Large Display Panel (1/4)

- LDP provides plant overview information and alarms to enhance MCR staff awareness of the plant status (i.e., presents spatially-dedicated continuously visible (SDCV) critical safety and power production functions with supporting component status and parameters and is the apex of entire HSI information hierarchy)

- LDP provides computer aided operator's support information;
 - i) OK monitors (computer checking relevant component status at Reactor Trip, ECCS, CV isolation, etc.,)
 - ii) Critical safety function status
 - iii) Bypass or inoperable status indication (BISI) along with safety signals (e.g., Reactor Trip, ECCS, CV isolation)

Additional detailed information is displayed in the O-VDU screens



Presentation to the ACRS Subcommittee

**Mitsubishi Heavy Industries, Ltd.
US-APWR Design Certification Application Review**

Safety Evaluation with No Open Items: Chapter 8

ELECTRIC POWER

September 19, 2019

Technical Topics

Section 8 – Electric Power

Technical Topics

- US-APWR electric power system comprises of the following systems:
 - ♦ Offsite power system
 - ♦ Onsite AC power system, including 4 Class 1E trains each with a Class 1E Gas Turbine Generator (GTG), and Alternate AC source
 - ♦ Onsite DC Power System, including 4 trains of Class 1E 125Vdc

- Staff's review:
 - ♦ In the Phase 4 review the staff concluded that the DCD application, Chapter 8 met all applicable regulatory criteria.
 - ♦ In particular, the staff will discuss the closure of the following open items:
 - ♦ Open Phase Conditions (OPC)
 - ♦ GTG Reliability

Technical Topics

Section 8 – Electric Power

Open Item #1: OPC

- Design criteria to address OPC includes:
 - Detection
 - Alarm
 - Response to a open phase conditions
- ♦ OPC protection features per BTP 8-9
 - COL Item 8.2(12) requires the COL applicant to identify the type of open phase detection and protection (OPDP) system.

Technical Topics

Section 8 – Electric Power

Resolution of Open Item #1

- ♦ COL Item 8.2(12) will ensure that the COL applicant will determine an OPDP system that meets the guidance in BTP 8-9 including detection, alarm in the main control room (MCR), and protection features in that the Class 1E medium voltage buses will transfer to a power source without an open phase condition.
- ♦ DCD Tier 2, Section 8.2, includes a general description of the criteria for addressing OPC.
- ♦ ITAACs were added to verify that:
 - The OPDP system can detect an open phase condition.
 - The OPDP system can provide an alarm in the MCR upon detection of an OPC.
 - Class 1E medium voltage buses are automatically separated from the degraded offsite source, transferred to the alternate power source or onsite standby source.
- ♦ TS were modified to incorporate surveillance requirements for OPC protection.

Technical Topics

Section 8 – Electric Power

Open Item #2: GTG Reliability

- ◆ MHI proposed the use of GTG as the Class 1E emergency power source.
- ◆ The challenges of this proposal included:
 - First of a kind application in the nuclear fleet, therefore there was no operating experience
 - No reliability data available
- ◆ In absence of operating experience and reliability data, the staff requested the applicant to perform type tests to ensure GTGs will perform their intended function and achieve their target reliability level.

Technical Topics

Section 8 – Electric Power

Resolution of Open Item #2

- ♦ The GTGs have been qualified for Class 1E application using methodology and assumptions in Technical Reports MUAP 07024-P, “Qualification and Test Plan of Class 1E Gas Turbine Generator System.”
- ♦ The applicant documented the successful qualification of the Class 1E GTGs in Technical Reports MUAP-10023-P, “Initial Type Test Result of the Class 1E Gas Turbine Generator.”
- ♦ The result presented in Technical Report MUAP-10023-P states that to satisfy the starting reliability of 0.975 with 95 percent confidence, 150 start tests should be performed with no failures.
 - MHI performed 150 start and load acceptance tests of the GTGs.
 - The staff finds that these tests prove that the GTGs satisfy the reliability criterion of 0.975 with 95 percent confidence.
- ♦ In conclusion, the staff finds that the applicant’s approach to demonstrating Class 1E GTG reliability is adequate, considering compliance with GDC 17, conformance to RG 1.155, as well as successful qualification via type testing.



Mitsubishi APWR Design Certification Review

SER Chapter 18

Human Factors Engineering Program

Presentation to the ACRS Subcommittee September 19, 2019

Chapter 18 Review Team



Technical Staff

- Brian Green, Ph.D. NRR/DIRS/IRAB


Project Manager

- George Wunder, NRO/DLSE/LB3

Overview

- The HFE design described in the Topical Report MUAP-07007 conforms to NUREG-0700.
- DCD Scope conforms to NUREG-0711, revision 2
 - Implementation plans are complete
 - Level of detail is sufficient to assess implementation effectiveness
 - ITAAC are used to verify acceptable results
 - Final design results are provided for the following HFE elements: HFE Program Management, Operating Experience, Human Reliability Analysis

Overview: Iteration is Key



PREDECESSOR DESIGN

- Designed using process like NUREG-0711

BASIC DESIGN PLATFORM

- Phase 1a/1b
- Topical Report MUAP-07007
- Americanizing the predecessor design

ITERATION with NUREG-0711

- Phase 2a/2b
- Implementation Plans (IPs) used to analyze, design, verify/validate
- Development of HSI inventory

FINAL DESIGN

- Phase 3a/3b
- Design, verify/validate, and implement site-specific aspects
- Operator training

Topical Report Comments

- At the time the Phase 4 SER was written, the US-Basic Human-System Interface (HSI) System was the most detailed design description staff had reviewed.
- Audit and review of the HFE design descriptions verified the design conforms to NUREG-0700 (HSI design guidelines).
- Full scope simulator was used effectively in the design process.

Design Certification Comments



- Reviewed to ensure the Implementation Plans were included by reference and there were no inconsistencies with the Implementation Plans.
- Includes ITAAC to confirm adequate completion of Implementation Plans.

Implementation Plans

HFE Area	Level of Review
HFE Program Management	Complete Element
Operating Experience Review	Implementation Plan
Functional Requirements Analysis and Function Allocation	Implementation Plan
Task Analysis	Implementation Plan
Staffing and Qualifications	Implementation Plan
Human Reliability Analysis	Complete Element
Human-System Interface Design	Implementation Plan
Procedure Development	See Chapter 13
Training Program Development	See Chapter 13
Human Factors Verification and Validation	Implementation Plan
Design Implementation	Implementation Plan
Human Performance Monitoring	COL action Item

Status of Open/Confirmatory Items



- There no Open Items.
- There are no Confirmatory Items.

Conclusions

- The topical report describes an acceptable generic platform referred to as the US-Basic HSI.
- Implementation Plans provide confidence that iteration on the US-Basic HSI will be consistent with “state-of-the-art human factors principles” and US regulations.
- DCD Chapter 18 uses ITAAC to confirm that acceptable HFE practices are incorporated into the final US-APWR design.