



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76012

PDR
LPDR
TIC ✓
NSIC
CENTRAL FILES

April 2, 1980

In Reply Refer To:

RIV


Docket Nos. 50-498/IE Information Notice No. 80-14
50-499/IE Information Notice No. 80-14

Houston Lighting & Power Company
ATTN: Mr. E. A. Turner, Vice President
Power Plant Construction and
Technical Services
Post Office Box 1700
Houston, Texas 77001

Gentlemen:

The enclosed IE Information Notice provides information regarding the practices to be followed by NRC inspectors when they receive expressions of concern related to safety from plant employees.

Sincerely,


Karl V. Seyfrit
Director

Enclosures:

1. IE Information Notice
No. 80-14
2. List of IE Information
Notices Recently Issued

8004240216

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

SSINS No.: 6870
Accession No.:
8002280649

IE Information Notice No. 80-14
Date: April 2, 1980
Page 1 of 1

SAFETY SUGGESTIONS FROM EMPLOYEES

On February 29, 1980, the NRC Office of Inspection and Enforcement issued an instruction to NRC inspectors on the handling of safety suggestions received from licensee employees during inspections. A copy of the instruction, Temporary Instruction No. 1210/1, is enclosed.

The purpose of this instruction is to reaffirm to inspectors that they must be sensitive to the safety concerns of employees. We encourage employees to attempt resolution of their safety concerns through the normal communication channels to their supervisors and managers. Nevertheless, there are instances where an employee apparently feels more comfortable expressing his or her safety concerns to an NRC inspector. In these cases, the inspector will follow the practices described in the enclosed instruction.

We suggest that licensees post this Information Notice and the enclosed instruction in an area where employees can read them.

Enclosure:
IE Temporary Instruction
No. 1210/1

SAFETY SUGGESTIONS RECEIVED DURING INSPECTIONS

During inspections, inspectors may receive safety suggestions relating to plant conditions or operations from licensee employees. Inspectors must be receptive to such suggestions and should attempt to resolve or deal with each one received. Even in those cases where the suggestion would require a licensee to do more than is required by NRC regulations, license conditions, or technical specifications, the inspector should discuss the suggestion with the employee and provide, to the best of the inspector's ability, the options that are available.

Depending upon the nature of the suggestion, some possible courses of action are as follows:

1. Encourage the employee to forward the suggestion in writing to plant management and, if appropriate, to the NRC.
2. For matters clearly under the jurisdiction of another Federal agency, or a state or local agency, encourage the employee to contact the appropriate agency, or offer to bring the information to the attention of the proper official.
3. Inform the employee that the matter will be evaluated and, if appropriate, brought to the attention of NRC management.

It is important that an employee proffering a suggestion related to safety be made aware that the NRC is interested in such suggestions and they will be pursued.

LISTING OF RECENTLY ISSUED
IE INFORMATION NOTICES

Information Notice No.	Subject	Date Issued	Issued To
80-09	Possible Occupational Health Hazard Associated With Closed Cooling Systems For Operating Power Plants	3/7/80	All holders of power reactor Operating Licenses (OLs) and near term Construction Permits (CPs)
80-10	Partial Loss of Non-Nuclear Instrument System Power Supply During Operation	3/7/80	All Power reactor facilities holding Operating Licenses (OLs) and Construction Permits (CPs)
80-11	General Problems with ASCO Valves in Nuclear Application Including Fire Protection Systems	3/14/80	All holders of Reactor Operating License (OL), Construction Permit (CP), fuel fabrication and processing facilities
80-12	Instrument Failure Causes Opening of PORV and Block Valve	3/31/80	All holders of Power Reactor Operating Licenses (OLs) and Construction Permits (CPs)
80-13	General Electric Type SBM Control Switches - Defective Cam Followers	4/2/80	All light water reactor facilities holding power reactor Operating Licenses (OLs) and Construction Permits (CPs)

Enclosure