



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 13, 2019

Mr. Tim Hanley
BWRVIP Chairman, ATTN: Debbie Rouse
Exelon Corporation
1300 West W.T. Harris Boulevard (Building 1)
Charlotte, NC 28262-8550

Mr. Nathan Palm
BWRVIP Program Manager
Electric Power Research Institute
1300 West W.T. Harris Boulevard (Building 1)
Charlotte, NC 28262-8550

SUBJECT: COLUMBIA GENERATING STATION – DISPOSAL OF 300 DEGREE
RECONSTITUTED SURVEILLANCE SPECIMENS (EPID L-2019-PMP-0050)

Dear Messrs. Hanley and Palm:

On July 11, 2019, the Electric Power Research Institute (EPRI) and the BWR [Boiling Water Reactor] Vessel and Internals Project (BWRVIP) group documented a request to the U.S. Nuclear Regulatory Commission (NRC) (Agencywide Documents Access and Management System (ADAMS) Accession No. ML19196A107) concerning the future disposal schedule of the BWRVIP Integrated Surveillance Program (ISP) (located at the 300 degree azimuth) capsule at Columbia Generating Station (Columbia) per Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, Appendix H, "Reactor Vessel Material Surveillance Program Requirements," Section III(B.3), "Surveillance Program Criteria."

The letter addresses the 300 degree surveillance capsule for Columbia, which currently resides in the Columbia spent fuel pool and requests NRC permission to dispose of the specimens in the future, in the event that a need should arise for Energy Northwest (the licensee) to dispose of them.

The BWRVIP's technical justification for the future disposal is that:

1. It is not possible to repair or return the 300 degree specimens to the reactor pressure vessel (RPV) due to the mechanical failure of the specimen rod to basket interface, which occurred in 2017, although the specimens remain in the basket and are intact.
2. Columbia is not a host plant under the ISP program and there are no current or future plans under the ISP to withdraw or test any surveillance capsules from the Columbia RPV, but the specimens are currently retained by the site without NRC approval for disposition.
3. Two other surveillance capsules that were installed prior to plant startup still reside in the Columbia RPV and, should the need arise, are still available for testing. Inspections of

these two surveillance capsules were performed during the May 2017 refueling outage and no signs of wear, degradation, or movement were identified. Additionally, historical test data for the original 300 degree location specimen (completed in 1996) is retained and available—the current 300 degree specimen in the spent fuel pool is a reconstituted sample that was established in 1997.

NRC staff has reviewed the letter, the stated technical justification, and finds that the EPRI BWRVIP request for disposal is acceptable and meets the requirements of 10 CFR Part 50, Appendix H Section III(B.3).

If you have any questions regarding this matter, I may be reached at (301) 415-5136 or via e-mail at John.Klos@nrc.gov.

Sincerely,

/RA/

L. John Klos, Project Manager
Plant Licensing Branch IV
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos: 99902016 and 50-397

cc: Mr. Bradley J. Sawatzke
Chief Executive Officer
Energy Northwest
MD 1023
76 North Power Plant Loop
P.O. Box 968
Richland, WA 99352

Listserv

SUBJECT: COLUMBIA GENERATING STATION – DISPOSAL OF 300 DEGREE
RECONSTITUTED SURVEILLANCE SPECIMENS (EPID L-2019-PMP-0050)
DATED NOVEMBER 13, 2019

DISTRIBUTION:

PUBLIC

PM File Copy

RidsACRS_MailCTR Resource

RidsNrrDorlLpl4 Resource

RidsNrrPMColumbia Resource

RidsNrrLAPBlechman Resource

RidsRgn4MailCenter Resource

RidsNrrDnrlNvib Resource

ADAMS Accession No. ML19309F171

OFFICE	NRR/DORL/LPL4/PM	NRR/DORL/LPL4/LA	NRR/DMLR/MVIB	NRR/DORL/LPL4/BC	NRR/DORL/LPL4/PM
NAME	JKlos	PBlechman	Dave Alley	JDixon-Herrity	JKlos
DATE	11/5/2019	11/8/2019	10/10/2019	11/13/19	11/13/19

OFFICIAL RECORD COPY