

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N | C | B | E | P | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 57 CAT 58

CON'T
01 | L | 0 | 5 | 0 | - | 0 | 3 | 2 | 4 | 7 | 0 | 3 | 2 | 5 | 8 | 0 | 8 | 0 | 4 | 2 | 2 | 8 | 0 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | While performing PT 1.7.1PC, Accumulator Leak Detection Instrumentation Calibration
03 | and Functional Test, the leak detection level switch for HCU 26-47 did not actuate.
04 | No water was noted on the nitrogen side of the accumulator, and the other 136 HCU's
05 | passed the PT.
06 |
07 |

Technical Specifications 3.1.3.5, 6.9.1.9b

09 | R | B | E | A | I | N | S | T | R | U | S | Z |
9 10 11 12 13 18 19 20
17 | LER/RO REPORT NUMBER | 8 | 0 |
21 22
18 | A | Z | Z | Z | 0 | 0 | 0 | 0 | N | Y | N | G | 0 | 8 | 0 |
33 34 35 36 37 40 41 42 43 44 47
22 | HOURS | 0 | 0 | 0 | 0 |
37 40
23 | ATTACHMENT SUBMITTED | N |
41 40
24 | NPD-4 FORM SUB. | Y |
42 43
25 | PRIME COMP. SUPPLIER | N |
43 44
26 | SEQUENTIAL REPORT NO. | 0 | 2 | 7 |
24 26
27 | OCCURRENCE CODE | 0 | 3 |
28 29
28 | REPORT TYPE | L |
30 31
32 | REVISION NO. | 0 |
32 32
31 | VALVE SUBCODE | Z |
20 20
30 | COMP. SUBCODE | S |
19 19
29 | COMPONENT CODE | I | N | S | T | R | U |
13 13 13 13 13 13 13 13
27 | CAUSE SUBCODE | A |
12 12
23 | CAUSE CODE | E |
11 11
22 | SYSTEM CODE | R | B |
9 10 10 10

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The contacts on the switch were not making; therefore, the switch was replaced with a
11 | new switch from stock, and the PT was successfully completed. This is considered an
12 | isolated event, and no further action is required.
13 |
14 |

15 | H | 0 | 0 | 0 | N/A | B | Periodic Test
7 8 9 10 12 13 44 45 46 80
16 | Z | Z | N/A | N/A |
7 8 9 10 11 44 45 80
17 | 0 | 0 | 0 | Z | N/A
7 8 9 11 12 13 80
18 | 0 | 0 | 0 | N/A
7 8 9 11 12 80
19 | Z | N/A
7 8 9 10 12 80
20 | N | N/A
7 8 9 10 80

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521
8004280592