

FOLLOW-UP
LER NO. 80-13/3L
DOCKET NO. 50-317
EVENT DATE 02/25/80
REPORT DATE 03/25/80
ATTACHMENT

CAUSE DESCRIPTION AND CORRECTIVE ACTION: (CONTINUED)

Facility Change Request 80-25 has been originated to allow replacement of several industrial grade capacitors with MILSPEC devices to improve the reliability of this instrument as recommended by the manufacturer. Contingent on approvals, it is estimated that the Field Change will be completed by January 1, 1981.