

March 21, 1980

Office of Inspection and Enforcement
Region I
Attention: Mr. Boyce H. Grier, Director
U. S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406


Dear Mr. Grier:

Re: Nine Mile Point Unit 2
Docket No. 50-410

Your February 6, 1980 I.E. Bulletin 80-03 requested Niagara Mohawk to visually inspect charcoal adsorber cells for leakage or loss of charcoal. The charcoal adsorber cells for Nine Mile Point Unit 2 have not been received on site. These cells will be manufactured by the Mine Safety Appliances Company. Their design will utilize spot welding every 3/4 inch to prevent the loss of charcoal from adsorber cells.

Very truly yours,

NIAGARA MOHAWK POWER CORPORATION



James Bartlett
Executive Vice President

PEF:jk

cc: Director

Division of Fuel Facility and Materials Safety Inspection
Office of Inspection and Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555